



**RETURN BIDS TO:**  
**RETOURNER LES SOUMISSIONS À:**  
Bid Receiving Public Works & Government  
Services Canada/Réception des soumissions Travaux  
publics et Services gouvernementaux Canada  
1713 Bedford Row  
Halifax, N.S./Halifax,(N.E.)  
B3J 1T3  
Halifax  
Bid Fax: (902) 496-5016

## SOLICITATION AMENDMENT MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

### Comments - Commentaires

Vendor/Firm Name and Address  
Raison sociale et adresse du  
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution  
Atlantic Region Acquisitions/Région de l'Atlantique  
Acquisitions  
1713 Bedford Row  
Halifax, N.S./Halifax, (N.E.)  
B3J 3C9  
Halifax  
Nova Scot

<b>Title - Sujet</b> Big Bras d'Or Deck Replacement	
<b>Solicitation No. - N° de l'invitation</b> EB144-161695/A	<b>Amendment No. - N° modif.</b> 004
<b>Client Reference No. - N° de référence du client</b> EB144-16-1695	<b>Date</b> 2015-12-16
<b>GETS Reference No. - N° de référence de SEAG</b> PW-\$PWA-310-5319	
<b>File No. - N° de dossier</b> PWA-5-74130 (310)	<b>CCC No./N° CCC - FMS No./N° VME</b>
<b>Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2015-12-18</b>	<b>Time Zone</b> Fuseau horaire Atlantic Standard Time AST
<b>F.O.B. - F.A.B.</b> <b>Plant-Usine:</b> <input type="checkbox"/> <b>Destination:</b> <input checked="" type="checkbox"/> <b>Other-Autre:</b> <input type="checkbox"/>	
<b>Address Enquiries to: - Adresser toutes questions à:</b> Stevenson, Jacquelyn	<b>Buyer Id - Id de l'acheteur</b> pwa310
<b>Telephone No. - N° de téléphone</b> (902) 403-3520 ( )	<b>FAX No. - N° de FAX</b> (902) 496-5016
<b>Destination - of Goods, Services, and Construction:</b> <b>Destination - des biens, services et construction:</b>	

Instructions: See Herein

Instructions: Voir aux présentes

<b>Delivery Required - Livraison exigée</b>	<b>Delivery Offered - Livraison proposée</b>
<b>Vendor/Firm Name and Address</b> <b>Raison sociale et adresse du fournisseur/de l'entrepreneur</b>	
<b>Telephone No. - N° de téléphone</b> <b>Facsimile No. - N° de télécopieur</b>	
<b>Name and title of person authorized to sign on behalf of Vendor/Firm (type or print)</b> <b>Nom et titre de la personne autorisée à signer au nom du fournisseur/de l'entrepreneur (taper ou écrire en caractères d'imprimerie)</b>	
<b>Signature</b>	<b>Date</b>

**Solicitation No. - N° de l'invitation**  
EB144-161695/A  
**Client Ref. No. - N° de réf. du client**  
EB144-161695

**Amd. No. - N° de la modif.**  
004  
**File No. - N° du dossier**  
PWA-5-74130

**Buyer ID - Id de l'acheteur**  
PWA310  
**CCC No./N° CCC - FMS No/ N° VME**

#### Amendment 004

This amendment is being raised to answer questions that have been asked as well as ensure the appropriate Unit Price Table is being used.

**Delete** the Unit Price Table located in Appendix 1.

**Insert** the below Unit Price Table

Item	Specification Reference	Class of Labour, Plant or Material	Unit of Measurement	Estimated Quantity (EQ)	Price per Unit applicable taxe(s) extra (PU)	Extended amount (EQ x PU) applicable taxe(s) extra
1	03.30.00	Reinforced Concrete Deck	sm	460		
2	31.53.13	Treated Timber Cribwork Replacement	cm	20		
3	31.53.16	Treated Dimension Timber	cm	29.8		
4	31.53.16	Untreated Dimension Hardwood Timber	cm	5.8		
5	35.59.29	Mooring Cleats	Each	8		
6	05.50.00	Ladders	Each	6		
7	35.59.00	UHMW Panels (1200x3000x38mm)	Each	20		
<b>TOTAL EXTENDED AMOUNT (TEA)</b> Excluding applicable taxe(s)						

<b>TOTAL BID AMOUNT (LSA +TEA)</b> Excluding applicable taxe(s)	
--	--

**Question:**

Would a precast concrete deck be accepted on this project?

**Answer:**

The Contractor should bid the project as tendered with a cast-in-place deck system. Alternative delivery would be reviewed upon submission by the successful Contractor according to specification section 01 61 00 Clause 1.3

**Question:**

How many ladders will be required?

**Answer:**

Estimated Quantity of item #6 Ladders to be revised to 8.