

# Addendum / Addenda

Project Description / Description de projet <b>S 77 Heating Rad Replacement</b>		
Solicitation No./N° de sollicitation <b>15-22142</b>	Project No./N° de projet <b>4017</b>	W.O. No./N° d'ordre de travail <b>A1-006436-01</b>
Departmental Representative / représentant ministériel <b>Allan Smith</b>		Date <b>December 16, 2015</b>
<b>Notice:</b> This addendum shall form part of the tender documents and all conditions shall apply and be read in conjunction with the original plans and specifications.		<b>Nota:</b> Cet addenda fait partie intégrale des dossiers d'appel; toutes les conditions énoncées doivent être lues et appliquées en conjonction avec les plans et les devis originaux.

**1 What is included in Cost Allowance?**

Refer to the Appendix "A" of the Tender Form

**2 Who removes the Furniture/Articles from around the Rads being removed?**

The Client will be responsible to remove anything that is Client related. Tables, Chairs, other misc items are the responsibility of this Contractor to relocate and put back into place when work is complete

**3 Provide Drawings of main Supply and Return HW Risers**

Refer to the Drawings, the numbers shown primarily on the exterior of the building indicate the Risers in which serve the adjacent Rads. Note the Risers will be isolated by NRC. The Contractor is required to perform work only on those Risers that have been isolated. Until such time that the Contractor has completed "all" work on that Riser to the satisfaction of the NRC Rep and as per plans and Specifications, the Contractor will not be able to advance to the next Riser. This Contractor is to assist NRC with all aspects of filling of the system prior to acceptance of the Riser.

**4 Tag # 1056A not on Drawing?**

This Rad does not exist, it is part of an Electrical Room. Disregard the information pertaining to this Rad in the Schedule.

**5 Tag # 1125, not listed in Schedule?**

Use the same information listed for Tag # 2125-1 on 4014 - M201

**6 Security Note**

All bidders are required to make special note of Section 5 of the "Buy and Sell Notice". This will be strictly enforced.

## 7 Access to Pictures in the Cloud

The following are the links to pictures of the Rads and their surroundings;

<https://plus.google.com/photos/112389216694547802807/albums/6148047493478984465?authkey=CNPDs-bYoOf4zwE>

BSMT

<https://plus.google.com/photos/112389216694547802807/albums/6148048761408801617?authkey=CKHJ3cbOkb3DyAE>

FL01

<https://plus.google.com/photos/112389216694547802807/albums/6148050107309986497?authkey=CMS46Ynaw5jxRg>

FL02

<https://plus.google.com/photos/112389216694547802807/albums/6148051119543932769?authkey=CPGDi5HD-eiGlwE>

FL03

## 8 Alternate acceptable Radiators

Acceptable alternate Manufacturer is Sigma, model # J43690. Contact HTS OTTAWA

## 9 Quick ship of Radiation Products

Due to the timelines of this Project there is a requirement that (25%) of the Radiation Products required must be **shipped within 10 business days** from Shop Drawing Approval.

## 10 Project Completion Date

Refer to General Instructions Section 00 10 00 3.1; **CHANGE ( Complete all work within 16 week(s) after receipt of notification of acceptance of tender ) TO ( This Project is to be complete prior to March 31st 2016 )**

END / FIN

