



**RETURN BIDS TO:**  
**RETOURNER LES SOUMISSIONS À:**  
**Public Works Government Services Canada- Bid**  
**Receiving / Réception des soumissions**  
**189 Prince William Street**  
**Room 405**  
**Saint John**  
**New Brunswick**  
**E2L 2B9**

## SOLICITATION AMENDMENT MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

### Comments - Commentaires

**Vendor/Firm Name and Address**  
**Raison sociale et adresse du**  
**fournisseur/de l'entrepreneur**

**Issuing Office - Bureau de distribution**  
**Public Works Government Services Canada- Bid**  
**Receiving / Réception des soumissions**  
**189 Prince William Street**  
**Room 405**  
**Saint John**  
**New Bruns**  
**E2L 2B9**

<b>Title - Sujet</b> System Decommissioning, Bunker C	
<b>Solicitation No. - N° de l'invitation</b> EC016-161469/A	<b>Amendment No. - N° modif.</b> 005
<b>Client Reference No. - N° de référence du client</b> R.061874.001	<b>Date</b> 2015-12-18
<b>GETS Reference No. - N° de référence de SEAG</b> PW-\$PWB-101-3744	
<b>File No. - N° de dossier</b> PWB-5-38127 (101)	<b>CCC No./N° CCC - FMS No./N° VME</b>
<b>Solicitation Closes - L'invitation prend fin</b> <b>at - à 02:00 PM</b> <b>on - le 2016-01-07</b>	<b>Time Zone</b> <b>Fuseau horaire</b> Atlantic Standard Time AST
<b>F.O.B. - F.A.B.</b> <b>Plant-Usine:</b> <input type="checkbox"/> <b>Destination:</b> <input checked="" type="checkbox"/> <b>Other-Autre:</b> <input type="checkbox"/>	
<b>Address Enquiries to: - Adresser toutes questions à:</b> Lomax, Sandra	<b>Buyer Id - Id de l'acheteur</b> pwb101
<b>Telephone No. - N° de téléphone</b> (506) 636-4362 ( )	<b>FAX No. - N° de FAX</b> (506) 636-4376
<b>Destination - of Goods, Services, and Construction:</b> <b>Destination - des biens, services et construction:</b>	

**Instructions: See Herein**

**Instructions: Voir aux présentes**

<b>Delivery Required - Livraison exigée</b>	<b>Delivery Offered - Livraison proposée</b>
<b>Vendor/Firm Name and Address</b> <b>Raison sociale et adresse du fournisseur/de l'entrepreneur</b>	
<b>Telephone No. - N° de téléphone</b> <b>Facsimile No. - N° de télécopieur</b>	
<b>Name and title of person authorized to sign on behalf of Vendor/Firm</b> <b>(type or print)</b> <b>Nom et titre de la personne autorisée à signer au nom du fournisseur/</b> <b>de l'entrepreneur (taper ou écrire en caractères d'imprimerie)</b>	
<b>Signature</b>	<b>Date</b>

This Solicitation Amendment No. Five (5) is raised to include the following Addendum No. Five (5).

The following Addendum to the tender is effective immediately. This addendum shall form part of the contract documents.

**All other terms and conditions remain the same.**

**1. EXTENSION OF TIME**

Notice is hereby given that the time for the reception of tenders previously due December 23, 2015 is hereby extended to 14:00 hours, January 7, 2016.

**2. CLARIFICATION**

Section 01 10 10 General Instructions 1.1 Description of Work

.2 The contractor is to provide a written Tank Cleaning and Dismantling Procedure for review with their bid package, including an emergency spill response procedure.

**Clarification:**

The bid will be evaluated based on price (lowest bidder) and not on the content of the Cleaning and Dismantling Procedure. The purpose of submitting the procedure is to verify that the bidder complies with all applicable federal and provincial codes of practice, guidelines and regulations, as well as operational requirements of the Institution. If the Cleaning and Dismantling Procedure submitted by the lowest bidder is not acceptable, it will be returned to the bidder for re-submittal. The bidder shall maintain their bid.

**3. QUESTIONS AND ANSWERS**

Q1: Is the vault currently considered a confined space?

A1: Vault is a not a confined, but Tanks are a confined space.

Q2: In order to heat the product inside the tank for removal a steam boiler will be required to run continuously for multiple days. With the working limitation on site being restricted to 7.5 hrs per day, will the boiler be permitted to run unattended? Suggestion: Provision of commissionaire to facilitate 24 hr per day while boiler running and work restricted to boiler supervision only. It will be hard to heat product for removal if boiler can be allowed to run continuously. It is not safe to allow the boiler to run without supervision.

A2: Commissionaire are not permitted to monitor a boiler overnight, it will be up to the general contractor to monitor the boiler as per code requirements.

Q3: Where will the boiler be permitted for installation?

A3: The temporary fence compound used for the stack demolition project is being kept as part of the bunker C system decommissioning project, the boiler truck will be inside this compound.

Solicitation No. - N° de l'invitation  
EC016-161469/A  
Client Ref. No. - N° de réf. du client  
EC015-161469

Amd. No. - N° de la modif.  
005  
File No. - N° du dossier  
PWB-5-31827

Buyer ID - Id de l'acheteur  
PWB 101  
CCC No./N° CCC - FMS No./N° VME

---

Q4: How should the vault roof be secured every day?

A4: The roof openings must be secured at the end of every working day for safety concerns and the door to the vault must be locked.