



RETURN BIDS TO:

RETOURNER LES SOUMISSIONS Á:

Parks Canada Agency
1300 - 635 8 Ave SW
Calgary, AB T2P3M3
Bid Fax: (403) 292-4475

AMENDMENT / MODIFICATION

001

Tender To: Parks Canada Agency

We hereby offer to sell to Her Majesty the Queen in right of Canada, in accordance with the terms and conditions set out herein, referred to herein or attached hereto, the goods, services, and construction listed herein and on any attached sheets at the price(s) set out therefor.

Soumission aux: l'Agence Parcs Canada

Nous offrons par la présente de vendre à Sa Majesté la Reine du Chef du Canada, aux conditions énoncées ou incluses par référence dans la présente at aux annexes ci-jointes, les biens, services et construction énumérés ici et sur toute feuille ci-annexée, au(x) prix indiqué(s).

Comments - Commentaries

Vendor/Firm Name and Address
Raison sociale et adresse du fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution

Parks Canada Agency
Suite 1300
635 - 8 Ave SW
Calgary, AB T2P3M3

Title-Sujet Bath House Roofing Banff Upper Hot Springs	
Solicitation No. - No. de l'invitation 5P420-15-5266/A	Date: December 21, 2015
GETS Reference No. - No de reference de SEAG PW-15-00711967	Amendment No. - N° de la modif. 001
Solicitation Closes:	
at - á 02:00 PM	on - le December 23, 2015
Time Zone - Fuseau horaire MST - HNR	
F.O.B. - F.A.B.	
Plant-Usine: <input type="checkbox"/>	Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>
Address Inquiries to: - Adresser toute demande de renseignements à :	
Jen Maheu	
Telephone No. - No de téléphone (403) 292-8502	Fax No. - No de FAX: (403) 292-4475
Destination of Goods, Services, and Construction: Destinations des biens, services et construction:	
See Herein - Voir ici	

TO BE COMPLETED BY THE BIDDER (type or print)

Vendor/Firm Name	
Address - Adresse	
Name of person authorized to sign on behalf of the Vendor/Firm Nom de la personne autorisée a signer au nom du fournisseur/ de l'entrepreneur	
Titale - Titre	
Telephone No. - N° de telephone: _____	
Facsimile No. - N° de télécopieur: _____	
Signature	Date

Amendment 01

This amendment is issued to distribute clarifications from the optional site visit held on December 16, 2015 at 10:00 am (MST).

Company	Representative
Fraser Shingling & Exteriors	Jason Konkle

SITE VISIT CLARIFICATIONS

1) Specification Item 8

Roofing Contractor will provide a limited lifetime material and fire-retardant warranty on cedar shingles; a 10 year limited manufacturer's warranty on heat trace cables and components; and a 1 year warranty on heat trace controllers - Note that the Roofing Contractor must be an approved CSSB installer

2) Specification Item 9

Roofing Contractor will provide a 5 year letterhead warranty covering leak and defect repairs resulting from faulty workmanship

3) Specification Item 16

Roofing Contractor will put in place adequate measures to ensure that staff, visitors, customers, and contractors can safely access Bath House and adjacent facilities throughout project - Note that Bath House will be fully-occupied and in operation during re-roof - Roofing Contractor will comply with Health and Safety regulations for all site users, and limit disruption and noise to staff as much as possible - Measures must include maintaining a 3 meter fenced-off clearance immediate to areas of demolition and work, and a scaffold cover over northeast main doors and access ramp throughout project

4) Specification Item 24

Roofing Contractor will coordinate with Parks Canada Project Manager normal work days and hours (dawn to dusk [or 6:00 PM which comes first] Monday thru Friday), extended work days and hours, transportation routes, site access, parking, delivery, and construction site boundary - Note that Roofing Contractor must officially apply to Park Superintendent for extended work days and hours - In the case of a long weekend with a Friday statutory holiday, Roofing Contractor must shut down work at noon on Thursday and cannot resume work until the following Monday at dawn - In the case of a long weekend with a Monday statutory holiday, Roofing Contractor must shut down work at noon Friday and cannot resume work until the following Tuesday at dawn - Plan is to shutdown public access to roadway behind Bath House, that leads to current handicapped parking and Caretaker's cottage, throughout project - Handicapped parking will be located to southeast corner of Bath House at the top of the hill, and the current handicapped parking area will be made available to the Roofing Contractor for storage of vehicles, materials, disposal bins, equipment, and tools - Note that a clear path must always be maintained to the fire hydrant adjacent to Caretaker's cottage

5) Specification Item 33

Roofing Contractor will utilize fasteners, e.g. nails, screws, bolts, etc., of a size, strength, and type consistent with purpose, function, and material compatibility - Roofing Contractor will also construct an eave mock-up that includes new fascia board, drip edge, fascia flashing, and gutter profile, at project start Roof Inspection and Consulting Ltd.

6) Specification Item 34

Roofing Contractor will be responsible for removing rooftop snow accumulations to designated ground locations as required - Note that compact loaders are not allowed on patio deck adjacent to northeast main entrance doors

All other terms and conditions remain unchanged.