



RETURN BIDS TO:

RETOURNER LES SOUMISSIONS À:

Public Works and Government Services / Travaux
publics et services gouvernementaux
Kingston Procurement
Des Acquisitions Kingston
86 Clarence Street, 2nd floor
Kingston
Ontario
K7L 1X3
Bid Fax: (613) 545-8067

**SOLICITATION AMENDMENT
MODIFICATION DE L'INVITATION**

The referenced document is hereby revised; unless otherwise
indicated, all other terms and conditions of the Solicitation
remain the same.

Ce document est par la présente révisé; sauf indication contraire,
les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution
Public Works and Government Services / Travaux
publics et services gouvernementaux
Kingston Procurement
Des Acquisitions Kingston
86 Clarence Street, 2nd floor
Kingston
Ontario
K7L 1X3

Title - Sujet Dome Shelters	
Solicitation No. - N° de l'invitation W4938-16012S/A	Amendment No. - N° modif. 004
Client Reference No. - N° de référence du client W4938-16-012S	Date 2015-12-21
GETS Reference No. - N° de référence de SEAG PW-\$KIN-900-6724	
File No. - N° de dossier KIN-5-44092 (900)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2016-01-07	
Time Zone Fuseau horaire Eastern Standard Time EST	
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Emmons, Chris	Buyer Id - Id de l'acheteur kin900
Telephone No. - N° de téléphone (613) 484-2136 ()	FAX No. - N° de FAX (613) 545-8067
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction:	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

1. Amendment 001, Question 16, the answer states, "Wood is excluded" from the floor. The floor system we are proposing consists of premium grade Good One Side 3/4" plywood and 2" x 6.25" galvanized 'stud and track' framing on 16" centers. These materials are pre-cut and packaged. When on site, they can be pre-assembled into sub-assemblies and integrated into complete floor systems. This floor meets the R value stated in the RFP, as well as has the required non-slip finish. The benefits of this floor is that it's economical, and rot and pest resistant. It can accommodate the cables as well if required under the floor. Is this floor system acceptable to Canada?

Over the next three years, these shelters will be used as permanent structures and are exposed to a high humidity level. That is why we do not consider wood the best material for this use. However, we can accept the floor you offer on condition that its quality will not change as a result of moisture or possible water infiltration.

2. Amendment 001, Question 18, it states, "Installation time should not exceed 3 hours". Does this statement refer to the shelters only, or the shelter and the floor system?

Installation should take up to 3 hours for shelter and floor system.

3. Amendment 001, Question 10, the answer states the electrical distribution "panel will be positioned outside of the tent." We generally install the electrical distribution panel inside the shelter on the end panel and feed the power cable thru the cable port to the exterior of the shelter. Is this acceptable to Canada?

You can install an electrical panel in the shelter, provided it is not bulky and that it meets the safety standards set out in the Canadian Electrical Code 2012. However, external electrical panels will be installed in the vicinity of shelters in order to ensure the supply of electricity for those.