



RETURN BIDS TO:
RETOURNER LES SOUMISSIONS À:
Bid Receiving Public Works and Government
Services Canada/Réception des soumissions
Travaux publics et Services gouvernementaux
Canada
800 Burrard Street, Room 219
800, rue Burrard, pièce 219
Vancouver
British Columbia
V6Z 0B9
Bid Fax: (604) 775-9381

SOLICITATION AMENDMENT
MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution
Public Works and Government Services Canada -
Pacific Region
800 Burrard Street, Room 219
800, rue Burrard, pièce 219
Vancouver
British C
V6Z 0B9

Title - Sujet Lighting and Power Upgrades	
Solicitation No. - N° de l'invitation EZ108-161544/A	Amendment No. - N° modif. 004
Client Reference No. - N° de référence du client	Date 2015-12-22
GETS Reference No. - N° de référence de SEAG PW-\$PWY-019-7684	
File No. - N° de dossier PWY-5-38293 (019)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2016-01-07	Time Zone Fuseau horaire Pacific Standard Time PST
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Ngan, Ken (PWY)	Buyer Id - Id de l'acheteur pwy019
Telephone No. - N° de téléphone (604) 658-2755 ()	FAX No. - N° de FAX (604) 775-6633
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction: NRCan - Pacific Forestry Centre - Victoria, BC	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

Solicitation No. - N° de l'invitation
EZ108-161544/A
Client Ref. No. - N° de réf. du client

Amd. No. - N° de la modif.
004
File No. - N° du dossier
pwy-5-38293

Buyer ID - Id de l'acheteur
pwy019
CCC No./N° CCC - FMS No/ N° VME

Les documents français seront disponibles sur demande.

Please find following Addendum #3.

All other terms and conditions remain unchanged.

The following addendum supersedes information contained in drawings and specifications issued for the project to the extent referenced. This Addendum forms part of the Tender Documents and is subject to all of the conditions set out in the contract conditions.

This electrical addendum contains two (2) pages.

1. CLARIFICATIONS

Type	Question	Response
	<p>General Questions</p> <ol style="list-style-type: none"> -for all exterior rated fixture specifications will you be accepting a powder coat paint as acceptable to the note "marine grade corrosion resistant housing" -for all exterior rated lighting will you accept a 5 step Macadam Ellipse -for all <u>interior</u> recessed and surface troffer type lighting will you accept a 3.5 step Macadam Ellipse other than exceptions noted per other luminaire types -for all interior recessed down light will you accept a maximum 4step Macadam Ellipse 	<ol style="list-style-type: none"> -This is acceptable -No, this does not me ANSI standards for minimum lighting colour consistency Yes Yes
A	<ol style="list-style-type: none"> -advise existing pole height and davit -for new pole requirement will you accept galvanized octagonal davit pole -advise voltage 	<ol style="list-style-type: none"> 7m, davit to be 2.45m Yes 120V.
B	<p>-will you accept die cast aluminum</p> <p>-advise voltage</p>	Yes, 120V
C1		
C2	-will you accept 4000k to match other exterior lighting	Yes, this is acceptable
C3	<p>-will you accept die cast and or extruded aluminum</p> <p>-will IP65 be a suitable listing</p>	Yes, this is acceptable
C4	-will you accept 4000k to match other exterior lighting	Yes, this is acceptable
D	-will you accept L70 50,000 hrs ,7400 lumens with flood optics	Yes, this is acceptable
D1	-will you accept L70 50,000 hrs	Yes, this is acceptable
F	-will you accept a factory custom modification converting existing product to an Led source.	Yes, this is acceptable
G1		
H	-will you accept a 4step Macadam ellipse	Yes, this is acceptable
I1,		
I2,		
I3,	-will you accept 4100 lumens	Yes, this is acceptable
I4,	-will you accept 4100 lumens	Yes, this is acceptable
I5,		
I6		
P	-will you accept 4100 lumens	Yes, this is acceptable
R1		
R2		

R3	-please advise physical size of product required	No shop drawings are available for the existing product, and it resides in drywall ceiling so will require patchwork.
T1	-please advise existing aperture	7.5 inches
T2		
T3		
T4		
T5	-will you accept new fixture housing combination	Use of new housings are acceptable, but contractor must provide all additional labour, repairs, etc to install this product.
U1	-will you accept a new fixture versus a retrofit.	Yes, however many of these fixtures are surface mounted on wood/drywall ceilings and the additional cost to patch holes/repaint would need to be included in base bid. Additionally the time it takes to replace vs retrofit would need to be very similar to reduce operational impacts at the site. Additionally please indicate steps as alternate to leaving existing fixtures empty under current proposed solution.
U2	-will you accept a new fixture versus a retrofit.	See U1
V1	-will you accept a new fixture versus a retrofit.	See U1
V2	-will you accept a new fixture versus a retrofit.	See U1

END OF ELECTRICAL ADDENDUM #3