



RETURN BIDS TO:
RETOURNER LES SOUMISSIONS À:
Bid Receiving Public Works and Government
Services Canada/Réception des
soumissions/Travaux publics et Services
gouvernementaux Canada
The Cambridge Building
3 Queen Street/3, rue Queen
Charlottetown
Prince Edward Island
C1A 4A2

SOLICITATION AMENDMENT MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution
Public Works and Government Services Canada
The Cambridge Building
3 Queen Street/3 rue, Queen
PO Box 1268/CP 1268
Charlottetown
Prince Ed
C1A 4A2

Title - Sujet Wharf Reconstruction407 Montague PE	
Solicitation No. - N° de l'invitation ED001-161951/A	Amendment No. - N° modif. 002
Client Reference No. - N° de référence du client R.076454.001	Date 2015-12-22
GETS Reference No. - N° de référence de SEAG PW-\$PWC-004-3769	
File No. - N° de dossier PWC-5-38168 (004)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2016-01-05	Time Zone Fuseau horaire Atlantic Standard Time AST
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Doucet, Gisele PWC	Buyer Id - Id de l'acheteur pwc004
Telephone No. - N° de téléphone (506) 636-4541 ()	FAX No. - N° de FAX (902) 566-7514
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction:	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

This Solicitation Amendment No. two (2) is raised to include the following addendum no. 2.

The following addendum to the tender documents is effective immediately. This addendum shall form part of the contract documents.

All other terms and conditions remain the same.

Addendum No. 2.

1. QUESTION AND ANSWER

Q1. I had a call from our wharf timber supplier just now and he raised concerns about being able to supply some of the continuous lengths of 350 x 350 wharf timbers shown on the drawings for the above mentioned tender (they are just too long to get in that size). The drawings and specifications show that the 350 x 350 pile caps have to be a continuous runs per each pile bent. I am inquiring on how the bidders should proceed given the notes shown in the drawings and specs with this issue arising from the supplier this morning?

A1. The design consultant has confirmed with a timber pile supplier and they indicated that piles that are beyond their normal stock length are a special order item, but are available.