



Q&A #1

Date: December 22nd, 2015

Project: Building 73 Renovations

Bidders must make sure that their bids are based on the latest version of the tender documents published and take into consideration the following amendments and information, including any information provided in amendments or Q&As previously published for this project.

Bidders that do not comply with this requirement will be discarded.

Question 1:

Can the attendance sheets from the bidders meetings be shared upon request?

Answer 1:

AAFC is not able to publically share the attendance sheets.

Question 2:

I am wondering whether primer & 2 coats paint and rubber base board are required line items of contract for project # 15084; building # 73 at 2585 County Road 20, Harrow, ON for interior dry wall and ceiling. There is no room finish schedule attached in drawing package provided for tender submission.

Answer 2:

All exposed drywall ceiling or walls is required to be painted as per the Painting Specification provided in the tender documents. Rubber base is required to be installed on both first floor and second levels.

Question 3:

Would you please send me some detail for metal shelving such as type of coating or paint and gauge type of shelf material. I did not find specification for metal shelving in tender specification.

Are there specifications for the new metal shelving required for this project?

Answer 3:

- Metal shelving system to be provided to meet the loading described in drawing A202. Shelving configuration to meet the design layout on drawing A201.
 - Metal Shelving to be open style shelving with bracing as required to support the proposed loading.
 - Painted shelving units, complete with shelves to support the client's materials. Shelf material should not promote the possibility of mold growth. Open grate shelving acceptable.
 - Foot plates as required to secure to the supporting steel frames on the second floor and the floor slab to the first floor.
 - One example of acceptable shelving system: RediRack, a Division of The Econo-Rack Group (2015) Inc. Cited only as example not necessarily the recommended source.
-

All other conditions and requirements remain unchanged.