

F.C.G. SMITH - Portable fire extinguishers

#	Location	Model	Manuf. date	Serial no.	Last H/T	Next H/T	Last 6-year maintenance	Min. weight
NAVIGATION BRIDGE DECK								
1	Bridge	5 CO2	2011	878705	2011	2016		12 lbs = 5.5 kg
2	Sound room	5 CO2	2012	265656	2012	2017		12 lbs = 5.5 kg
MAIN DECK								
3	Forward cross passage	5 ABC	2013	BR-380579	2013	2025	2013	
4	Dining room	5 CO2	2014	AB-548033	2014	2019		12 lbs = 5.5 kg
5	Dining room	5 ABC	2015	658452	2015	2027	2015	
6	Central passage	5 ABC	2010	K-442200	2010	2022	2010	
ENGINE ROOM								
7	Starboard engine room (top)	5 ABC	2015	622463	2015	2027	2015	
8	Starboard engine room	5 ABC	2014	A-40098478	2014	2026	2015	
9	Starboard engine room	20 ABC	2009	K-207807	2009	2021	2015	
10	Port engine room	5 ABC	2015	A-40098471	2015	2027	2015	
11	Port engine room (top)	5 ABC	2014	BR 380572	2014	2026	2015	
12	Port engine room	20 ABC	2009	H166805 C	2009	2021	2015	
MAIN DECK								
13	Control room	5 CO2	2012	AC 265653	2012	2017		12.5 lbs = 5.7 kg
16	Fan room	10 ABC	2010	942003	2010	2022	2010	
23	Craft 533	5 ABC	2013	380572	2013	2025	2013	
34	Deck workshop	20 ABC	2015	A-40797421	2015	2027	2015	
26	Galley	6 litres K	2015	765229	2015	2020	2010	22 lbs 15 oz
LOWER DECK								
14	Forward starboard hold	5 ABC	2015	40098461	2015	2027	2015	
15	Forward port hold	5 ABC	2010	514201	2010	2022	2010	
17	Aft starboard hold	5 ABC	2015	40098472	2015	2027	2015	
18	Aft starboard hold	5 CO2	2012	265666	2012	2017		13 lbs = 5.9 kg
19	Aft port hold	5 ABC	2013	BR-380591	2013	2025	2013	
20	Aft port hold	5 CO2	2014	265649	2014	2019		13 lbs = 5.9 kg
21	Port steering gear	5 CO2	2012	1062393	2012	2017		12.5 lbs = 5.7 kg
22	Starboard steering gear	5 CO2	2012	106323	2012	2017		12 lbs = 5.5 kg
DECK ABOVE THE BRIDGE								
25	Lifeboat	2.5 ABC	2012	32478	2012	2024	2012	Hydro + recharge
ADDITIONAL EXTINGUISHERS								

Hydrostatic testing of CO2 and water extinguishers is performed every 5 years.

Hydrostatic testing of ABC extinguishers is performed every 12 years.