

CCGS Ile St-Ours
List of fire extinguishers, winter 2015-2016 maintenance

: HYDROSTATIC TEST TO BE DONE THIS YEAR
 : MAINTENANCE TO BE DONE THIS YEAR (POWDER)

No.	LOCATION	TYPE	SERIAL NUMBER	Manuf. date	5 (CO2) or 6 (powder) years SCHEDULED	HYDRO SCHEDULE D	CAPACITY
Bridge							
1	Bridge, starboard	CO ²	92183	11/1993	01/2016	01/2016	5 lbs.
2	Bridge, stairs	CO ²	92099	11/1993	01/2016	01/2016	5 lbs.
Main deck							
3	Galley, E/R entrance	Type K	1413	N/A	03/2020	03/2020	6 Litres
4	Passage, near water machine	Powder	673530	1985	03/2021	03/2020	10 lbs.
5	Cabin no. 1	Powder	40106478	2015	2021	2027	5 lbs.
6	Cabin no. 2	Powder	40098474	2015	2021	2027	5 lbs.
R-A	Storage cabinet, at the bottom of the bridge stairs	CO ²	103576	03/1985	01/2016	01/2016	5 lbs.
Engine room							
7	E/R workshop	Powder	40107089	11/2014	11/2020	11/2026	5 lbs.
8	E/R starboard entrance	CO ²	91309	10/1993	01/2016	01/2016	5 lbs.
9	E/R port entrance	Powder	673385	1985	03/2021	03/2021	10 lbs.
10	E/R, between the two propulsion engines	Powder	673377	1985	03/2021	03/2021	10 lbs.
11	E/R, aft port engine	CO ²	91395	11/1993	01/2016	01/2016	5 lbs.
12	E/R, aft starboard engine	CO ²	92193	11/1993	01/2016	01/2016	5 lbs.
13	E/R, potable water tank	Powder	442212	2010	2016	2021	5 lbs.
Forward hold							
14	Forward workbench	Powder	774845	2006	2018	2018	10 lbs.
15	Forward workbench	Powder	53882C	2001	2019	2013	10 lbs.
R-1	Hold (reserve)	Powder	88899	1998	01/2017	01/2023	10 lbs.
R-2	Hold (reserve)	Powder	291444	2009	2015	2021	10 lbs.
R-3	Hold (reserve)	Powder	926756	2007	01/2019	01/2019	10 lbs.
R-4	Hold (reserve)	Powder	40106479	2015	2021	2027	5 lbs.

Powder: maintenance six years, hydro 12 years

CO2: maintenance five years, hydro 5 years

Type K foam: maintenance five years, hydro five years