




HDK CONSULTING
INCORPORATED

55-81 Garry St.
Winnipeg, Manitoba
Canada, R3C 4J9
T: 204.818.0390
www.hdkconsulting.com
info@hdkconsulting.com

Mechanical | Electrical | Communications | Security Engineering



KEY PLAN



Certificate of Authorization

HDK Consulting Incorporated

No. 5539 Date: 04/30/2016

DO NOT SCALE DRAWINGS

Revision/Revision	Description/Description	Date/Date
3	ISSUED FOR CONSTRUCTION	15/11/20
2	100% CD SUBMISSION	15/10/29
1	99% CD SUBMISSION	15/09/28
0	50% CD SUBMISSION	15/08/14

Client/client

CANADA SCHOOL OF
PUBLIC SERVICE (CSPS)

WINNIPEG
MANITOBA

Project title/Titre du projet
STANLEY KNOWLES BUILDING
2ND FLOOR - 391 YORK AVENUE
WINNIPEG, MANITOBA

CSPS WINNIPEG FIT-UP

Approved by/Approuvé par
HUGO CEA CANAS

Designed by/Concept par
PAUL LAPOINTE

Drawn by/Dessiné par
RHODA DE CASTRO

PWGC Project Manager/Administrateur de Projets TPSGC
JOHN ALIBIN

PWGC, Architectural and Engineering Resources Manager/
Ressources Architectural et de Directeur d'ingénierie, TPSGC

Client/client
PUBLIC WORKS AND GOVERNMENT SERVICES CANADA

Drawing title/Titre du dessin

SECOND FLOOR NEW
LIGHTING PLAN

Project No./No. du
projet
R.060508.003

Sheet/Feuille
E4
OF 12

Revision no./
La Révision
no.
3

NOTES:

- EXISTING LUMINAIRES TO BE RELOCATED DESIGNATED WITH 'R'. CLEAN ALL REFLECTORS AND LENSES AND REPLACE ALL BROKEN COMPONENTS TO MAKE THEM FULLY OPERATIONAL. RELAMP WITH NEW T8/835K FLUORESCENT LAMPS. LUMINAIRES TO BE WIRED TO EXISTING DOUGLAS LIGHTING CONTROL PANEL. RE-USE EXISTING RELAYS. PROVIDE ALL REQUIRED PROGRAMMING TO HAVE LUMINAIRE ON ELEVATOR LOBBY CENTRAL TIMECLOCK CONTROL AND LOCAL SWITCHES. CONFIRM ON SITE.
- EXISTING LUMINAIRES TO BE RELOCATED AND WIRED AS NIGHT LIGHTING. CLEAN ALL REFLECTORS AND LENSES AND REPLACE ALL BROKEN COMPONENTS. RELAMP WITH NEW T8/835K FLUORESCENT LAMPS. LUMINAIRES TO BE WIRED TO EXISTING 2ND FLOOR NIGHT LIGHTING CIRCUIT. BACK TO EXISTING PANEL E100 IN BASEMENT MAIN ELECTRICAL ROOM. CONFIRM EXISTING ON SITE.

