



1 SECOND FLOOR NEW LIFE SAFETY SYSTEMS PLAN
E6 1:100

NOTES:

1. ALL EGRESS SIGNAGE TO BE WIRED TO EXISTING SECOND FLOOR EXIT SIGN 15A, 347V/1Ø CIRCUIT #13 IN PANEL E100 LOCATED IN BASEMENT ELECTRICAL ROOM. CONFIRM EXISTING ON SITE.
2. ALL FIRE ALARM DEVICES TO BE RE-WIRED TO EXISTING LOCAL AREA FIRE ALARM. INITIATING AND ANNUNCIATING CIRCUITS BACK TO EXISTING NOTIFIER MAIN FIRE ALARM CONTROL PANEL IN BASEMENT ELECTRICAL ROOM.
3. PROVIDE COMPLETE FIRE ALARM VERIFICATION FOR ALL AFFECTED CIRCUITS AND DEVICES.
4. CONFIRM OPERABILITY OF ALL EXISTING FIRE ALARM DEVICES WITHIN AREA OF RENOVATION. REPLACE ALL NON-OPERABLE DEVICES. CONFIRM EXISTING ON SITE.



DO NOT SCALE DRAWINGS		
3	ISSUED FOR CONSTRUCTION	15/11/20
2	100% CD SUBMISSION	15/10/29
1	99% CD SUBMISSION	15/09/28
0	50% CD SUBMISSION	15/08/14
Revision/ Révision	Description/Description	Date/Date
Client/client		
CANADA SCHOOL OF PUBLIC SERVICE (CSPS)		
Winnipeg MANITOBA		
Project title/Titre du projet STANLEY KNOWLES BUILDING 2ND FLOOR - 391 YORK AVENUE WINNIPEG, MANITOBA		
CSPS WINNIPEG FIT-UP		
Approved by/Approuvé par HUGO CEA CANAS		
Designed by/Concept par PAUL LAPOINTE		
Drawn by/Dessiné par RHODA DE CASTRO		
PWGSC Project Manager/Administrateur de Projets TPSGC JOHN ALIBIN		
PWGSC, Architectural and Engineering Resources Manager/ Ressources Architectural et de Directeur d'ingénierie, TPSGC		
Client/client PUBLIC WORKS AND GOVERNMENT SERVICES CANADA		
Drawing title/Titre du dessin SECOND FLOOR NEW LIFE SAFETY SYSTEMS PLAN AND NOTES		
Project No./No. du projet R.060508.003	Sheet/ Feuille E6 OF 12	Revision no./ La Révision no. 3

