

AMENDMENT 003**Questions and Answers:**

Q1. What sized rip-rap product is required?

A1. A uniform sized rip-rap product is required and should not exceed 1.5m in diameter with an acceptable range from 1.5 m down to 0.3 m diameter. The riprap armour material must be hard, durable quarry stone free from seams, cracks or other structural defects.

Q2. Where should material be disposed?

A2. As per 01 11 00, 1.3.1.6 & 1.3.1.7, the material must be disposed of at a BC MoE permitted disposal facility.

Q3. Please provide a drawing showing utilities in and around the project area.

A3. The drawing attached (“Colwood Overview”) shows utilities in and around the project area from 2013. The drawing is for information purposes only and does not relieve the contractor of their responsibilities to complete utility locates as outlined in the specification - 01 11 00: Summary of Work, 1.3.1.3, Section 01 35 29.06: Health and Safety Requirements, 1.20, Section 01 35 43: Environmental Procedures, 1.15.1

All other terms and conditions remain unchanged.