



**RETURN BIDS TO:**  
**RETOURNER LES SOUMISSIONS À:**  
Bid Receiving Public Works and Government  
Services Canada/Réception des  
soumissions/Travaux publics et Services  
gouvernementaux Canada  
The Cambridge Building  
3 Queen Street/3, rue Queen  
Charlottetown  
Prince Edward Island  
C1A 4A2

**SOLICITATION AMENDMENT**  
**MODIFICATION DE L'INVITATION**

The referenced document is hereby revised; unless otherwise  
indicated, all other terms and conditions of the Solicitation  
remain the same.

Ce document est par la présente révisé; sauf indication contraire,  
les modalités de l'invitation demeurent les mêmes.

**Comments - Commentaires**

All enquiries are to be submitted in writing to the  
Contracting Authority, Crystal Bysterveldt, either  
by facsimile or by e-mail at:  
crystal.bysterveldt@pwgsc.gc.ca

**Vendor/Firm Name and Address**  
**Raison sociale et adresse du**  
**fournisseur/de l'entrepreneur**

**Issuing Office - Bureau de distribution**

Public Works and Government Services Canada  
The Cambridge Building  
3 Queen Street/3 rue, Queen  
PO Box 1268/CP 1268  
Charlottetown  
Prince Ed  
C1A 4A2

<b>Title - Sujet</b> Theatre Seat Replacement, Gagetown	
<b>Solicitation No. - N° de l'invitation</b> W0501-160060/A	<b>Amendment No. - N° modif.</b> 002
<b>Client Reference No. - N° de référence du client</b> W0501-160060	<b>Date</b> 2016-01-05
<b>GETS Reference No. - N° de référence de SEAG</b> PW-\$PWC-024-3747	
<b>File No. - N° de dossier</b> PWC-5-38129 (024)	<b>CCC No./N° CCC - FMS No./N° VME</b>
<b>Solicitation Closes - L'invitation prend fin</b> <b>at - à 02:00 PM</b> <b>on - le 2016-01-07</b>	
<b>Time Zone</b> Fuseau horaire Atlantic Standard Time AST	
<b>F.O.B. - F.A.B.</b> <b>Plant-Usine:</b> <input type="checkbox"/> <b>Destination:</b> <input checked="" type="checkbox"/> <b>Other-Autre:</b> <input type="checkbox"/>	
<b>Address Enquiries to: - Adresser toutes questions à:</b> Bysterveldt, Crystal	<b>Buyer Id - Id de l'acheteur</b> pwc024
<b>Telephone No. - N° de téléphone</b> (902) 940-7122 ( )	<b>FAX No. - N° de FAX</b> (902) 566-7514
<b>Destination - of Goods, Services, and Construction:</b> <b>Destination - des biens, services et construction:</b>	

**Instructions: See Herein**

**Instructions: Voir aux présentes**

<b>Delivery Required - Livraison exigée</b>	<b>Delivery Offered - Livraison proposée</b>
<b>Vendor/Firm Name and Address</b> <b>Raison sociale et adresse du fournisseur/de l'entrepreneur</b>	
<b>Telephone No. - N° de téléphone</b> <b>Facsimile No. - N° de télécopieur</b>	
<b>Name and title of person authorized to sign on behalf of Vendor/Firm</b> <b>(type or print)</b> <b>Nom et titre de la personne autorisée à signer au nom du fournisseur/</b> <b>de l'entrepreneur (taper ou écrire en caractères d'imprimerie)</b>	
<b>Signature</b>	<b>Date</b>

This Addendum is raised to provide the following answers to questions provided by bidders.

The following changes in the tender documents are effective immediately. This addendum will form part of the contract documents.

### **TENDER CLOSING**

Notice is hereby given that the closing date for tenders has been extended from Wednesday, January 6, 2016 to:

**Thursday, January 7, 2016 at 2:00pm**

### **ANSWERS TO QUESTIONS**

1. **QUESTION**

We would like to inquire about the specification regarding weight capacity, being 755lbs in the centre of seat. Here it is mentioned in your spec Seat assembly and pedestal (complete installed chair) must support a load of 755lbs in the middle part of the seat without any deformation to the seat. Shall we still bid if we don't meet that spec? We would be as tested on attached document. Will we be disqualified if we tell you that we meet all specs but this one?

One comment made by our supplier was that if someone was actually close to 700 lbs, they definitely would never fit into the seat anyways..... good point? Please advise asap, as we are prepared to bid otherwise.

**ANSWER**

According to Statistics Canada the average male is between 185 and 200 lbs.

The minimum weight load of the theatre seat must have redundancy built in. They need to be built well above the weight of a person. Also, when people shift in the seats and the force of someone sitting down applies pressure as well. The figure of 725lbs does not represent one person weighing 725 pounds but rather a much lighter person applying pressure (weight) over a 2 hour (average length of a movie) time period.

I suggest that the weight requirement is reduced to no less than 400lbs. This is triple the weight of an average Cdn male (ages 18 to 65). This includes the moving force of 200lbs being applied to a surface (the seat) and the motion of someone sitting down.

---

**Annex "C"**

**Technical Evaluation**

**Delete: M 1.17** Seat assembly and pedestal (complete installed chair) must support a load in the range of 725 to 775lbs (329kg to 352kg) in the middle part of the seat without any deformation to the seat structure.

**Replace with: M 1.17** Seat assembly and pedestal (complete installed chair) must support a load no less than 400lbs in the middle part of the seat without any deformation to the seat structure.