



**RETURN BIDS TO:**  
**RETOURNER LES SOUMISSIONS À:**  
**Bid Receiving Public Works and Government**  
**Services Canada/Réception des soumissions**  
**Travaux publics et Services gouvernementaux**  
**Canada**  
**1713 Bedford Row**  
**Halifax, N.S./Halifax, (N.É.)**  
**B3J 1T3**  
**Bid Fax: (902) 496-5016**

## **SOLICITATION AMENDMENT**

## **MODIFICATION DE L'INVITATION**

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

**Comments - Commentaires**

**Vendor/Firm Name and Address**  
**Raison sociale et adresse du**  
**fournisseur/de l'entrepreneur**

**Issuing Office - Bureau de distribution**  
Atlantic Region Acquisitions/Région de l'Atlantique  
Acquisitions  
1713 Bedford Row  
Halifax, N.S./Halifax, (N.É.)  
B3J 3C9  
Nova Scot

<b>Title - Sujet</b> Electronic Swipe System	
<b>Solicitation No. - N° de l'invitation</b> W010S-16J160/A	<b>Amendment No. - N° modif.</b> 007
<b>Client Reference No. - N° de référence du client</b> W010S-16-J160	<b>Date</b> 2016-01-05
<b>GETS Reference No. - N° de référence de SEAG</b> PW-\$HAL-220-9672	
<b>File No. - N° de dossier</b> HAL-5-75152 (220)	<b>CCC No./N° CCC - FMS No./N° VME</b>
<b>Solicitation Closes - L'invitation prend fin</b> <b>at - à 02:00 PM</b> <b>on - le 2016-01-12</b>	
<b>Time Zone</b> Fuseau horaire Atlantic Standard Time AST	
<b>F.O.B. - F.A.B.</b> <b>Plant-Usine:</b> <input type="checkbox"/> <b>Destination:</b> <input checked="" type="checkbox"/> <b>Other-Autre:</b> <input type="checkbox"/>	
<b>Address Enquiries to: - Adresser toutes questions à:</b> Dunphy, Nancy	<b>Buyer Id - Id de l'acheteur</b> hal220
<b>Telephone No. - N° de téléphone</b> (902) 496-5481 ( )	<b>FAX No. - N° de FAX</b> (902) 496-5016
<b>Destination - of Goods, Services, and Construction:</b> <b>Destination - des biens, services et construction:</b>	

**Instructions: See Herein**

**Instructions: Voir aux présentes**

<b>Delivery Required - Livraison exigée</b>	<b>Delivery Offered - Livraison proposée</b>
<b>Vendor/Firm Name and Address</b> <b>Raison sociale et adresse du fournisseur/de l'entrepreneur</b>	
<b>Telephone No. - N° de téléphone</b> <b>Facsimile No. - N° de télécopieur</b>	
<b>Name and title of person authorized to sign on behalf of Vendor/Firm</b> <b>(type or print)</b> <b>Nom et titre de la personne autorisée à signer au nom du fournisseur/</b> <b>de l'entrepreneur (taper ou écrire en caractères d'imprimerie)</b>	
<b>Signature</b>	<b>Date</b>

Solicitation No. - N° de l'invitation  
**W010S-16J160/A**

Amd. No. - N° de la modif.  
**007**

Buyer ID - Id de l'acheteur  
**hal220**

Client Ref. No. - N° de réf. du client  
**W010S-16-J160**

File No. - N° du dossier  
**HAL-5-75152**

CCC No./N° CCC - FMS No./N° VME

---

**This Amendment 007 is being raised to answer questions from potential bidders as follows:**

Question 14:

Please confirm if keyway cylinders must be included.

**Answer 14**

**No, they do not need to be included.**

Question 15:

In Annex "B" Item 012 there is a requirement for PLATES LONG WIDE. Please advise on the purpose of these plates.

**Answer 15**

**The plates go on either side of the door, with the handle/mechanism attached over them.**

Question 16:

Please advise if covering over of scars on the doors is required with the use of wrap around plates.

**Answer 16**

**Not required, as long as the swipe card system is on the door and function. If you would like to use wrap around plates that is ok as well.**

Question 17

Please confirm if the use of standard 22 gauge wrap around plates is acceptable to hide scars on doors.

**Answer 17**

**Yes, but see question 16.**

**PLEASE NOTE: DND will not be replacing doors that are splitted/cracked if the installers are able to fix with a plate/plates in order to install the lock system.**

**ALL OTHER TERMS AND CONDITIONS REMAIN UNCHANGED**