



RETURN BIDS TO:
RETOURNER LES SOUMISSIONS À:
Bid Receiving Public Works & Government
Services Canada/Réception des soumissions Travaux
publics et Services gouvernementaux Canada
1713 Bedford Row
Halifax, N.S./Halifax,(N.E.)
B3J 1T3
Halifax
Bid Fax: (902) 496-5016

SOLICITATION AMENDMENT

MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution
Atlantic Region Acquisitions/Région de l'Atlantique
Acquisitions
1713 Bedford Row
Halifax, N.S./Halifax, (N.E.)
B3J 3C9
Halifax
Nova Scot

Title - Sujet Flooring Replacement - BIO	
Solicitation No. - N° de l'invitation EB144-162015/A	Amendment No. - N° modif. 001
Client Reference No. - N° de référence du client EB144-16-2015	Date 2016-01-11
GETS Reference No. - N° de référence de SEAG PW-\$PWA-121-5337	
File No. - N° de dossier PWA-5-74143 (121)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2016-01-25	Time Zone Fuseau horaire Atlantic Standard Time AST
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Russell (PWA), Alex	Buyer Id - Id de l'acheteur pwa121
Telephone No. - N° de téléphone (902) 496-5168 ()	FAX No. - N° de FAX (902) 496-5016
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction:	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

Amendment 001 is raised for the following:

Question 1

On SK1- can you confirm the delineation line between T1 and T2 – it is unclear on the drawing provided.

Response 1

See attached.

Revisions to specifications:

Reference specification section 09 30 13 Ceramic Tiling:

- Omit subsection 1.3.1.3.2
- Replace subsection 1.3.3.3 with the following,
“Transition strips, expansion joints, stair nosing and grout.”
- Replace subsection 2.1.1 with the following,
“Porcelain tile – T1: Porcelain thru body rectified tile per applicable codes and standards, [308.4] x [609.6] x [10] mm size, edges, minimum R9 Slip Resistant surface, DCOF > 0.42, Water Absorption ≤ 0.1%, Bending Strength ≥ 45N/mm², chemical resistant, MOH’s Hardness ≥ 5, resistant to grazing, Stain Resistance ≥ 4, resistant to deep abrasion . Colour to be a warm, neutral beige in tone with slightly mottled/shaded appearance (not homogeneous colour); final colour selection to be approved by Departmental Representative. Provide manufacture’s written performance/tested standards for the tile proposed tile. For ramps, colour contrast tile is required to demarcate the leading edge of the beginning and end of the ramp at HM-4B2-36 (Stair #3). Samples of colour-contrast tile also to be presented for review and approval.”
- Replace subsection 2.1.2 with the following,
“Porcelain tile – T2 (matching hexagon shaped mosaic): Porcelain thru body rectified tile per applicable codes and standards, [101.6] x [101.6] x [10] mm size, edges, minimum R9 Slip Resistant surface, DCOF > 0.42, Water Absorption ≤ 0.1%, Bending Strength ≥ 45N/mm², chemical resistant, MOH’s Hardness ≥ 5, resistant to grazing, Stain Resistance ≥ 4, resistant to deep abrasion . Colour to be a warm, neutral beige in tone with slightly mottled/shaded appearance (not homogeneous colour); final colour selection to be approved by Departmental Representative. Provide manufacture’s written performance/tested standards for the tile proposed tile.”
- Replace subsection 2.3 with the following,
“.1 In areas of existing vinyl or rubber bases, remove existing and install new 4” high tile base (T1) with Schluter “Shiene” (or equivalent) brushed aluminum top edge trim and outside corners. Contractor to paint and repair wall as required when old base is removed (only in areas

specified for new flooring).

.2 Existing wood base to remain in area of corridor.”

- In subsection 2.6, replace the word “mortal” with “mortar”.
- Replace subsection 2.9.5 with the following,
“Transition strips: Between rectangular tile (T1) and matching hexagon mosaic tile (T2) use Schluter “Schiene” or equivalent (height relative to materials). Finish – satin anodized aluminum (AE). Note: Contractor to provide and install new aluminum transitions at all doorways where new flooring meets existing transitions to match existing. Contractor to provide transition samples for review and approval by Departmental Representative.” [Omit subsections 2.9.5.1 and 2.9.5.2]
- Replace subsection 3.6 with the following,
“Install in accordance with TTMAC detail [09 30 00].”

All other terms and conditions remain the same.

