

Solicitation No. - N° de l'invitation

Amd. No. - N° de la modif.

Buyer ID - Id de l'acheteur

EA011-161735

006

pwd008

Client Ref. No. - N° de réf. du client

File No. - N° du dossier

CCC No./N° CCC - FMS No./N° VME

R.072196.004

PWD-5-38167

 THE FOLLOWING AMENDMENT TO THE TENDER DOCUMENTS IS EFFECTIVE IMMEDIATELY. THE
 ADDENDUM SHALL FORM A PART OF THE CONTRACT DOCUMENTS.

Addendum # 3

1. On Drawing No. C11 of 13, detail #1-11-11, replace the note "150 x 150 timber decking" to read "50 x 150 timber decking"

2. In the specification, add new Appendix "B" – Test Results from Timber and Dredge material testing

3. In the specification, section 01 74 21, add the following new clauses:
 - 1.8.11 Refer to Appendix "B" for test results from dredge material and timber testing.

 - 1.8.12 It is acceptable to dispose of the treated waste wood at a provincially approved landfill that is currently in operation (Approved Waste Disposal Site) with the prior permission of the owner/operator. For a complete list of currently operating provincial landfills contact Service NL.

4. In the specification, section 35 20 23, add the following new clauses:
 - 1.5.4: It is acceptable to dispose of the dredged material at a provincially approved landfill that is currently in operation (Approved Waste Disposal Site) with the prior permission of the owner/operator. For a complete list of currently operating provincial landfills contact Service NL.

 - 1.5.5: If there are odor or fly issues associated with the material, it is to be covered with a layer of clean, non-dredged material or hydrated lime.

5. In the specification, Appendix "A", delete Letter dated August 17, 2015 Re: Dredge Material Disposal – Newman Sound, Terra Nova National Park Headquarters Wharf, NL.

By submission of its bid, the bidder confirms that it has been read and understands the requirements expressed in all addenda and has included all cost of these requirements in its total bid amount.

All other terms and conditions remain unchanged.
