

1 General

1.01 REFERENCES

- .1 Agriculture and Agri-Food Canada
 - .1 The Canadian System of Soil Classification, Third Edition, 1998.
- .2 Canadian Council of Ministers of the Environment
 - .1 PN1340-[2005], Guidelines for Compost Quality.
- .3 Canada Green Building Council (CaGBC)
 - .1 LEED Canada-NC Version 1.0-[2004], LEED (Leadership in Energy and Environmental Design): Green Building Rating System Reference Package For New Construction and Major Renovations (including Addendum [2007]).
 - .2 LEED Canada-CI Version 1.0-[2007], LEED (Leadership in Energy and Environmental Design): Green Building Rating System Reference Guide For Commercial Interiors.

1.02 DEFINITIONS

- .1 Compost:
 - .1 Mixture of soil and decomposing organic matter used as fertilizer, mulch, or soil conditioner.
 - .2 Compost is processed organic matter containing 40% or more organic matter as determined by Walkley-Black or Loss On Ignition (LOI) test.
 - .3 Product must be sufficiently decomposed (i.e. stable) so that any further decomposition does not adversely affect plant growth (C:N ratio below 25), and contain no toxic or growth inhibiting contaminants.

1.03 ACTION AND INFORMATIONAL SUBMITTALS

- .1 Provide submittals in accordance with Section 01 33 00 - Submittal Procedures.
- .2 Quality control submittals :
 - .1 Soil testing: submit certified test reports showing compliance with specified performance characteristics and physical properties as described in PART 2 - SOURCE QUALITY CONTROL.
 - .2 Certificates: submit product certificates signed by manufacturer certifying materials comply with specified performance characteristics and criteria and physical requirements.

1.04 WASTE MANAGEMENT AND DISPOSAL

- .1 Do not dispose of unused soil amendments into sewer systems, into lakes, streams, onto ground or in locations where it will pose health or environmental hazard.

2 Products

2.01 TOPSOIL

- .1 Topsoil for seeded areas: mixture of particulates, microorganisms and organic matter which provides suitable medium for supporting intended plant growth.
 - .1 Contain no toxic elements or growth inhibiting materials.

- .2 Finished surface free from:
 - .1 Debris and stones over 25 mm diameter.
 - .2 Course vegetative material, 10 mm diameter and 100 mm length, occupying more than 2% of soil volume.
- .3 Consistence: friable when moist.
- .4 Containing minimum of 4% organic matter for clay loams and 2% for sandy loams to maximum of 25% by volume, and having a pH of 5.5 to 7.5.
- .5 Topsoil containing subsoil, roots, stones larger than 15 mm, weeds, couch grass, crabgrass or foreign objects is not acceptable

2.02 SOIL AMENDMENTS

- .1 Limestone:
 - .1 Ground agricultural limestone.
 - .2 Gradation requirements: percentage passing by weight, 90% passing 1.0 mm sieve, 50% passing 0.125 mm sieve.
- .2 Fertilizer: industry accepted standard medium containing nitrogen, phosphorous, potassium and other micro-nutrients suitable to specific plant species or application or defined by soil test.

2.03 SOURCE QUALITY CONTROL

- .1 Advise Consultant of sources of topsoil to be utilized with sufficient lead time for testing.
- .2 Contractor is responsible for amendments to supply topsoil as specified.
- .3 Soil testing by recognized testing facility for PH, P and K, and organic matter.
- .4 Testing of topsoil will be carried out by testing laboratory designated by Consultant.
 - .1 Soil sampling, testing and analysis to be in accordance with Provincial standards.

3 Execution

3.01 TEMPORARY EROSION AND SEDIMENTATION CONTROL

- .1 Provide temporary erosion and sedimentation control measures to prevent soil erosion and discharge of soil-bearing water runoff or airborne dust to adjacent properties and walkways.
- .2 Inspect, repair, and maintain erosion and sedimentation control measures during construction until permanent vegetation has been established.
- .3 Remove erosion and sedimentation controls and restore and stabilize areas disturbed during removal.

3.02 PREPARATION OF EXISTING GRADE

- .1 Verify that grades are correct.
- .2 Grade soil, eliminating uneven areas and low spots, ensuring positive drainage.
- .3 Remove debris, roots, branches, stones in excess of 25 mm diameter and other deleterious materials.
 - .1 Remove soil contaminated with calcium chloride, toxic materials and petroleum products.

- .2 Remove debris which protrudes more than 75 mm above surface.
- .3 Dispose of removed material off site.
- .4 Cultivate entire area which is to receive topsoil to minimum depth of 100 mm.
 - .1 Cross cultivate those areas where equipment used for hauling and spreading has compacted soil.

3.03 PLACING AND SPREADING OF TOPSOIL/PLANTING SOIL

- .1 Place topsoil after Consultant has accepted subgrade.
- .2 Spread topsoil in uniform layers not exceeding 150 mm.
- .3 For sodded areas keep topsoil 15 mm below finished grade.
- .4 Spread topsoil [as indicated] to following minimum depths after settlement.
 - .1 150 mm for seeded areas.
 - .2 135 mm for sodded areas.
 - .3 300 mm for flower beds.
 - .4 500 mm for shrub beds.
- .5 Manually spread topsoil/planting soil around trees, shrubs and obstacles.

3.04 FINISH GRADING

- .1 Grade to eliminate rough spots and low areas and ensure positive drainage.
 - .1 Prepare loose friable bed by means of cultivation and subsequent raking.

END OF SECTION

1 General

1.01 ACTION AND INFORMATIONAL SUBMITTALS

- .1 Submit in accordance with Section 01 33 00 - Submittal Procedures.
- .2 Product Data:
 - .1 Submit manufacturer's instructions, printed product literature and data sheets for seed, and fertilizer.
- .3 Certificates: product certificates signed by manufacturer certifying materials comply with specified performance characteristics and criteria and physical requirements.

1.02 DELIVERY, STORAGE AND HANDLING

- .1 Deliver, store and handle materials in accordance with manufacturer's written instructions.
- .2 Delivery and Acceptance Requirements:
 - .1 Labelled bags of fertilizer identifying mass in kg, mix components and percentages, date of bagging, supplier's name and lot number.
 - .2 Fertilizer must be dry.
- .3 Storage and Handling Requirements:
 - .1 Store fertilizer in dry location and in accordance with manufacturer's recommendations in clean, dry, well-ventilated area.
 - .2 Replace defective or damaged materials with new.

1.03 WARRANTY

- .1 For seeding, 12 months warranty period is extended to 1 full growing season.
- .2 Contractor hereby warrants that seeding will remain free of defects in accordance with General Conditions CCDC GC 12.3, but for 1 full growing season.
- .3 End-of-warranty inspection will be conducted by Consultant.

2 Products

2.01 GRASS SEED

- .1 Canada "Certified" seed, "Canada No. 1 Lawn Grass Mixture" in accordance with Government of Canada "Seeds Act" and "Seeds Regulations".
 - .1 Grass seed mixture.
 - .1 Mixture composition:
 - .1 50% Kentucky Blue Grass.
 - .2 40% Creeping Fescue.
 - .3 10% Perennial Rye Grass
 - .4 []% [].
- .2 In packages individually labelled in accordance with "Seeds Regulations" and indicating name of supplier.

2.02 WATER

- .1 Free of impurities that would inhibit germination and growth.

2.03 FERTILIZER

- .1 To Canada "Fertilizers Act" and Regulations.
- .2 Complete synthetic fertilizer with guaranteed minimum analysis as specified.

3 Execution

3.01 EXAMINATION

- .1 Verification of Conditions: verify conditions of substrate previously installed under other Sections or Contracts are acceptable for mechanical seeding installation in accordance with manufacturer's written instructions.
 - .1 Inform Consultant of unacceptable conditions immediately upon discovery.
 - .2 Proceed with installation only after unacceptable conditions have been remedied Consultant.

3.02 SEED BED PREPARATION

- .1 Do not perform work under adverse field conditions as determined by Consultant.
- .2 Remove and dispose of weeds; debris; stones 25 mm in diameter and larger; soil contaminated by oil, gasoline and other deleterious materials off site.
- .3 Verify that grades are correct. If discrepancies occur, notify Consultant.
- .4 Fine grade surface free of humps and hollows to smooth, even grade to elevations indicated to tolerance of plus or minus 15 mm, surface draining naturally.
- .5 Cultivate fine graded surface approved by Consultant to 25 mm depth immediately prior to seeding.

3.03 SEED PLACEMENT

- .1 Ensure seed is placed under supervision of certified Landscape Planting Supervisor.
- .2 For mechanical seeding:
 - .1 Mechanical landscape drill seeder ("Brillion" type or equivalent) which accurately places seed at specified depth and rate and rolls in single operation.
 - .2 Use equipment and method acceptable to Consultant.
- .3 For manual seeding:
 - .1 Use manually operated drop seeder ("Cyclone" type or equivalent).
 - .2 Use manually operated, water ballast, landscaping type, smooth steel drum roller. Ballast as directed by Consultant.
- .4 On cultivated surfaces, sow seed uniformly at rate of:
 - .1 2kg/100m² lawn grass mixture.
- .5 Blend applications 150 mm into adjacent grass areas to form uniform surfaces.

- .6 Sow half of required amount of seed in one direction and remainder at right angles as applicable.
- .7 Incorporate seed by light raking in cross directions.
- .8 Consolidate mechanically seeded areas by rolling area if soil conditions warrant or if directed by Consultant with equipment approved by Consultant immediately after seeding.

3.04 CLEANING

- .1 Progress Cleaning:
 - .1 Leave Work area clean at end of each day.
 - .2 Keep pavement and area adjacent to site clean and free from mud, dirt, and debris at all times.
- .2 Final Cleaning: upon completion remove surplus materials, rubbish, tools and equipment.
 - .1 Clean and reinstate areas affected by Work.

3.05 PROTECTION

- .1 Erect plastic snow fence around newly seeded areas sufficient to protect against deterioration due to pedestrian or other traffic.

3.06 MAINTENANCE DURING ESTABLISHMENT PERIOD

- .1 Ensure maintenance is carried out under supervision of certified Landscape Maintenance Supervisor.
- .2 Perform following operations from time of seed application until acceptance by Consultant:
 - .1 Water seeded area to maintain optimum soil moisture level for germination and continued growth of grass. Control watering to prevent washouts.
 - .2 Repair and reseed dead or bare spots to allow establishment of seed prior to acceptance.
 - .3 Cut grass to 50 mm whenever it reaches height of 70 mm. Remove clippings which will smother grass [as directed by Consultant.
 - .4 Fertilize seeded areas after first cutting. Spread half of required amount of fertilizer in one direction and remainder at right angles and water in well.
 - .5 Control weeds by mechanical or chemical means utilizing acceptable integrated pest management practices.
 - .6 Adjust protection barrier as necessary to protect against deterioration due to pedestrian or other traffic as needed.

3.07 FINAL ACCEPTANCE

- .1 Seeded areas will be accepted by Consultant provided that:
 - .1 Areas are uniformly established free of rutted, eroded, bare or dead spots and extent of weeds apparent in grass is acceptable.
 - .2 Areas have been cut at least twice.
 - .3 Areas have been fertilized.
- .2 Areas seeded in fall will be accepted in following spring, one month after start of growing season provided acceptance conditions are fulfilled.

3.08 MAINTENANCE DURING WARRANTY PERIOD

- .1 Perform following operations from time of acceptance until end of warranty period.
 - .1 Water seeded area to maintain optimum soil moisture level for continued growth of

- grass. Control watering to prevent washouts.
- .2 Repair and reseed dead or bare spots to satisfaction of Consultant.
- .3 Cut grass to 50 mm whenever it reaches height of 70 mm. Remove clippings which will smother grass Consultant.
- .4 Fertilize seeded areas in accordance with fertilizing program. Spread half of required amount of fertilizer in one direction and remainder at right angles and water in well.
- .5 Control weeds by mechanical or chemical means utilizing acceptable integrated pest management practices.

END OF SECTION