



- KEYED NOTES:**
- 1- 400W, 347V HPS. LIGHT FIXTURE, c/w SUPPORT BRACKET, 1200mm OF CHORD & TWIST LOCK PLUG (TYP.)
 - 2- 50X150mm HSS GALVANIZED STEEL LIGHT CANOPY SUPPORT (TYP.)
 - 3- 38X76mm HSS GALVANIZED STEEL LIGHT SUPPORT (TYP.)
 - 4- 102X102x6.4mm GALVANIZED STEEL ANGLE, BOLTED TO POST AT TRUSS BOTTOM ELEVATION TO SUPPORT LIGHT CANOPY SUPPORT (TYP.)
 - 5- GALVANIZED STEEL ENERGY TRUSS

ARCHITECTURE 49

1410 MOUNT EDWARD ROAD
CHARLOTTETOWN PE CANADA C1E 2A1
TEL: 902.367.4646 | FAX: 902.367.4647 | ARCHITECTURE49.COM

ghe
Greenhouse Engineering

86 Glenview Avenue, Toronto, Ontario M4R 1P8, Canada
Tel: (416) 489 3816 Fax: (416) 481 3883

THE ASSOCIATION OF PROFESSIONAL ENGINEERS OF THE PROVINCE OF PRINCE EDWARD ISLAND VALID FOR THE YEAR 2015

Alexander Turkewitsch
No. 1307
DATE: 22 Dec 2015

LICENSED PROFESSIONAL ENGINEER
PROVINCE OF PRINCE EDWARD ISLAND

2	ISSUED FOR TENDER	8-10-15
1	ISSUED FOR 66% SUBMISSION	15-9-15
revisions		date
project	AAFC GREENHOUSE EXPANSION HARRINGTON RESEARCH FARM HARRINGTON, PEI	

GREENHOUSE SUPPLEMENTAL LIGHTING PLAN

designed	AT	comp
drawn	AE	dessiné
date	JULY 21, 2015	
approved	<i>Alexander Turkewitsch</i>	approuvé
Tender	Submission	
PWSC Project Manager	Administrateur de Projets TPSC	
project number	R.072545.001	
drawing no.	GH-10	

GREENHOUSE SUPPLEMENTAL LIGHTING PLAN 1
GH-10

