

Solicitation No. - N° de l'invitation EQ754-162033 /A	Amd. No. - N° de la modif. 002	Buyer ID - Id de l'acheteur pw012
Client Ref. No. - N° de réf. du client R.074570.001	File No. - N° du dossier PWL-5-38179	CCC No./N° CCC - FMS No/ N° VME

Attachment No. 003

1.0 Tender Document Clarifications – Bidders' Questions

- 1.1 Question: In the specs section of the project: section 07 52 16 (page 6) 3.5.3 tapered insulation, it says minimum 2% slope, and in the roof type legend in the roof plan page A300 in calls for a 1% slope, please clarify**

Response: Revise Specification Section 07 52 16, line item 3.5.3: **Delete:** "2% slope". **Insert:** "1% slope".

- 1.2 Question: Would it be possible to add the separate price item on the tender form for the reinstatement of the parapet cap as shown on drawing a200 or should we include that in the lump sum price?**

Response: Delete all references to Option 2 Separate Price. See Section 2.0 below. There will be no separate price required.

- 1.3 Question: Tender specs 075216, 2.1.8 mention use two component adhesive to install base sheet insulation panel and tapered insulation, not clear how deck sheathing want to be installed: adhesive or asphalt?**

Response: Revise Specification Section 07 52 16, line item 2.1.3 to read: "Deck sheathing: ASTM C1177, 13mm thick. Mechanically fasten or use low-rise, two-component polyurethane adhesive to install deck sheathing."

Revise Specification Section 07 52 16, line item 2.1.8: **Delete phrase:** "base sheet insulation panel".

- 1.4 Question: In specs 075216, 2.1.3 mention Deck sheathing 6mm thick but in drawing A200 says 13mm Gypsum board. Please advise the right materials.**

Response: Revise Specification Section 07 52 16, line item 2.1.3: **Delete:** "6mm". **Insert:** "13mm".

2.0 Tender Drawings – Revisions

- 2.1 Delete** Drawing Detail 5/A200.
- 2.2** Revise title of Detail 3/A200: **Delete** the words "OPTION 1".
- 2.3** Revise Roof Type Legend on Drawing A200: For Roof Type  New Roofing Assembly at Main Roof, **Delete** requirements for "13MM GYPSUM BOARD".
- 2.4** Revise Detail 3/A100: **Delete** requirements for work shown within dashed bubble for removal of existing vitreous panel parapet cap and **delete** reference to separate price.
- 2.5** Drawing A100, General Notes- Demolition, item 11: **Delete** the words "SEPARATE PRICE FORM".
- 2.6** Drawing A100 (upper right hand corner of drawing), **Delete** the words: "MAIN ROOF (SEPARATE PRICE)&" within the Note box as shown below:

Solicitation No. - N° de l'invitation
EQ754-162033 /A

Amd. No. - N° de la modif.
002

Buyer ID - Id de l'acheteur
pw012

Client Ref. No. - N° de réf. du client
R.074570.001

File No. - N° du dossier
PWL-5-38179

CCC No./N° CCC - FMS No/ N° VME

VITREOUS METAL PARAPET CAP REMOVAL
AT MAIN ROOF (SEPARATE PRICE) &
PENTHOUSE ROOF (BASE BID):

1. LOCATIONS OF EXISTING VITREOUS METAL CAPS AND ITS SUB-GIRT SYSTEMS MUST BE RECORDED AND NUMBERED PRIOR TO REMOVAL AND STORAGE.
2. PROTECT AND STORE ALL VIT. METAL CAPS FOR REINSTATEMENT WITH NEW PURPOSE MADE FASTENERS.

3.0 Sketch Issued with this Amendment

- 3.1** Structural: S-SK-1 REINFORCEMENT FOR NEW ROOF DECK OPENING, dated January 20, 2016.