



consultant:

**onsa**  
F.C. O'Neill, Scriven  
& Assoc's Limited  
Consulting Engineers  
5450 Cornwallis Street  
Halifax, Nova Scotia, B3K 1A9  
P: (902) 429-9701  
F: (902) 429-9729  
W: www.onsa.ca



B	ISSUED FOR TENDER	01/18 2016
A	ISSUED FOR 100% REVIEW	01/14 2016
revisions		date

project

POLARIS BUILDING  
FLOOR PLAN UPGRADES

BEDFORD INSTITUTE OCEANOGRAPHY  
DARTMOUTH - NS

drawing

design

LEVEL 3  
DEMO & NEW  
SPRINKLER

designed BS conçu

date DEC 2015

drawn BS dessiné

date DEC 2015

approved MR approuvé

date JAN 2016

Tender Soumission

PWGSC Project Manager Administrateur de projets TPSC

project number no. du projet

F5654-150080

drawing no. no. du dessin

H3

## GENERAL NOTES

- Ⓐ VERIFY EXISTING SITE CONDITIONS BEFORE COMMENCING WORK.
- Ⓑ COORDINATE WORK WITH OTHER SERVICES TO AVOID INTERRUPTION OR CHANGES TO PIPING AND/OR EQUIPMENT IN CEILING SPACE OUTSIDE SCOPE OF WORK.
- Ⓒ EXISTING SERVICES OUTSIDE SCOPE OF WORK ARE NOT SHOWN FOR CLARITY.
- Ⓓ THE CONTRACTOR AND ALL SUB-CONTRACTORS SHALL NOT SCALE DRAWINGS AND VERIFY ALL JOB SITE DIMENSIONS.

## LEGEND

○	EXISTING SPRINKLER HEAD
●	NEW PENDANT SPRINKLER HEAD (N=6.0)
●	NEW RESPONSE QUICK RESPONSE SPRINKLER PLATED RATED FOR 130 °F
●	2ND TYPE ABC DRY CHEMICAL FIRE EXTINGUISHER

## SPRINKLER NOTES

- ① PROVIDE 20MM SCH40 STEEL PIPE TO RUIT NEW HEAD LOCATION WITH EXISTING SPRINKLER HEAD WITH NEW PENDANT SPRINKLER HEAD.
- ② PROVIDE A FIRE RATED FIRE EXTINGUISHER CABINET TO MATCH THE FIRE RATING OF THE WALL.
- ③ INSPECT ALL SPRINKLER HEADS AFTER WORK IS COMPLETE FOR SIGNS OF DAMAGE AND REPLACE ALL DAMAGED SPRINKLERS WITH NEW HEADS.

## 1 SPRINKLER DEMOLITION PLAN - LEVEL THREE

SCALE : 1:100

0m 1m 2m 3m 4m 5m 6m 7m 8m 9m 10m

## 2 NEW SPRINKLER PLAN - LEVEL THREE

SCALE : 1:100

0m 1m 2m 3m 4m 5m 6m 7m 8m 9m 10m

