


consultant:



F.C. O'Neill, Scriven
& Assoc's Limited
Consulting Engineers

5450 Cornwall Street
Halifax, Nova Scotia B3K 1A9
P: (902) 429-0701
F: (902) 429-9729
E: www.onsltd.ca



B	ISSUED FOR TENDER	01/18/2016
A	ISSUED FOR 100% REVIEW	01/14/2016

revisions

project

POLARIS BUILDING
FLOOR PLAN UPGRADES

BEDFORD INSTITUTE OCEANOGRAPHY
DARTMOUTH - NS

drawing

LEVEL 2
DEMO & NEW
VENTILATION

designed BS

date DEC 2016

drawn BS

date JAN 2016

approved MR

date JAN 2016

Tender

PWSC Project Manager Administrateur de projets TPSC

project number

F5654-150080

drawing no.

H10

E-DRM/GDD-E:

GENERAL NOTES

- VERIFY EXISTING SITE CONDITIONS BEFORE COMMENCING WORK.
- COORDINATE WORK WITH OTHER SERVICES TO AVOID INTERRUPTION OR CHANGES TO PIPING AND/OR EQUIPMENT IN CEILING SPACE OUTSIDE SCOPE OF WORK.
- EXISTING SERVICES OUTSIDE SCOPE OF WORK ARE NOT SHOWN FOR CLARITY.
- THE CONTRACTOR AND ALL SUB-CONTRACTORS SHALL NOT SCALE DRAWINGS AND VERIFY ALL JOB SITE DIMENSIONS.

VENTILATION NOTES

- VERIFY CONDITION OF FLEX DUCTING AND DIFFUSERS/GRILLES IN AREAS WHERE T-BAR CEILING IS BEING REPLACED (COORDINATE W/ ARCH DWGS). REPLACE DAMAGED FLEX DUCTING AND/OR DIFFUSERS/GRILLES.
- ALLOW FOR TESTING, ADJUSTING AND BALANCING (TAB) FOR THE ENTIRE VENTILATION SYSTEM, INCLUDING AHU, FOR FLOORS 1 TO 4. SUPPLY AIR AND OUTSIDE AIR FLOW RATES WILL BE PROVIDED ONCE FINAL LAYOUT IS AVAILABLE.

VENTILATION LEGEND

NEW	DESCRIPTION	EXISTING
	SUPPLY AIR GRILLE	
	RETURN AIR GRILLE	
	BALANCING DAMPER	
	SUPPLY AIR DUCT	
	CROSS TALK SILENCER	
	TO BE REMOVED	
	DUCT CAP	
	KITCHEN UV PURIFIER	

1 VENTILATION DEMOLITION PLAN - LEVEL TWO

SCALE : 1:100

0m 1m 2m 3m 4m 5m 6m 7m 8m 9m 10m

2 NEW VENTILATION PLAN - LEVEL TWO

SCALE : 1:100

0m 1m 2m 3m 4m 5m 6m 7m 8m 9m 10m

