


1 VENTILATION DEMOLITION PLAN – LEVEL THREE  
SCALE : 1:100



2 NEW VENTILATION PLAN – LEVEL THREE  
SCALE : 1:100

### GENERAL NOTES


- Ⓐ VERIFY EXISTING SITE CONDITIONS BEFORE COMMENCING WORK.
- Ⓑ COORDINATE WORK WITH OTHER SERVICES TO AVOID INTERRUPTION OR CHANGES TO PIPING AND/OR EQUIPMENT IN CEILING SPACE OUTSIDE SCOPE OF WORK.
- Ⓒ EXISTING SERVICES OUTSIDE SCOPE OF WORK ARE NOT SHOWN FOR CLARITY.
- Ⓓ THE CONTRACTOR AND ALL SUB-CONTRACTORS SHALL NOT SCALE DRAWINGS AND VERIFY ALL JOB SITE DIMENSIONS.

### VENTILATION NOTES

- ① VERIFY CONDITION OF FLEX DUCTING AND DIFFUSERS/GRILLES IN AREAS WHERE T-BAR CEILING IS BEING REPLACED (COORDINATE W/ ARCH DWGS). REPLACE DAMAGED FLEX DUCTING AND/OR DIFFUSERS/GRILLES.
- ② ALLOW FOR TESTING, ADJUSTING AND BALANCING (TAB) FOR THE ENTIRE VENTILATION SYSTEM, INCLUDING AHU, FOR FLOORS 1 TO 4. SUPPLY AIR AND OUTSIDE AIR FLOW RATES WILL BE PROVIDED ONCE FINAL LAYOUT IS AVAILABLE.

### VENTILATION LEGEND

NEW	DESCRIPTION	EXISTING
	SUPPLY AIR GRILLE	
	RETURN AIR GRILLE	
	BALANCING DAMPER	
	SUPPLY AIR DUCT	
	CROSS TALK SILENCER	
	TO BE REMOVED	
	DUCT CAP	
	KITCHEN UV PURIFIER	



consultant:  
**onsa**  
F.C. O'Neill, Scriven & Assoc's Limited  
Consulting Engineers  
5450 Cornwallis Street  
Halifax, Nova Scotia B3K 1A9  
P: (902) 429-0701  
F: (902) 429-9729  
www.onsa.ca



B	ISSUED FOR TENDER	01/18 2016
A	ISSUED FOR 100% REVIEW	01/14 2016

revisions: date

project: project

POLARIS BUILDING  
FLOOR PLAN UPGRADES

BEDFORD INSTITUTE OCEANOGRAPHY  
DARTMOUTH – NS

drawing: dessin

LEVEL 3  
DEMO & NEW  
VENTILATION

designed BS conçu

date DEC 2016

drawn BS dessiné

date JAN 2016

approved MR approuvé

date JAN 2016

Tender Soumission

PWGSC Project Manager Administrateur de projets TPSGC

project number no. du projet

F5654-150080

drawing no. no. du dessin

H11