



RETURN BIDS TO:
RETOURNER LES SOUMISSIONS À:
Bid Receiving Public Works & Government
Services Canada/Réception des soumissions Travaux
publics et Services gouvernementaux Canada
1713 Bedford Row
Halifax, N.S./Halifax,(N.E.)
B3J 1T3
Halifax
Bid Fax: (902) 496-5016

SOLICITATION AMENDMENT

MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution
Atlantic Region Acquisitions/Région de l'Atlantique
Acquisitions
1713 Bedford Row
Halifax, N.S./Halifax, (N.E.)
B3J 3C9
Halifax
Nova Scot

Title - Sujet Electrical Materials	
Solicitation No. - N° de l'invitation 5P128-150659/A	Amendment No. - N° modif. 002
Client Reference No. - N° de référence du client 5P128-15-0659	Date 2016-01-22
GETS Reference No. - N° de référence de SEAG PW-\$PWA-122-5332	
File No. - N° de dossier PWA-5-74124 (122)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2016-01-28	
Time Zone Fuseau horaire Atlantic Standard Time AST	
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Chinye (PWA), Chukwudi	Buyer Id - Id de l'acheteur pwa122
Telephone No. - N° de téléphone (902) 496-5476 ()	FAX No. - N° de FAX (902) 496-5016
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction:	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

Amendment 002 is raised to clarify the following requirements in Annex B-Basis of Payment:

DO NOT MODIFY items in Description, Estimated Quantity and Unit of Measurement columns of ANNEX B-Basis of Payment.

Question 1: Panel C/W- What is the Panel Amperage?

Answer to Question 1: 100A

Question 2: 2 p 30- 1 or 3 phase?

Answer to Question 2: 3 phase

Question 3: 2 p 20-Main breaker?

Answer to Question 3: No

Question 4: 1p 15- Main Lug?

Answer to Question 4: Yes

Type of Panel;

Question 5: 1p 15 for existing panel- Manufacturer?

Answer to Question 5: Square D #QOB

Question 6: 3p 100 for existing panel- Manufacturer?

Answer to Question 6: Square D #QOB

Question 7: 1p 20 for existing panel- Manufacturer?

Answer to Question 7: Square D # QOB

Question 8: 1Ø 3W Transformer 250 kva 600-240/120vZ=6.1%- Any specification? EEMAC1 Enclosure? Aluminium winding?

Answer to Question 8: Indoor unit, NEMA 12, K rated, Cu winding

Question 9 : 3 wire Transformer - 167.5 Kva 600/240/120v 1Ø Z=6.5%- Any specification? Indoor? EEMAC1 Enclosure? Aluminum winding?

Answer to Question 9: Indoor unit, NEMA 12, K rated, Cu winding

Question 10: Re the tender 2 pages attached for parks Canada Cheticamp Lines 10 through 13 noted, R90-3 copper. There is no quantity unit given. I would assume 300meter reels?

Answer to Question 10: Line items 10 through 13

Three (3) meters of #3AWG cu R90 red in colour

Three(3) meters of #3AWG cu R90 white in colour

Three (3) meters of #3AWG cu R90 black in colour

Three (3) meters of #3AWG cu R90 green in colour

Solicitation No. - N° de l'invitation
5P128-15-0659/A
Client Ref. No. - N° de réf. du client
5P128-150659

Amd. No. - N° de la modif.
amd002
File No. - N° du dossier

Buyer ID - Id de l'acheteur
HALL122
CCC No./N° CCC - FMS No./N° VME

Question 11: Can you confirm Also, Are email bids accepted or hard copy to 1713 Bedford Row ?

Answer to Question 11: Bids received via email on or before the solicitation closing date WILL not be accepted. Bids MUST be mailed in or faxed to the address below on or before the solicitation closing date.

RETURN BIDS TO:
Bid Receiving Public Works & Government
1713 Bedford Row
Halifax, N.S
B3J 1T3
Halifax

Bid Fax: (902) 496-5016

All Other Terms and Conditions Remain the Same.