

PART 1 **GENERAL**

1.1 **SECTION INCLUDES**

- .1 Service equipment and installation.

1.2 **RELATED SECTIONS**

- .1 Section 26 05 28 - Grounding - Secondary.
- .2 Section 26 05 31 - Splitters, Junction, Pull Boxes and Cabinets.
- .3 Section 26 24 16.01 - Panelboards Breaker Type.
- .4 Section 26 28 16.02 - Moulded Case Circuit Breakers.

PART 2 **PRODUCTS**

2.1 **EQUIPMENT**

- .1 Enclosed circuit breaker: in accordance with Section 26 28 16.02 - Moulded Case Circuit Breakers, rating as indicated.
- .2 Panelboard breaker type: in accordance with Section 26 24 16.01 - Panelboards Breaker Type, rating as indicated.
- .3 Cabinet type 'A' for utility revenue metering Junction box Pull box Splitter box: in accordance with Section 26 05 31 - Splitters, Junction, Pull Boxes and Cabinets, size as indicated.

PART 3 **EXECUTION**

3.1 **INSTALLATION**

- .1 Install service equipment.
- .2 Connect to incoming service.
- .3 Connect to outgoing load circuits.
- .4 Install ground fault equipment.
- .5 Make grounding connections in accordance with Section 26 05 28 - Grounding – Secondary.
- .6 Make provision for power supply authority's metering.

END OF SECTION