

**PART 1      GENERAL**

**1.1      REALTED SECTIONS**

- .1      Section 01 33 00 – Submittal Procedures.
- .2      Section 26 80 00 – Commissioning of Electrical Systems.
- .3      Section 26 05 00 – Common Work Results – Electrical.

**1.2      SUBMITTALS**

- .1      Submit shop drawings and product data for cabinets.
- .2      Provide manufacturer’s printed product literature, specifications and datasheet and include product characteristics, performance criteria, physical size, finish and limitations.
- .3      Provide drawings stamped and signed by professional engineer registered or licensed in the Province of Newfoundland and Labrador, Canada.

**PART 2      PRODUCTS**

**2.1      SPLITTERS**

- .1      Sheet metal enclosure, welded corners and formed hinged cover suitable for locking in closed position.
- .2      Main and branch lugs to match required size and number of incoming and outgoing conductors as indicated.
- .3      At least three spare terminals on each set of lugs in splitters less than 400 A.

**2.2      JUNCTION AND PULL BOXES**

- .1      Welded steel construction with screw-on flat covers for surface mounting.
- .2      Covers with 25 mm minimum extension all around, for flush-mounted pull and junction boxes.

**2.3      CABINETS**

- .1      Type E: sheet steel, hinged door and return flange overlapping sides, handle, lock and catch, for surface mounting.
- .2      Type T: sheet steel cabinet, with hinged door, latch, lock, 2 keys, containing 19 mm fir plywood backboard for surface flush mounting.

**PART 3**            **EXECUTION**

**3.1**                    **SPLITTER INSTALLATION**

- .1        Install splitters and mount plumb, true and square to the building lines.
- .2        Extend splitters full length of equipment arrangement except where indicated otherwise.

**3.2**                    **JUNCTION, PULL BOXES AND CABINETS INSTALLATION**

- .1        Install pull boxes in inconspicuous but accessible locations.
- .2        Mount cabinets with top not higher than 2 m above finished floor.
- .3        Install terminal block as indicated in Type T cabinets.
- .4        Only main junction and pull boxes are indicated. Install pull boxes so as not to exceed 30 m of conduit run between pull boxes.

**3.3**                    **IDENTIFICATION**

- .1        Provide equipment identification in accordance with Section 26 05 00 – Common Work Results - Electrical.
- .2        Install size 2 identification labels indicating system name voltage and phase.

**END OF SECTION**