



**RETURN BIDS TO:**  
**RETOURNER LES SOUMISSIONS À:**  
Bid Receiving Public Works and Government  
Services Canada/Réception des  
soumissions/Travaux publics et Services  
gouvernementaux Canada  
The Cambridge Building  
3 Queen Street/3, rue Queen  
Charlottetown  
Prince Edward Island  
C1A 4A2

## SOLICITATION AMENDMENT MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

### Comments - Commentaires

All enquiries are to be submitted in writing to the Contracting Authority, Crystal Bysterveldt, either by facsimile or by e-mail at:  
crystal.bysterveldt@pwgsc.gc.ca.

**Vendor/Firm Name and Address**  
**Raison sociale et adresse du**  
**fournisseur/de l'entrepreneur**

### Issuing Office - Bureau de distribution

Public Works and Government Services Canada  
The Cambridge Building  
3 Queen Street/3 rue, Queen  
PO Box 1268/CP 1268  
Charlottetown  
Prince Ed  
C1A 4A2

<b>Title - Sujet</b> Greenhouse Expansion, Harrington PE	
<b>Solicitation No. - N° de l'invitation</b> ED001-162184/A	<b>Amendment No. - N° modif.</b> 003
<b>Client Reference No. - N° de référence du client</b> R.072545.001	<b>Date</b> 2016-01-29
<b>GETS Reference No. - N° de référence de SEAG</b> PW-\$PWC-024-3792	
<b>File No. - N° de dossier</b> PWC-5-38187 (024)	<b>CCC No./N° CCC - FMS No./N° VME</b>
<b>Solicitation Closes - L'invitation prend fin</b> <b>at - à 02:00 PM</b> <b>on - le 2016-02-09</b>	<b>Time Zone</b> Fuseau horaire Atlantic Standard Time AST
<b>F.O.B. - F.A.B.</b> <b>Plant-Usine:</b> <input type="checkbox"/> <b>Destination:</b> <input checked="" type="checkbox"/> <b>Other-Autre:</b> <input type="checkbox"/>	
<b>Address Enquiries to: - Adresser toutes questions à:</b> Bysterveldt, Crystal	<b>Buyer Id - Id de l'acheteur</b> pwc024
<b>Telephone No. - N° de téléphone</b> (902) 940-7122 ( )	<b>FAX No. - N° de FAX</b> (902) 566-7514
<b>Destination - of Goods, Services, and Construction:</b> <b>Destination - des biens, services et construction:</b>	

**Instructions: See Herein**

**Instructions: Voir aux présentes**

<b>Delivery Required - Livraison exigée</b>	<b>Delivery Offered - Livraison proposée</b>
<b>Vendor/Firm Name and Address</b> <b>Raison sociale et adresse du fournisseur/de l'entrepreneur</b>	
<b>Telephone No. - N° de téléphone</b> <b>Facsimile No. - N° de télécopieur</b>	
<b>Name and title of person authorized to sign on behalf of Vendor/Firm</b> <b>(type or print)</b> <b>Nom et titre de la personne autorisée à signer au nom du fournisseur/</b> <b>de l'entrepreneur (taper ou écrire en caractères d'imprimerie)</b>	
<b>Signature</b>	<b>Date</b>

THE FOLLOWING CHANGES IN THE TENDER DOCUMENTS ARE EFFECTIVE IMMEDIATELY. THIS ADDENDUM WILL FORM PART OF THE CONTRACT DOCUMENTS.

THIS ADDENDUM IS RAISED TO PROVIDE THE FOLLOWING ANSWERS TO QUESTIONS PROVIDED BY BIDDERS.

## **SPECIFICATION - CLARIFICATIONS**

### **ANSWERS TO QUESTIONS**

1. **QUESTION**

We are requesting alternations for Division 8 section 08 71 00 for door hardware.

**ANSWER**

**Hinges**

IVES 3CB1 Hinges are an acceptable alternate for the McKinney TA 314 Hinges specified in Section 08 71 00 Clauses 2.1.2.1, 2.1.2.3, 2.1.2.4 & 2.1.2.5.

**Mortise Locks**

Schlage L-Series Mortice Locks are an acceptable alternate for Sargent 7800-Series Mortice Locks specified in Section 08 71 00 Clauses 2.1.2.1 & 2.1.2.3.

Glynn Johnson HL-6 Paddle Trim is an acceptable alternate for the Sargent PT Paddle Trim specified in Section 08 71 00 Clauses 2.1.2.1 & 2.1.2.3.

**Exit Devices**

Von Duprin 9827/9927 Series Exit Devices are an acceptable alternate for the Sargent 8710 Series Exit Device specified in Section 07 71 00 Clauses 2.1.2.2.

Von Duprin 98/99 Series Exit Devices are an acceptable alternate for the Sargent 8800 Series Exit Devices specified in Section 08 71 00 Clauses 2.1.2.4 & 2.1.2.5.

**Closers**

LCN 1460 Series Closers are an acceptable alternate for the Sargent 1430 Series Closers specified in Section 08 71 00 Clauses 2.1.2.1, 2.1.2.2, 2.1.2.3, 2.1.2.4 & 2.1.2.5.

**Overhead Holders**

Glynn Johnson 80 Series Overhead Stops are an acceptable alternate for the Sargent 590 Series Overhead Stops specified in Section 08 71 00 Clauses 2.1.2.1, 2.1.2.3, & 2.1.2.5.

**2. QUESTION**

I need clarification on the hardware for the aluminum doors & frames. In Section 08 71 00 Part 2 asks for Section 08 71 00 to supply hardware (Group A , B , C & D ) for the Aluminum Doors & Frames by Section 13 12 30. Now I had a call yesterday from the contractor who built the green house in Harrington a few years ago and he told me the supplier of the green house supplied the hardware and the hardware was already installed in the doors when they arrived on site. Please confirm if this is correct.

**ANSWER**

Reference Section 13 34 13 Clause 2.8.2 says to refer to Section 08 71 00 for Door Hardware. It is intended that aluminum doors & frames will be provided by Section 13 34 13 and that the hardware will be provided by Section 08 71 00. Note that fabricator of aluminum doors and frames is to coordinate with Section 08 71 00 to obtain all templates necessary for providing the necessary hardware preps to the doors and frames.

Reference Section 08 11 14 – Metal Doors and Frames. Note that this section relates only to the one hollow metal door and pressed steel frame required near grid reference C1. All other required doors & frames are aluminum fabrications provided under Section 13 34 13.

**3. QUESTION**

My company is interested in performing Testing & Balancing services for the Harrington Greenhouse Expansion project, but we would require permission from the Project Engineer to be considered eligible. Would you be so kind as to forward the attached letter to the Project Engineer?

**ANSWER**

The qualifications of a Testing & Balancing (TAB) contractor will be reviewed after award, when the General identifies their proposed TAB sub-contractor and provides a copy of the TAB's experience and certification, as part of the submittal and verification process.

**4. QUESTION**

We are requesting alternations for access doors section 15 01 00 and 14 40 00.

**ANSWER**

15 01 00 Clause 1.14–Acudor access doors are considered as acceptable products.

15 40 00 Clause 2.03.2.8 – Wilkins 740 considered as acceptable alternate.

**5. QUESTION**

We are requesting alternations for section 15 40 00.

**ANSWER**

- 15 40 00 Clause 2.03.2.1 & 2 – Watts floor and funnel drains are acceptable alternatives to the specified Zurn models.
- 15 40 00 Clause 2.03.2.3 – Watts dead level d c/w catch basin is an acceptable alternate to the specified ACO system.
- 15 40 00 Clause 2.03.2.4– Watts cleanout is an acceptable alternative to the specified Zurn model.
- 15 40 00 Clause 2.03.2.5– Watts water hammer arrester is an acceptable alternative to the specified Zurn model.
- 15 40 00 Clause 2.03.2.6– Watts wall hydrant is an acceptable alternative to the specified Zurn model.
- 15 40 00 Clause 2.03.2.7– Watts vacuum breaker is acceptable to the CSA-B64 series requirement.