



RETURN BIDS TO:
RETOURNER LES SOUMISSIONS À:
Bid Receiving Public Works and Government
Services Canada/Réception des soumissions
Travaux publics et Services gouvernementaux
Canada
800 Burrard Street, Room 219
800, rue Burrard, pièce 219
Vancouver
British Columbia
V6Z 0B9
Bid Fax: (604) 775-9381

SOLICITATION AMENDMENT
MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution
Public Works and Government Services Canada -
Pacific Region
800 Burrard Street, Room 219
800, rue Burrard, pièce 219
Vancouver
British C
V6Z 0B9

Title - Sujet Hatchery Complex Construction	
Solicitation No. - N° de l'invitation F1700-150669/A	Amendment No. - N° modif. 005
Client Reference No. - N° de référence du client F1700-150669	Date 2016-02-03
GETS Reference No. - N° de référence de SEAG PW-\$PWY-028-7723	
File No. - N° de dossier PWY-5-38345 (028)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2016-02-05	
Time Zone Fuseau horaire Pacific Standard Time PST	
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Lam (PWY), Tian	Buyer Id - Id de l'acheteur pwy028
Telephone No. - N° de téléphone (604) 775-9382 ()	FAX No. - N° de FAX (604) 775-6633
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction: DFO - Snootli Creek Hatchery - Bella Coola, BC	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

Solicitation No. - N° de l'invitation
F1700-150669/A

Amd. No. - N° de la modif.
005

Buyer ID - Id de l'acheteur
pwy028

Client Ref. No. - N° de réf. du client

File No. - N° du dossier CCC No./N°
PWY-5-38345

CCC - FMS No./N° VME

Les documents français seront disponibles sur demande.
Vous trouverez l'addenda n° 4 ci-joint.
Les autres conditions ne changent pas.

THE FOLLOWING CHANGES/CLARIFICATIONS IN THE TENDER DOCUMENTS ARE EFFECTIVE IMMEDIATELY.

“THIS ADDENDUM WILL FORM PART OF THE CONTRACT DOCUMENTS”

ANSWERS TO QUESTIONS RAISED BY BIDDERS

Q1. Drawing EC-101 indicates the limits of the work for contract shown around hatchery complex only. On Drawing C-101 indicates grading and gravel surfacing. Is the grading and gravel surfacing to be included in this contract ?

A1. All site development work other than immediately surrounding the Hatchery Complex Building is excluded.

Q2. What method of fastening is being used to fasten the standing seam roofing to the roof deck ?

A2. Standing-seam roof deck shall be fastened to wood sheathing below with steel roof deck manufacturer's proprietary screws, nylon head, spacing per manufacturer's printed instructions. Fastener proposed shall be part of Shop Drawing Submission. Wood sheathing is fastened to corrugated-metal structural deck by either metal z-bar strips within the insulation, or wood sleepers mechanically fastened.

Q3. Addendum No.3 refer to “13mm tongue and groove pressure treated plywood to replace the OSB on the main assembly detail 4 A-206 & cupola as well. Please advise as to which supplier offers this product, as our supplier has informed us minimum thickness of pressure treated t&g plywood available is 19mm.

A3. Sheathing product within the roof deck shall be 12.5mm softwood ply, sheathing grade, square edge.

Q4. Please clarify the requirement for the 2 ply. Mod. Bit. W.P. membrane, on the roof deck. Membrane thickness and membrane selection.

A4. Modified bitumen membrane shall be SBS single-ply high-heat resistant self-adhesive membrane with 3-ply woven polyethylene surface, 1mm thick x 910mm selvage Lastobond Shield HT or equal.

Q5. The answer to question #4 calls for ‘13 mm ply roof sheathing shall be pressure treated tongue and groove plywood.’ Note: This product is not available, please provide an alternative.

A5. Refer to Q3 above.

Q6. Will the owner be supplying all the structural fill including crush for the hatchery Complex on EC – 101 Shaded (Limit of work) and is the General Contractor therefore responsible for all excavation, compaction, backfill and grading of this area?

A6. Site of the hatchery complex will be prepared by the Owner and ready for the excavation for footings.

END OF ADDENDUM NO.4