

---

**Robertson Martin Architects**

216 Pretoria Avenue  
Ottawa, ON K1S 1X2  
Phone:613.567.1361  
<http://www.robertsonmartin.com>

**RFI RESPONSE  
NO. RFI-R-01-R2**

<u>To:</u>	CFIA 93 Mt. Edward Road, Charlottetown, PEI	<u>Project:</u>	<b>CFIA Fallowfield Lab Retrofit 3851 Fallowfield Road, Ottawa, ON K2H 8P9</b>
<u>Att:</u>	Mr. Blair Murphy, Project Leader	<u>Project No.:</u>	<b>H0541 (RMA)15181</b>
<u>CC:</u>	Ms. Lisa Lacasse, Contracting Specialist	<u>Date:</u>	<b>02/02/2016</b>

---

**RFI RESPONSE**

The Following response provides an answer to the request for information noted herein. Proceeding with work in accordance with this response indicates the *Contractor's* acknowledgement that there is no change in *Contract Price* and/or *Contract Time*. If the *Contractor* believes that this response affects the *Contract Price* or *Contract Time*, the *Contractor* shall promptly notify the *Consultant*.

---

**References:** All Drawings, Specifications and addenda.

**Title: RMA RFI Response - Glazing****1. Question:**

We require clarification on the type of glass for the store front entrance.

Nous avons besoin de précisions sur le type de verre pour l'entrée principale.

**1.1. Response:**

Basis of Design: **SOLARBAN 60 (2) Clear + Clear** or approved equivalent.

Concept de Base: **SOLARBAN 60 (2) Clear + Clear** ou équivalent approuvé

**Issued by:**



**Jason Gillmor**

Technologist, Dip. Arch Tech.

---

**Robertson Martin Architects Incorporated**