



RETURN BIDS TO:
RETOURNER LES SOUMISSIONS À:
Public Works Government Services Canada- Bid
Receiving / Réception des soumissions
189 Prince William Street
Room 405
Saint John
New Brunswick
E2L 2B9

SOLICITATION AMENDMENT
MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution
Public Works Government Services Canada- Bid
Receiving / Réception des soumissions
189 Prince William Street
Room 405
Saint John
New Bruns
E2L 2B9

Title - Sujet Key Control & Access System Install	
Solicitation No. - N° de l'invitation EC016-162188/A	Amendment No. - N° modif. 002
Client Reference No. - N° de référence du client R.061860.001	Date 2016-02-08
GETS Reference No. - N° de référence de SEAG PW-\$PWB-013-3799	
File No. - N° de dossier PWB-5-38193 (013)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2016-02-11	
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Johnston, Edward PWB	Buyer Id - Id de l'acheteur pwb013
Telephone No. - N° de téléphone (506) 636-3142 ()	FAX No. - N° de FAX (506) 636-4376
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction:	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

Solicitation No. - N° de l'invitation
EC016-162188/A

Amd. No. - N° de la modif.
002

Buyer ID - Id de l'acheteur
pwb013

Client Ref. No. - N° de réf. du client
R.061860.001

File No. - N° du dossier
PWB-5-38193 (013)

CCC No./N° CCC - FMS No./N° VME

This Solicitation Amendment No. Two (2) is raised to include the following addendum no. 2.

The following addendum to the tender documents is effective immediately. This addendum shall form part of the contracts documents.

All other terms and conditions remain the same.

Addendum no. 2

CLARIFICATIONS

1. DRAWINGS:

.1 **Reference Drawing A-1, Under HARDWARE: Add the following hardware to the list.**

a- **1025 Combined cores for the key boxes**

b- **2050 Cut keys**

2. SPECIFICATIONS:

Section 28 13 00 page 2 of 7, Article 2.2.4: Access control system

Replace the following paragraph:

Manufacturer: Basis Access Control Systems, RBH Access Technologies, or equal.

With this one:

Manufacturer: Basis Access Control Systems.

Section 28 13 00 page 5 of 7, Article 2.4.21: Key cabinets

Remove the following from the specifications:

Building 19

Qty	Part #	Description
1	K1C2836B096G	96-key SAM, 6"d x 28"w x 36"h
1	2690154	Card Reader – HID Proximity
1	To Be Advised	Cabinet Cap - 64/96

Add the following items to building 2:

Qty	Part #	Description
2	2K20013-1	Remote access panel

Solicitation No. - N° de l'invitation
EC016-162188/A

Amd. No. - N° de la modif.
002

Buyer ID - Id de l'acheteur
pwb013

Client Ref. No. - N° de réf. du client
R.061860.001

File No. - N° du dossier
PWB-5-38193 (013)

CCC No./N° CCC - FMS No./N° VME

Revise the quantities for building 3 as follows:

Qty	Part #	Description
8	K1C2836B096G	96-key SAM, 6"d x 28"w x 36"h
8	2690154	Card Reader – HID Proximity
8	To Be Advised	Cabinet Cap - 64/96
1	2K20013-1	Remote Keypad Enclosure For Handicap accessible Cabinet

3. QUESTIONS AND ANSWERS

Question 1. Can you please provide a list of attendees to the site visit?

Answer 1. Due to privacy issues this information cannot be provided.

Question 2. Drawing provided only show Building 1, 2, 3, 4 and A1, on Page 5 of 7 The Specification describes building 1, 2, 3, 4, 19 please confirm which numbering scheme?

Answer 2. Building 1,2,3,4 and A-1 is correct. Any reference to building 19 shall be removed from the plans and specifications.

Question 3. KSI key system is not an integration partner with Best Access or RBH? Could we select an integration partner on the KSI site?

Answer 3. There is BEST Access Systems components currently installed within the institution. We have confirmed with KSI that BEST will integrate with the KSI System. Best Access must be maintained.

Question 4. Where are the card access panels to be located in building 2, 3, 4 and A1?

Answer 4. Card access panels are located in Building 1 in the Central Communications/Equipment Room and in building 3 only. All other readers and keypads tie into the Key System Directly.

Question 5. Section 28 13 00, page 5, 2.4.21 indicates 7 cabinets in Building 3 and 1 cabinets in Building 19. Drawing E-5 indicates 8 cabinets in Building 3 and 0 cabinets in Building 19. Please confirm what is required?

Answer 5. The answer to this question is part of this amendment. See part 2 SPECIFICATIONS.

Question 6. Request extension to Solicitation Closing Date?

Answer 6. NO extension to Solicitation Closing Date. Closing Date remains as originally posted.

Please note: As per SI03-Enquiries during the Solicitation Period, enquiries should be received no later than five (5) calendar days prior to the date set for solicitation closing. Therefore the last day for questions was February 05, 2016. Questions received after that date shall not be considered.

4. PHOTOS FROM SITE VISIT

Photos taken at the February 02 Site Visit have been uploaded are available for viewing in the folder titled ec016-162188 site visit photos.zip.