



RETURN BIDS TO:

RETOURNER LES SOUMISSIONS À:

**Bid Receiving - PWGSC / Réception des soumissions
- TPSGC**
11 Laurier St. / 11, rue Laurier
Place du Portage, Phase III
Core 0B2 / Noyau 0B2
Gatineau, Québec K1A 0S5
Bid Fax: (819) 997-9776

**SOLICITATION AMENDMENT
MODIFICATION DE L'INVITATION**

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution
Fuel & Construction Products Division
11 Laurier St./11, rue Laurier
7A2, Place du Portage, Phase III
Gatineau, Québec K1A 0S5

Title - Sujet TANK, LIQUID STORAGE	
Solicitation No. - N° de l'invitation W8482-168290/A	Amendment No. - N° modif. 002
Client Reference No. - N° de référence du client W8482-168290	Date 2016-02-10
GETS Reference No. - N° de référence de SEAG PW-\$\$HL-601-68773	
File No. - N° de dossier hl601.W8482-168290	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2016-02-29	
Time Zone Fuseau horaire Eastern Standard Time EST	
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Lemieux, Johanna	Buyer Id - Id de l'acheteur hl601
Telephone No. - N° de téléphone (873) 469-3347 ()	FAX No. - N° de FAX () -
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction:	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

Amendment number 002 to Request for Proposal (RFP) W8482-168290/A which closes February 17, 2016 at 2:00 p.m. is raised to:

1. Revise the Request for Proposal closing date to: **FEBRUARY 29, 2016** at 2:00pm EST.
2. Respond to questions received from bidders and provide the following additional information:

Q1- Open top or closed top with hole/cap? Or removable lid/lid fixed with hinge?

A1- The top is removable and is tied down by eye nuts. The cover is also fitted with handles.

Q2- Are handles required?

A2- No handles required on the tank, but the cover requires handles.

Q3- Is there a need for drainage?

A3- Yes

Q4- Does the tank need levelers?

A4- Yes

Q5- Is the tank portable or fixed?

A5- Fixed

Q6- Does the inside need to be polished sanitary?

A6- The finish of the tank must be chemical resistant as it will be used to stock chemicals.

Q7- How many litres will it hold, minimum and maximum?

A7- Min. 0 Gallon, Max 50. Gallons

Q8- What kind of opening is required to fill the tank?

A8- The tank must be fitted with hole on the side of the tank where a flanged pipe will be installed.

Q9- What is the wall thickness of the tank?

A9- 1/8"

Q10- What and where are the required nozzle connections?

A10- The tank is fitted with two 2" flanges #150. One is located on the side of the tank and the other one is located on one of the tapered sides.

Q11- The description notes the tanks are tapered. How much taper and what direction?

A11- There are two 45 degree tapers at the bottom of the tank on the length of the tank.

Q12- What are the dimensions of the skid?

A12- The base of the tank requires support brackets. The skid dimensions are 33" X 33" X 61.63" (The skid drawing is not owned by DND).

Q13- Is the skid a base type or a total enclosure type?

A13- Base type

All other terms and conditions of the Request for Proposal remain unchanged.