



**Royal Canadian Mounted Police**  
**Gendarmerie royale du Canada**

**RETURN BIDS TO :**

**RETOURNER LES SOUMISSIONS :**

Bid Receiving Unit / Grope de la réception des sousmissions

Procurement and Contracting Services  
 73 Leikin Drive,  
 Visitor Center - Building M1  
 Mailstop # 15  
 Ottawa, ON K1A 0R2

Attn: Shannon Plunkett

**AMENDMENT TO THE INVITATION TO TENDER**

Royal Canadian Mounted Police

We hereby offer to sell to Her Majesty the Queen in right of Canada, in accordance with the terms and conditions set out herein, referred to herein or attached hereto, the goods, services and construction listed herein and on any attached sheets at the price(s) set out therefore.

**MODIFICATION À L'APPEL D'OFFRES**

Gendarmerie royale du Canada

Nous offrons par la présente de vendre à Sa Majesté l Reine du chef du Canada, aux conditions énoncées ou incluses par référence dans la présente et aux annexes ci-jointes, les biens, services et construction énumérés ici sur toute feuille ci-annexée, au(x) prix indiqué(s).

Comments – Commentaries

Vendor/Firm Name and Address

Raison sociale et adresse du fournisseur/de l'entrepreneur

Telephone No. – No de téléphone:

( )

Facsimile No. – No de télécopieur:

( )

<b>Title-Sujet</b> Construction – Residential Housing - Saskatchewan		
<b>Solicitation No. – No. de l'invitation</b> 201604781	<b>Amend. – Modif.</b> No. : 3	<b>Date</b> February 10, 2016
<b>Client Reference No. - No. de Référence du Client</b> 201604781		
<b>GETS Reference No. – No de Référence du SEAG</b> 201604781		
<b>Solicitation Closes – L'invitation prend fin</b> <b>at - à</b> 2 :00 pm <b>EST</b> <b>on - le</b> February 23rd, 2016		
<b>F.O.B. - F.A.B.</b> Destination		
<b>Address Enquiries to: - Adresser toute questions à :</b> Eric Glynn – Contracting Authority <a href="mailto:Eric.glynn@rcmp-grc.gc.ca">Eric.glynn@rcmp-grc.gc.ca</a>		
<b>Telephone No. - No de téléphone</b> 613-843-5533	<b>Fax:</b> 613-825-0082	
<b>Destination of Goods - Destinations des biens:</b> <b>See Herein</b>		
<b>Instructions : See Herein / Voir aux présentes</b>		
<b>Delivery Required – Livraison exigée:</b> <b>See Herein</b>		
<b>Name and Title of person authorized to sign on behalf of Vendor/Firm.</b> <b>Nom et titre de la personne autorisée à signer au nom du fournisseur/de l'entrepreneur</b>		



Royal Canadian Mounted Police

Gendarmerie royale du Canada

Amendment #3 of Solicitation 201604781 has been issued to respond to **Questions and Answers – Part 3**, and **Request for Alternative Products and/or Materials – Part 2**.

**Questions and Answers – Part 3:**

Q21 – Instead of doing proposed 8" concrete wall with a framed wall with r20 on the inside, can we do a ICF basement wall which gives you a r22 foundation and eliminates the 2x4 wall on the inside?

**A21 – Yes.**

Q22 – What percentage is required for Labour and Material Bonds? Do you require a letter of intent in addition to the actual Tender Documents?

**A22 – A minimum of 50% of the resulting Contract is required for Labour and Material Bonds. The request to submit this bond only occurs after a successful Contractor has been identified.**

Q23 – Are any window coverings required for this project or will this be done through the owner?

**A23 – Yes, both the supply and installation of window coverings is required. See Specification, Section 08 B 2.1.**

Q24 – Under ITT Amendment #2, your Answer to Q18 did not specify who is responsible for roughing in of the central vac system? Please confirm.

**A24 – The General Contractor is responsible for the Rough-in only.**

Q25 – What type of sump pit configuration do you want? Do you want a pump in it? or just a “Y” off the main drain run into it with a P-Trap and backflow preventer? Also, do you want a perforated tank or solid tank with the weeping tile cut into it?

**A25 – The requirement is for a solid sealed plastic tank, with pumpout, appropriate check valve, splashpad, and hose. Weeping tile will feed into the tank.**

Q26 – What site services are required?

**A26 – Sewer, domestic water, electrical, natural gas, and telephone.**

Q27 – Is there a mechanical drawing that pertains specifically to the Cornoach building?

**A27 – No, all like buildings are the same.**



Royal Canadian Mounted Police

Gendarmerie royale du Canada

Q28 – Under Question and Answers #1, 2, & 16, a clarification is required.

***A28 – The unit(s) in Kamsack have underground electrical services. The unit(s) in Canora have sewer and water hookups for the home on the 4<sup>th</sup> Avenue lot, and are fed from the South side.***

**Request for Alternative Products and/or Materials – Part 2:**

Request 3 – Chadd Winterhalt – Winteralt Mechanical Ltd. – Furnace, Water Heater and HRV.

***Response 3 – The furnace is not approved as it isn't the correct size. The filter rack and John Wood Domestic Hot Water heater are both approved and the van EE Heat Recovery ventilator is approved as long as it is AVS. The Venmar HRV isn't approved due to lesser warranty terms.***

Request 4 – Kayle Kessler – Wolseley Express Champion – Furnace and Air Exchanger.

***Response 4 – The furnace is not approved. The Van EE Air Exchanger is approved, as long as it is AVS. The Venmar HRV is not approved.***

Request 5 – Chadd Winterhalt – Winteralt Mechanical Ltd. Various other pieces of equipment. (Bathroom accessories, sinks, faucets, etc)

***Response 5 – All approved.***

ALL OTHER TERMS AND CONDITIONS REMAIN UNCHANGED.