



TENDER AMENDMENT

RETURN BIDS TO:

Parks Canada Agency
635 – 8 Avenue S.W., Suite 1300
Calgary, AB T2P 3M3
Bid Fax: (403) 292-4475

The referenced document is hereby amended: unless otherwise indicated, all other terms and conditions of the contract remain the same.

Issuing Office:

Parks Canada Agency
635 – 8 Avenue S.W., Suite 1300
Calgary, AB T2P 3M3

MODIFICATION D'APPEL D'OFFRES

RETOURNER LES SOUMISSIONS À :

Agence Parcs Canada
635 – 8 Avenue S.O., pièce 1300,
Calgary, AB T2P 3M3
N° de télécopieur pour soumissions : (403) 292-4475

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Bureau de distribution :

Agence Parcs Canada
635 – 8 Avenue S.O., pièce 1300
Calgary (AB) T2P 3M3

Title: Remplacement de la toiture du logement du personnel aux sources thermales Miette – Parc national Jasper		
Solicitation No.: / N° de l'invitation : 5P420-15-5186/B	Amendment No.: / N° de modification de l'invitation : 001	Date: February 12, 2016 Date : 12 février 2016
GETS Reference No.: / N° de référence de SEAG : PW-16-00717883		
Solicitation Closes: / L'invitation prend fin :		
At: 02:00 PM	On: February 17, 2016	Time Zone: Mountain Standard Time (MST)
À : 14h00	Le : 17 février 2016	Fuseau horaire : Heure normale des Rocheuses (HNR)
Address Inquiries to: / Adresser toute demande de renseignements à : Nicole Levesque-Welch		
Telephone No.: / N° de téléphone : (403) 292-4691	Fax No.: / N° de télécopieur : (403) 292-4475	Email Address: / Courriel : nicole.levesque-welch@pc.gc.ca
TO BE COMPLETED BY THE BIDDER (type or print)		
Vendor/Firm Name – Nom du fournisseur/de l'entrepreneur		
Address - Adresse		
Name of person authorized to sign on behalf of the Vendor/Firm Nom de la personne autorisée à signer au nom du fournisseur/de l'entrepreneur		
Title - Titre		
Signature		Date



La présente modification vise à enlever à identifier les participants à la visite des lieux et pour fournir plus de clarification sur les spécifications.

Projet

- Remplacement de la toiture - Logement du personnel aux sources thermales Miette – Parc national Jasper (**5P420-15-5186/B**, pas 5P420-15-5186/A)

Visite Facultative des lieux

- Les gens présents à la visite facultative des lieux conduit le mercredi, 3 février 2016 à 13h00 comprenait des personnels de PCA (Stephen Suen, Andrew Oosting, Uwe Waeser) et des représentants de Sundance (Jack Groff, Jim Groff), Rocky Mountain Sundeck & Roofing Ltd., Flynn Canada Ltd., Fraser Bros. Roofing Ltd., SAW Construction Ltd., et Jasper Concrete Ltd.
- Les discussions ont menés aux clarifications suivantes au sujet de la spécification livrée le 11 janvier 2016 :

Specification Item 1.01.1.3

Existing wood deck identified as 2x6 T&G cedar - Bid amount to include replacement of 400 lineal ft - Parks Canada to apply paint/stain to open ceilings and soffits below as required at a later date

Specification Item 1.01.3

Roofing Contractor will comply with all relevant government regulatory requirements including but not limited to acts, regulations, directives, policies, and guidelines - Roofing Contractor will assume 'prime contractor' status, and be responsible for supplier, worker, subcontractor, and worksite compliance to Alberta OH&S Regulations and Codes

Specification Item 1.01.7

The Development Permit will be required and will be applied and paid for by Parks Canada. A building permit is not required for this work.

Specification Item 1.01.10

Parks Canada to remove enough ground snow prior to project start to enable reasonable building access, and set-up on east side of building - Roofing Contractor will be responsible for rooftop snow removal as required to designated ground location(s)

Specification Item 1.01.12

The contractor will provide sanitary facilities on site.

Specification Item 1.03.2

Roofing Contractor will introduce health and safety coordinator and submit site specific health and safety plan for review
- Parks Canada to provide a radio to Roofing Contractor for emergency communication with Central Dispatch if required
- Parks Canada to also facilitate the double-locking of lower gate to provide access to Roofing Contractor when Parks Canada staff are not onsite

Specification Item 1.9.1

Roofing Contractor will provide a 40-year limited conditional manufacturer's warranty with respect to the quality of pre-finish on metal standing seam panels and flashings



Specification Item 1.9.2

The Roofing Contractor will provide a 2-year maintenance bond consigned to Parks Canada covering leak or defect repairs resulting from faulty workmanship - Maintenance bond must be issued by a duly incorporated surety company authorized to transact business in the Province of Alberta

Specification Item 2.02.1.b

Delete plywood leveling surface.

Tous les autres termes et conditions resteront inchangés