

RETURN BIDS TO :

RETOURNER LES SOUMISSIONS :

Bid Receiving Unit / Grope de la réception des sousmissions

Procurement and Contracting Services 73 Leikin Drive, Visitor Center - Building M1 Mailstop # 15 Ottawa, ON K1A 0R2

Attn: Shannon Plunkett

AMENDMENT TO THE INVITATION TO TENDER

Royal Canadian Mounted Police

We hereby offer to sell to Her Majesty the Queen in right of Canada, in accordance with the terms and conditions set out herein, referred to herein or attached hereto, the goods, services and construction listed herein and on any attached sheets at the price(s) set out therefore.

MODIFICATION À L'APPEL D'OFFRES

Gendarmerie royale du Canada

Nous offrons par la présente de vendre à Sa Majesté I Reine du chef du Canada, aux conditions énoncées ou incluses par référence dans la présente et aux annexes ci-jointes, les biens, services et construction énumérés ici sur toute feuille ci-annexée, au(x) prix indiqué(s).

Comments - Commentaries

Vendor/Firm Name and Address

Raison sociale et adresse du fournisseur/de l'entrepreneur

Telehone No. – No de téléphone:

()

Facsimile No. - No de télécopieur:

()

Construction – Residenti	al Housing - Saskatchev	wan
Solicitation No. – No. de l'invitation 201604781	Amend. – Modif.	Date
	No. : 4	February 12, 2016
Client Reference No N	o. de Référence du Clie	ent
201604781		
GETS Reference No. – N	o de Référence du SEA	G
201604781		
Solicitation Closes – L'in	vitation prend fin	
at - à 2 :00 pm EST		
on - le February 23rd, 2	2016	
F.O.B F.A.B.		
Destination		
Address Enquiries to: - A	Adresser toute questior	ns à :
Eric Glynn – Contracting	g Authority	
Eric.glynn@rcmp-grc.gc.	<u>ca</u>	
Telephone No No de téléphone		Fax:
613-843-5533		613-825-0082
Destination of Goods - I	Destinations des biens:	
See Herein		
Instructions : See Hereir	n / Voir aux présentes	
Delivery Required – Livr	aison exigée:	
See Herein		
	on authorized to sign on	h behalf of Vendor/Firn
Name and Title of perso		



Amendment #4 of Solicitation 201604781 has been issued to respond to **Questions and** Answers – Part 4, and <u>Request for Alternative Products and/or Materials – Part 3</u>.

Questions and Answers – Part 4:

- Q29 The requirement is for 1 1/2" rigid insulation on all exterior walls; however, only Hardi Board siding can be installed for rigid insulation over 1". Please clarify.
- A29 The 1.5" rigid insulation has vertical 1.5 inch strapping every 2 feet; approximately.
 The Hardi Board siding can be fastened solidly on the strapping through the air and water house wrap which is fastened right to the OSB sheathing and structural framing.
- Q30 Is Air Conditioning included in this requirement?
- A30 No.
- Q31 Do the exterior doors get storm doors as well?
- A31 Yes. See Specification 08A (3).
- Q32 Do exterior doors get windows in the slab?
- A32 Yes. See Specification 08A (3).
- Q33 In Coronach specifically, there is only 1 sewer and water service into lots 2 and 3. Is it acceptable to service both sides off the duplex off of one 4" sewer line and 1 3/4" water line?

Note: I've confirmed with the town of coronach that they will accept this. There would still be a water meter for each side. The only other option to have two separate waterlines is digging up the newly paved street and tying a new service into the main. The town will not cover any of these costs.

A33 – In Coronach, feed the building with one 4 inch sewer line and one 1.75 inch waterline, both units are to be separately metered.

Q34 – In Coronach, it appears that the yard of the existing RCMP single family dwelling to the south encroaches into lots 2 and 3 of the duplex by approximately 15'. Fencing and a garden shed will need to be relocated. Should the tender include costs involved in relocating the shed and demo of fence?

A34 – No, do not include this. This matter will be handled separately.



- Q35 Do we leave the bid amount blank for the project locations we are not interested in bidding?
- A35 Yes, you can leave them blank, or enter "n/a".

Request for Alternative Products and/or Materials – Part 3:

- Request 6 Justin Iversen DSI Contracting Bakor Dampproofing Concrete Foundation, Taymor Door Hardware, and River Rock.
- Response 6 Bakor dampproofing is not approved, as no brush or spray on products is allowed. Taymor Door Hardware is not approved for security / consistency reasons. 0.75 Crused rock (clean) would be approved, only where River Rock is not available.

ALL OTHER TERMS AND CONDITIONS REMAIN UNCHANGED.