



RETURN BIDS TO:
RETOURNER LES SOUMISSIONS À:
Public Works Government Services Canada- Bid
Receiving / Réception des soumissions
189 Prince William Street
Room 405
Saint John
New Brunswick
E2L 2B9

SOLICITATION AMENDMENT

MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

All enquiries are to be submitted in writing to the Contracting Officer, Janine Donovan: Email - janine.donovan@pwgsc.gc.ca or Fax No. (506) 636-4376..

Vendor/Firm Name and Address

**Raison sociale et adresse du
fournisseur/de l'entrepreneur**

Issuing Office - Bureau de distribution

Public Works Government Services Canada- Bid
Receiving / Réception des soumissions
189 Prince William Street
Room 405
Saint John
New Bruns
E2L 2B9

Title - Sujet Harbour Improvements, Back Bay,NB	
Solicitation No. - N° de l'invitation EC373-162339/A	Amendment No. - N° modif. 003
Client Reference No. - N° de référence du client R.076165.001	Date 2016-02-17
GETS Reference No. - N° de référence de SEAG PW-\$PWB-020-3810	
File No. - N° de dossier PWB-5-38205 (020)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2016-02-24	Time Zone Fuseau horaire Atlantic Standard Time AST
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Donovan, Janine PWB	Buyer Id - Id de l'acheteur pwb020
Telephone No. - N° de téléphone (506) 636-5347 ()	FAX No. - N° de FAX (506) 636-4376
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction:	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

Cette modification à l'invitation numéro trois (3) est soumise pour inclure l'addenda numéro 3 suivant.

La modification qui suie apportée aux documents de soumission entre en vigueur dès maintenant.
L'addenda fera partie des documents de contrat.

Toutes autres conditions ne changent pas.

Addenda 3.

1. **QUESTIONS AND ANSWERS**

Q1: On drawing C1 of 8 it is showing several barges within the area of the existing breakwater and the wharf. Will these barges be moved so we can access the dredge area and containment cell?

A1: Drawing C1 of 8

Several barges are shown on drawing within the area of the work. The contractor will coordinate moving of the barges with the fishermen and the Harbour Authority as required to do the work.

Q2: In section 35 20 23 item 1.4.1.1 it is noting that we are not to interfere with fishing operations, marine operations, etc. Are the boats that tie up to the wharf within the dredge area be removed so we can perform our work? Are we able to use the wharf for offloading of barges, etc?

A2: Section 35 20 23 Part 1.4.1.1

Fishing and marine operations will be ongoing. The contractor will coordinate with the fishermen and the Harbour Authority for Moving of fishing vessels in areas of work. The wharf will be active during construction. Off-loading of barges etc. can be done depending on loads and accessibility once again cooperation with local fishermen and Harbour Authority is essential. Should contractor choose to use the wharf for unloading they are to perform their own assessment of wharf load capability. PWGSC will not provide loads nor will they do load assessment.

2. **SPECIFICATIONS**

1. Specification Section 26 05 31

.1 Revise item 2.1 as follow

2.1 JUNCTION AND PULL BOXES

- .1 Construction: 316 stainless steel, CSA 4X rated.
- .2 Covers: lockable stainless steel removable hinged with stainless steel hasps and neoprene gasket and stainless steel screws.
- .3 Mounting feet and mounting plate for terminal block installation.
- .4 Sized as required with drilled conduit holes to suit.
- .5 Acceptable materials:
 - .1 Hoffman
 - .2 Hammond
 - .3 Rittal
 - .4 Crouse Hinds

2. Specification Section 26 09 23.02

.1 Revise item 2.1 as follows:

2.1 PHOTOELECTRIC LIGHTING CONTROL

- .1 Die cast aluminum body, stem mounting.

- .2 SPST-Rated 2000W, 120 V.
- .3 Voltage variation: plus or minus 10%.
- .4 Temperature range: minus 40 °C to plus 60 °C.
- .5 Switching on lights at 10 to 50 lx.
- .6 Switching off lights at 30 to 150 lx.
- .7 Rated for 5000 operations.
- .8 Fail-safe circuit when de-energized.
- .9 On-off adjustment by moving slide cover.
- .10 Time delay both 'on' and 'off'.
- .11 Colour coded lead wires.
- .12 Five year warranty.
- .13 Acceptable materials:
 - .1 Tork 2110 Series.

3. Specification Section 26 09 23.02

.1 Add item 2.2 as follows:

2.2

CONTACTORS

- .1 Contactors: to CSA C22.2 No.14.
- .2 Electrically held controlled by pilot devices as indicated and rated for type of load controlled. Half size contactors not accepted.
- .3 Complete with 1 normally open and 1 normally closed auxiliary contacts unless indicated otherwise.
- .4 Mount in a 316 stainless steel CSA Enclosure 4 unless otherwise indicated.
- .5 Rated for a 30A lighting load.
- .6 Control coil rated 120V with fused primary.
- .7 Acceptable manufacturers or approved equal:
 - .1 Allen-Bradley
 - .2 Cutler-Hammer
 - .3 Schneider Electric
 - .4 Siemens.

4. Specification Section 26 24 01

2.3 METER SOCKETS

.1 Add the following acceptable materials to item 2.3.1.7:

- .2 Eaton Cutler-Hammer
- .3 Microelectric

5. Specification Section 01 11 00

Remove paragraph 1.31. Scheduling of Payment

Solicitation No. - N° de l'invitation

EC373-162339/A

Client Ref. No. - N° de réf. du client

R.076185.001

Amd. No. - N° de la modif.

003

File No. - N° du dossier

PWB-5-38205

Buyer ID - Id de l'acheteur

pwb020

CCC No./N° CCC - FMS No./N° VME

3. DRAWINGS

Reference Drawing E2

1. Service detail:

- .1 Revise combination lighting contactor and photo cell to separate contactor and photocell as per specification sections noted above. Revise note 7 as follows:
 - .7 Lighting contactor and photo-electric controller.
- .2 Revise pull box from cast to stainless steel. Revise note 8 as follows:
 - .8 406mmH x 508mmW x 152mmD CSA 4X 316 stainless steel junction box/pull box c/w backplane. Supply and install reducing terminal blocks and ground bar.

Reference Drawing E3

1. Detail 5

- .1 Revise feraloy junction box to a CSA 4X 316 stainless steel unit with continuous hinge and clamps.