


LEGEND - SINGLE LINE & SCHEMATIC DIAGRAMS

NOT ALL SYMBOLS MAY APPEAR ON DRAWINGS

SYMBOL	DESCRIPTION	SYMBOL	DESCRIPTION	SYMBOL	DESCRIPTION
	H.V. CABLE STRESS CONE TERMINATION CABLE SIDE		HAND-OFF-AUTO 3 POSITION, 2 POLE, SHOWN IN 'HAND' POSITION		PANEL A
	INCOMING UTILITY CONNECTION		TWO POSITION SELECTOR SWITCH SHOWN IN 'LOCAL' POSITION		FLOAT SWITCH
	ULTIMATE AVAILABLE FAULT LEVEL (RMS SYM)		KEYSWITCH		ULTRASONIC HEAD
	PRESENT AVAILABLE FAULT LEVEL (RMS SYM)		SPEED SWITCH		RADIO ANTENNA
	SHORT CIRCUIT RATING OF EQUIPMENT		EMERGENCY STOP		METAL OXIDE VARISTOR
	LV CIRCUIT BREAKER (MOLDED CASE)		PUSHBUTTON - NORMALLY CLOSED MOMENTARY		RECTIFIER
	LV CIRCUIT BREAKER (DRAWOUT)		PUSHBUTTON - NORMALLY OPEN MOMENTARY		THYRISTOR GENERAL
	INSULATED CASE CIRCUIT BREAKER ELECTRICALLY OPERATED FOR REMOTE OR LOCAL (MANUAL) TRIP AND CLOSE		N.O. DELAYED CLOSING AFTER ENERGIZATION OF ACTUATING COIL		BATTERY
	BREAKER AUX CONTACTS BREAKER KEY INTERLOCK (# INDICATES KEY MATCH)		N.C. DELAYED CLOSING AFTER ENERGIZATION OF ACTUATING COIL		GROUND
	BREAKER DESIGNATION e.g. 52-71		N.O. DELAYED CLOSING AFTER DE-ENERGIZATION OF ACTUATING COIL		1 CONDUCTOR
	PROTECTION (OPERATIVE CIRCUIT) BREAKER TRIP UNIT RATING (NOTE 2)		N.C. DELAYED CLOSING AFTER DE-ENERGIZATION OF ACTUATING COIL		1 CONDUCTOR + NEUTRAL
	DRAWOUT CELL		LEVEL SWITCH - CLOSSES ON FALLING LEVEL		1 NEUTRAL
	HV CIRCUIT BREAKER (DRAWOUT) LETTER DESIGNATIONS IF USED: OCB: OIL CIRCUIT BREAKER SFC: SFC VAC: VACUUM R: RECLOSER		LEVEL SWITCH - CLOSSES ON RISING LEVEL		2 CONDUCTORS
	LIGHTNING ARRESTOR/SURGE ARRESTOR		LEVEL SWITCH - OPENS ON RISING LEVEL		2 CONDUCTORS + NEUTRAL
	POWER DISCONNECT SWITCH		TEMPERATURE SWITCH - CLOSSES ON RISING TEMPERATURE		3 CONDUCTORS
	LOAD BREAK SWITCH		TEMPERATURE SWITCH - OPENS ON RISING TEMPERATURE		3 CONDUCTORS + NEUTRAL
	FUSED CUTOFF (POLE MOUNTED)		PRESSURE SWITCH - CLOSSES ON RISING PRESSURE		PORTABLE CABLE WITH SEPARABLE CONNECTORS
	FUSED SWITCH		PRESSURE SWITCH - OPENS ON RISING PRESSURE		EYS SEAL
	EARTHING/SAFETY GROUNDING SWITCH		FLOW SWITCH - CLOSSES ON INCREASING MATERIAL FLOW		STUB-OUT FOR CONDUIT, OR INSULATED END FOR SPARE CABLE OR CONTROL WIRING
	LIVE LINE INDICATOR		FLOW SWITCH - OPENS ON INCREASING MATERIAL FLOW		TRANSFORMER
	AUTOMATIC TRANSFER SWITCH		LIMIT SWITCH - NORMALLY OPEN		AUTO TRANSFORMER
	MANUAL TRANSFER SWITCH		LIMIT SWITCH - NORMALLY CLOSED		REACTOR
	CONTROL FUSE		LIMIT SWITCH - NORMALLY CLOSED HELD OPEN		REACTOR (ALTERNATE SYMBOL)
	INDICATING INSTRUMENT: V = VOLTMETER A = AMMETER Hz = FREQUENCY METER KW = KILOWATT METER SS = SYNCHROSCOPE VS = VOLT METER SWITCH AS = AMMETER SWITCH		LIMIT SWITCH NORMALLY OPEN HELD CLOSED		FIELD WINDING
	TRANSDUCER		LIMIT SWITCH MAINTAINED NORMALLY OPEN		POTENTIAL TRANSFORMER
	CONVERTER		LIMIT SWITCH MAINTAINED NORMALLY CLOSED		CURRENT TRANSFORMER
	INVERTER		FOOT SWITCH - DEPRESS TO CLOSE		ZERO SEQUENCE CURRENT TRANSFORMER
	REDUCED VOLTAGE STARTER		FOOT SWITCH - DEPRESS TO OPEN		TEST LINK/SWITCH/BLOCK (1-LINE DIAGRAM)
	VARIABLE FREQUENCY DRIVE		RELAY COIL WITH INHIBIT		TEST LINK (WIRING DIAGRAM)
	INTEGRATING/RECORDING MAX. DEMAND INSTRUMENT: kWg = KILOWATT DEMAND METRE kVAR = KILOVOLT AMPERE REACTIVE METRE ET = ELAPSED TIME (OR HOUR METRE) Ad = AMMETER DEMAND METRE		RELAY COIL OR CONTACTOR COIL		600V BUSDUCT
	DIGITAL METERING SYSTEM POWER METER TYPE 1		MECHANICAL INTERLOCK		ELECTRICAL AND/OR MECHANICAL INTERLOCK
	DIGITAL METERING SYSTEM POWER METER TYPE 2		ELECTRICAL AND/OR MECHANICAL INTERLOCK		CABLE LABELS
	DIGITAL METERING SYSTEM REVENUE CERTIFIED METER		FORM-C CONTROL CONTACT		6112 SMS-7BKR OR 62A-7
	UTILITY POWER METER		N.O. CONTACT (ALTERNATE) OR DISCONNECT SWITCH		PANEL FRONT DEVICES
	SLIP RING		N.C. CONTACT (ALTERNATE)		ILLUMINATED PUSHBUTTON (GREEN)
	CAPACITOR		RTD RESISTANCE TEMPERATURE DETECTOR		PILOT LIGHT (RED)
	AC MOTOR (20 DESIGNATES HP)		RESISTOR (GENERAL)		NON-ILLUMINATED PUSHBUTTON (STOP)
	AC MOTOR (GENERAL)		NEUTRAL GROUNDING RESISTOR		MUSHROOM HEAD PUSHBUTTON
	DC MOTOR (GENERAL)		SHUNT		2-POSITION SELECTOR SWITCH
	AC GENERATOR SET		RESISTOR (ALTERNATE SYMBOL)		3-POSITION SELECTOR SWITCH
	DC GENERATOR (OR EXCITER)		HEATER		POTENTIOMETER
	CONTACTOR MAIN CONTACTS		COIL SERIES MAGNETIC OVERLOAD DEVICE/SOLENOID		CUT-OUT WITH CLOSING BUTTON
	VACUUM CONTACTOR		INDICATOR LIGHT		NOTES:

ANSI/IEEE STANDARD ELECTRICAL POWER SYSTEM DEVICE FUNCTION NUMBERS (NOTE 1):

- MASTER ELEMENT
- TIME-DELAY STARTING OR CLOSING RELAY
- CHECKING OR INTERLOCKING RELAY
- MASTER CONTACTOR
- STOPPING DEVICE
- STARTING CIRCUIT BREAKER
- ANODE CIRCUIT BREAKER
- CONTROL POWER DISCONNECTING DEVICE
- REVERSING DEVICE
- UNIT SEQUENCE SWITCH
- RESERVED FOR FUTURE APPLICATION
- OVERSPEED DEVICE
- SYNCHRONOUS SPEED DEVICE
- UNDER-SPEED DEVICE
- SPEED OR FREQUENCY MATCHING DEVICE
- RESERVED FOR FUTURE APPLICATION
- SHUNTING OR DISCHARGE SWITCH
- ACCELERATING OR DECELERATING DEVICE
- STARTING-TO-RUNNING TRANSITION CONTACTOR
- ELECTRICALLY OPERATED VALVE
- DISTANCE RELAY
- EQUALIZER CIRCUIT BREAKER
- TEMPERATURE CONTROL DEVICE
- RESERVED FOR FUTURE APPLICATION
- SYNCHRONIZING OR SYNCHRONISM-CHECK DEVICE
- APPARATUS THERMAL DEVICE
- UNDERVOLTAGE RELAY
- FLAME DETECTOR
- ISOLATING CONTACTOR
- ANNUNCIATOR RELAY
- SEPARATE EXCITATION LEVEL
- DIRECTIONAL POWER RELAY
- POSITION SWITCH
- MASTER SEQUENCE DEVICE
- BRUSH-OPERATING OR SLIP-RING SHORT-CIRCUITING DEVICE
- POLARITY OR POLARIZING VOLTAGE DEVICE
- UNDERCURRENT OR UNDERPOWER RELAY
- BEARING PROTECTIVE DEVICE
- MECHANICAL CONDITION MONITOR
- ANNUNCIATOR RELAY
- FIELD RELAY
- FIELD CIRCUIT BREAKER
- RUNNING CIRCUIT BREAKER
- MANUAL TRANSFER OR SELECTOR DEVICE
- UNIT SEQUENCE STARTING RELAY
- ATMOSPHERIC CONDITION MONITOR
- REVERSE-PHASE OR PHASE-BALANCE CURRENT RELAY
- PHASE-SEQUENCE VOLTAGE RELAY
- INCOMPLETE SEQUENCE RELAY
- MACHINE OR TRANSFORMER THERMAL RELAY
- INSTANTANEOUS OVERCURRENT OR RATE-OF-RISE RELAY
- AC TIME OVERCURRENT RELAY
- AC CIRCUIT BREAKER
- BREAKER AUXILIARY SWITCH, OPEN WHEN THE BREAKER IS OPEN
- BREAKER AUXILIARY SWITCH, CLOSED WHEN THE BREAKER IS OPEN
- EXCITER OR DC GENERATOR RELAY
- RESERVED FOR FUTURE APPLICATION
- POWER FACTOR RELAY
- FIELD APPLICATION RELAY
- SHORT-CIRCUITING OR GROUNDING DEVICE
- RECTIFICATION FAILURE RELAY
- OVERVOLTAGE RELAY
- VOLTAGE OR CURRENT BALANCE RELAY
- RESERVED FOR FUTURE APPLICATION
- TIME-DELAY STOPPING OR OPENING RELAY
- PRESSURE SWITCH
- GROUND DETECTOR RELAY
- GOVERNOR
- NOTCHING OR JOGGING DEVICE
- AC DIRECTIONAL OVERCURRENT RELAY
- LOCKING RELAY
- PERMISSIVE CONTROL DEVICE
- RHEOSTAT
- LEVEL SWITCH
- DC CIRCUIT BREAKER
- LOAD-RESISTOR CONTACTOR
- ALARM RELAY
- POSITION CHANGING MECHANISM
- DC OVERCURRENT RELAY
- PULSE TRANSMITTER
- PHASE-ANGLE MEASURING OR OUT-OF-STEP PROTECTIVE RELAY
- AC RECLOSING RELAY
- FLOW SWITCH
- FREQUENCY RELAY
- DC RECLOSING RELAY
- AUTOMATIC SELECTIVE CONTROL OR TRANSFER RELAY
- OPERATING MECHANISM
- CARRIER OR PILOT-WIRE RECEIVER RELAY
- LOCKOUT RELAY
- DIFFERENTIAL PROTECTIVE RELAY
- AUXILIARY MOTOR OR MOTOR GENERATOR
- LINE SWITCH
- REGULATING DEVICE
- VOLTAGE DIRECTIONAL RELAY
- VOLTAGE AND POWER DIRECTIONAL RELAY
- FIELD-CHANGING CONTACTOR
- TRIPPING OR TRIP-FREE RELAY



NOTES:  
1. FOR DETAILED DESCRIPTION OF DEVICE AND SUFFIX LETTERS TO BE USED WITH FUNCTION NUMBERS, SEE ANSI/IEEE C37.2.  
2. UNLESS NOTED OTHERWISE, 1-LINE DIAGRAMS INDICATE ONLY BREAKER TRIP RATINGS. FOR BREAKER FRAME SIZES, SEE SWITCHGEAR FRONT ARRANGEMENT DRAWINGS. WHERE BOTH FRAME SIZE AND TRIP RATING ARE SHOWN ON 1-LINE DIAGRAMS, THEY ARE INDICATED AS (e.g. 600AF, 500AT)

LEGEND - LAYOUT DRAWINGS

NOT ALL SYMBOLS MAY APPEAR ON DRAWINGS. SOME SYMBOLS MAY ALSO APPEAR ON SINGLE LINE AND SCHEMATIC DRAWINGS

SYMBOL	DESCRIPTION	SYMBOL	DESCRIPTION
	LUMINAIRE		TELEPHONE OUTLET
	SUSPENDED LUMINAIRE		DATA OUTLET
	CEILING MOUNTED LUMINAIRE		COMBINATION DATA/TEL OUTLET C/W 2 DATA & 1 TEL UNLESS OTHERWISE INDICATED
	WALL MOUNTED LUMINAIRE		INTERCOM
	LUMINAIRE ON EMERGENCY/24hr CIRCUIT		MICROPHONE OUTLET
	BOLLARD/POST TOP LUMINAIRE		CEILING MOUNTED HORN
	POLE MOUNTED LUMINAIRE		WALL MOUNTED HORN
	DIRECTIONAL LUMINAIRE		DUAL COMPARTMENT RACEWAY C/W OUTLETS AS INDICATED
	SINGLE POLE TOGGLE SWITCH, GANGED AS SHOWN. LETTERS, WHERE SHOWN, DENOTE SWITCHING		CEILING MOUNTED FIRE ALARM PAGING SPEAKER
	2 - TWO POLE 3 - THREE WAY 4 - FOUR WAY		WALL MOUNTED FIRE ALARM PAGING SPEAKER
	WP - WEATHER PROOF		CLOCK C/W MASTER CLOCK WIRING AND 120V RECEPTACLE
	XP - EXPLOSION PROOF		SURFACE MOUNTED COMMUNICATIONS PANEL
	P - C/W PILOT LIGHT		RECESSED/FLUSH MOUNTED COMMUNICATIONS PANEL
	K - KEY OPERATED		RECEPTACLES AND OUTLETS:
	D - DOOR OPERATED		DUPLEX RECEPTACLE
	M - MOTOR STARTER		5-20R (15/20A) DUPLEX RECEPTACLE
	MC - MOMENTARY CONTACT, 3-POSITION		4-PLEX RECEPTACLE
	LOW VOLTAGE SWITCH		SINGLE RECEPTACLE
	DIMMER SWITCH		GROUND FAULT INTERRUPTER RECEPTACLE
	3 WAY DIMMER SWITCH		CEILING MOUNTED JUNCTION BOX
	PHOTO ELECTRIC CELL		WALL MOUNTED JUNCTION BOX
	EMERGENCY LIGHTING:		MECHANICAL EQUIPMENT CONNECTION
	EXIT SIGN C/W ARROWS AS SHOWN		SPECIAL PURPOSE RECEPTACLE
	EMERGENCY LIGHT BATTERY UNIT, WATTAGE AS SHOWN		SPECIAL PURPOSE OUTLET
	REMOTE EMERGENCY HEADS		MOTORIZED DAMPER
	GROUNDING:		FIRE ALARM:
	GROUND ROD		FIRE ALARM PULL STATION
	GROUND ROD IN ACCESSIBLE BOX		FIRE ALARM BELL
	END-TO-END GROUND CONNECTION POINT		FIRE ALARM STROBE
	X-CONNECTION (GROUNDING)		COMBINATION HEAT/SMOKE DETECTOR
	T-CONNECTION (GROUNDING)		FIRE ALARM ZONE ISOLATION MODULE
	GROUNDING PLATE (CAST FLUSH IN CONCRETE)		SITE PLAN:
	WELDED OR EXOTHERMIC END CONNECTION (GROUNDING)		EQUIPMENT CONNECTION AS NOTED ON DRAWING
	GROUNDING END CONNECTION WITH CABLE LUG, CLAMP CONNECTOR OR OTHER MECHANICAL CONNECTOR BOLTED TO EQUIPMENT		HIGH VOLTAGE UNDERGROUND CHAMBER OR BOX
	MOTOR STARTER		LOW VOLTAGE UNDERGROUND CHAMBER OR BOX
	MAGNETIC MOTOR STARTER		COMMUNICATIONS UNDERGROUND CHAMBER OR BOX
	NON-FUSED DISCONNECT SWITCH		RIGID STEEL CONDUIT
	FUSED DISCONNECT SWITCH		
	COMBINATION MAGNETIC STARTER/DISCONNECT SWITCH		
	INDOOR SERVICE POLE		
	MOTOR CONNECTION		
	SURFACE MOUNTED POWER PANEL		
	RECESSED/FLUSH MOUNTED POWER PANEL		
	PANEL DESIGNATION		
	DISTRIBUTION PANEL DESIGNATION		
	SECURITY:		
	MOTION SENSOR		
	CLOSE CIRCUIT TELEVISION CAMERA		
	DOOR CONTACT		
	ELECTRIC STRIKE		
	CARD READER		
	REQUEST-TO-EXIT SENSOR		

Revision/Revisión	Description/Descripción	Date/Date
5	ISSUED FOR TENDER	15/01/28
4	ISSUED FOR 90% DESIGN REVIEW	16/01/06
3	ISSUED FOR 60% DESIGN REVIEW	15/11/25
2	ISSUED FOR 33% DESIGN REVIEW	15/10/28
1	ISSUED FOR DESIGN DEVELOPMENT	15/09/11
0		

Client/client

**ESQUIMALT GRAVING DOCK**

825 ADMIRALS ROAD  
VICTORIA, BC, V9A 2P1

Project title/Titre du projet  
**825 ADMIRALS ROAD VICTORIA BC  
ESQUIMALT GRAVING DOCK  
ELECTRICAL SAFETY UPGRADE**

**SOUTH SUBSTATION  
SWITCHGEAR  
REPLACEMENT  
(SSSR)**

Consultant Signature Box Only

Designed by/Concept par  
**I. BARNES**

Drawn by/Dessiné par  
**J. BIELING / S. SEYMOUR**


PWGSC Project Manager/Administrateur de Projets TPSGC  
**Jamie LeBlanc**

PWGSC, Regional Manager, Architectural and Engineering Services/  
Gestionnaire régionale, Services d'architecture et de génie, TPSGC  
**Preetpal Paul**

Drawing title/Titre du dessin

ELECTRICAL SYMBOL LEGEND

Project No./No. du projet	Sheet/Feuille	Revision no./no. de révisión
R.062548.2	5001	5



### ABBREVIATIONS

NOT ALL ABBREVIATIONS MAY APPEAR ON DRAWINGS

AIR CIRCUIT BREAKER	ACB	HAND HARDWARE	*H	RECEPTACLE RELAY	(RCPT), *REC (RLY), *R
AIR NATURAL/AIR FORCED TRANSFORMER COOLING ALARM	ANANANAF ALM	HARMONIC FILTER BANK	*HFB	REMOTE	(RMT), *REM
ALTERNATING CURRENT APPROXIMATELY	AC APPROX	HIGH VOLTAGE HORIZONTAL	*HV *HORZ	REMOTE INPUT DEVICE REVERSE	RID (*R), *REV
ARRESTER	ARSR	INCANDESCENT INCREASE INDICATOR, INDICATING	INCAND INCR *INDT	RIGID POLYVINYL CHLORIDE RIGID STEEL CONDUIT ROOM	RPVC RSC RM
AUTOMATIC AUXILIARY	(*A), AUTO *AUX	INDUCTION (MOTOR) INFORMATION INTERLOCK	*IND INFO INTLK	SCHEMATIC SECONDARY SERVICE ENTRANCE SUBSTATION	SCHEM SEC SES
BOILER BRAKE	BLR BK	KEY INTERLOCK	K	SELECTOR SHEET SOFT START	SEL SH *SS
BREAKER BC HYDRO BY-PASS	(*BKR) BRKR BCH BYP	LIGHT LIGHTING LIMIT SWITCH	LT LTG ZS	SOLENOID VALVE SOUTH SIDE SUBSTATION (EXISTING) SOUTH SIDE SUBSTATION REPLACEMENT (FUTURE)	*EV SS SSR
CABINET CABLE LIST CAPACITOR	CAB *CL CAP	LOCAL LOCK-OUT ATTACHMENT LOW VOLTAGE	(LCL), *LOC *LIO *LV	SPECIFICATION SPEED SWITCH STANDARD START STARTER	SPEC *SPS *STD (*S), *ST *STR
CIRCUIT CIRCUIT BREAKER CLOSED CIRCUIT TELEVISION	(*CCT), CKT CB CCTV	MAIN SUBSTATION MANHOLE MANUAL MANUFACTURER	MS MH *MAN MFR	STOP SUPPLIED WITH EQUIPMENT SWITCH	(*SP), *STOP *SWE SW
COMMUNICATION(S) COMPLETE WITH CONSOLE	COMM *CW (*CNLS), CSL	MATERIAL MAXIMUM MEDIUM MINIMUM	MATL MAX MED MIN	SWITCHBOARD SWITCHGEAR SYNCHRONOUS/SYNCHRONIZING	SWBD SWGR *SYNCH
CONTACTOR CONTROL CURRENT TRANSFORMER	*C (*CTL), CONT CT	MISCELLANEOUS MOTOR MOTOR CONTROL CENTRE	MISC (*M), MOT *MCC	TEST SWITCH TEMPERATURE TEMERINAL BLOCK TEST TERMINAL	TSW TEMP *TB (*TT), *TST
DECREASE DIAMETER DIGITAL METERING SYSTEM	DECR DIA *DMS	MOTOR FIELD RHEOSTAT MOUNTED MOUNTING MUNROE HEAD	*MFR MTD MTG MH	THERMOSTAT TRANSFORMER TRANSMITTER TYPICAL	(*T), *STAT XFMR XMTR TYP
DIRECT CURRENT DIRECT DIGITAL CONTROL DISCONNECT	DC DDC DISC	NETWORK NEUTRAL GROUND RESISTOR NORTH SUBSTATION (FUTURE) NORTH LANDING WHARF SUBSTATION (EXISTING) NOT APPLICABLE	NET NGR NS NLWS *NA	UP VERTICAL	(*U), UP VERT
DRAWING EACH EARTHING SWITCH	DWG *EA ES	OFF OIL CIRCUIT BREAKER ON ORIGINAL EQUIPMENT MANUFACTURER OVERLOAD	*O OCB *OEM *OIL	WEATHERPROOF WINDING WORKERS' COMPENSATION BOARD	*WP WDG WCB
ELECTRICAL EQUIPMENT LIST ELECTRICAL MASTER DRAWING(S) ELECTRICAL STANDARD DRAWING(S)	*EEL *EMD *ESD	PADMOUNT PANEL PHASE PHOTOELECTRIC CONTROL PILOT LIGHT/PILOT LAMP POINT OF COMMON COUPLING POLARITY	*PDMT PNL (*P), PH *PEC (PL), *PIL *PCC PLRT	ZERO SEQUENCE CT COLOURS BLACK BLUE BROWN GREY GREEN ORANGE RED YELLOW WHITE SLATE	*ZSCT BLK BLU BRN *GRY (*G), GRN (*OR), ORN (*R), RED (*Y), YEL (*W), WHT SLT
ELECTRICALLY OPERATED VALVE (e.g. SOLENOID VALVE) EMERGENCY ENGINE STARTER EXCITER	EV *EM *EST EXC	POTENTIAL TRANSFORMER POWER POWER FACTOR CORRECTION CONTROLLER PRESSURE SWITCH PRIMARY PROGRAMMABLE LOGIC CONTROLLER PUMPHOUSE PUMPHOUSE SUBSTATION PUSH BUTTON PURPLE	PT *PWR *PFCC *PS PRI PLC PH PHS PB PPL		
EXISTING FEEDER FIELD FIRE ALARM	EXST FDR FLD *FA	FLOAT SWITCH FLOW SWITCH FLUORESCENT	*FLS *FS *FL		
FOOT CANDLE FORWARD FULL LOAD AMPS FUSE	(*FC), *Fc (*FOR), FWD *FLA FU	FUSED SWITCH GALVANIZED GAS INSULATED SWITCH GENERATOR GROUND	FS GALV GIS (*G), GEN GRD		
GROUND FAULT MONITORING SYSTEM	*GFM				

### NOTES:

- UNLESS OTHERWISE NOTED, ABBREVIATIONS ARE IN ACCORDANCE WITH CSA Z85-1983
- ABBREVIATIONS IN BRACKETS ARE ALTERNATE CHOICES.
- ASTERISK (\*) INDICATES ABBREVIATIONS NOT COVERED BY OR CONTRARY TO CSA Z85-1983.
- SINGLE LETTER ALTERNATE CHOICES ARE PRIMARILY MEANT FOR USE ON SINGLE LINE, SCHEMATIC AND WIRING DIAGRAMS AS PART OF THE DEVICE SYMBOL.

5	ISSUED FOR TENDER	15/01/28
4	ISSUED FOR 99% DESIGN REVIEW	16/01/06
3	ISSUED FOR 66% DESIGN REVIEW	15/11/25
2	ISSUED FOR 33% DESIGN REVIEW	15/10/28
1	ISSUED FOR DESIGN DEVELOPMENT	15/09/11
0		

Revision/Revisión	Description/Description	Date/Date
-------------------	-------------------------	-----------

Client/client

### ESQUIMALT GRAVING DOCK

825 ADMIRALS ROAD VICTORIA, BC, V9A 2P1

Project title/Titre du projet  
825 ADMIRALS ROAD VICTORIA BC  
ESQUIMALT GRAVING DOCK  
ELECTRICAL SAFETY UPGRADE

### SOUTH SUBSTATION SWITCHGEAR REPLACEMENT (SSSR)

Consultant Signature Box Only

Designed by/Concept par

I. BARNES

Drawn by/Dessiné par

J. BIELING / S. SEYMOUR

PWGSC Project Manager/Administrateur de Projets TPSGC

Jamie LeBlanc

PWGSC Regional Manager, Architectural and Engineering Services/ Gestionnaire régionale, Services d'architecture et de génie, TPSGC


Preetipal Paul

Drawing title/Titre du dessin

### ELECTRICAL ABBREVIATIONS

Project No./No. du projet	Sheet/Feuille	Revision no./La Révision no.
R.062548.2	5002	5





EMD DRAWING CROSS-REFERENCE	
EMD	CONTRACT DRAWING SHEET
E2	5900
E3	5901
E4	5902
E5	5903
E6	5905



- NOTES (POWER SYSTEM COMPONENTS NUMBERING CONVENTION):
- IN GENERAL, POWER SYSTEM COMPONENTS ARE NUMBERED IN A WAY TO FACILITATE IDENTIFYING THE POWER SOURCE WHICH SUPPLIES THEM, STARTING WITH VOLTAGE, AND FOLLOWED BY ONE OR MORE LOCATION, FUNCTION, OR ALPHANUMERIC DESIGNATORS AS FOLLOWS:
    - VOLTAGE DESIGNATORS: 12.5-12.500 V; 6.347/600 V; 4.277/480V; 2.120/208V
    - LOCATION DESIGNATORS: MS: MAIN SUBSTATION; NL: NORTH LANDING WHARF; PH: PUMPHOUSE; SC: SOUTH COMPRESSOR ROOM; SS: SOUTHSIDE SUBSTATION; MH - MUNROE HEAD
  - FUNCTIONAL DESIGNATORS: DS: DISCONNECT SWITCH (NOT PART OF A SWITCHBOARD OR MCC); FS: FUSED DISCONNECT SWITCH (SIMILAR TO DS); MCC: MOTOR CONTROL CENTER; HFB: HARMONIC FILTER BANK; S: STANDBY POWER SYSTEM; SS: SOFT START.
  - IN GENERAL, SWITCHBOARDS ARE NUMBERED WITH A VOLTAGE DESIGNATOR, FOLLOWED BY A LOCATION DESIGNATOR.
    - WHERE THERE IS MORE THAN ONE SWITCHBOARD OF THE SAME VOLTAGE IN THE SAME AREA, THEY ARE DIFFERENTIATED BY CONSECUTIVE NUMERIC DESIGNATORS, SUCH AS 4S1 AND 4S2.
    - SWITCHBOARD SECTIONS ARE NUMBERED IN CONSECUTIVE ORDER WITH INCOMING SECTION BEING SECTION #1.
  - MOTOR CONTROL CENTERS ARE NUMBERED SIMILAR TO SWITCHBOARDS, FOLLOWED BY "MCC".
  - IN GENERAL, PANELBOARDS ARE NUMBERED WITH A VOLTAGE DESIGNATOR, FOLLOWED BY A CONSECUTIVE ALPHABETICAL DESIGNATOR (e.g. 2A, 2B, ETC.). ALPHABETICAL DESIGNATOR "S" IS NOT USED IN ORDER TO AVOID CONFUSION WITH STANDBY PANELS AS DESCRIBED BELOW.
    - SUB-PANELS ARE NAMED AFTER THE PARENT PANELBOARD, FOLLOWED BY A SECOND ALPHABETICAL DESIGNATOR STARTING WITH "A" AND CONTINUING CONSECUTIVELY FOR EACH SUB-PANEL (e.g. SUB-PANEL 2VA IS FED FROM PANEL 2V).
    - FOR STANDBY SYSTEM PANELBOARDS, THE ALPHABETICAL DESIGNATOR IS "S", FOLLOWED BY A SECOND ALPHABETICAL DESIGNATOR STARTING WITH "A" AND CONTINUING CONSECUTIVELY. EXCEPTIONS EXIST FOR THE FOLLOWING STANDBY PANELBOARDS: PANEL "6SP1" IS CURRENTLY LABELED WITH AN ENGRAVED NAMEPLATE PER EXISTING DRAWINGS, AND THE ADJOINING PANEL IS DESIGNATED "6SP2" TO MAINTAIN SIMILARITY.
  - BREAKERS ARE NUMBERED AS FOLLOWS:
    - IN GENERAL, BREAKERS ARE NUMBERED TO MATCH THE ORIGINAL SWITCHBOARD MANUFACTURER'S DESIGNATION (e.g. BREAKER 4S1-2 IS NAMED AFTER 52-2).
    - IN LARGE SWITCHBOARDS, EACH SWITCHBOARD SECTION IS ASSIGNED A BLOCK OF BREAKER NUMBERS, BASED ON THE BEST ESTIMATE OF POSSIBLE NUMBER OF BREAKERS WHICH MIGHT BE INSTALLED IN THAT SECTION.
    - IN PANELBOARDS, EACH BREAKER IS NUMBERED AFTER THE CIRCUIT NUMBER. FOR 2- OR 3-POLE BREAKERS, THE LOWER CIRCUIT NUMBER DETERMINES THE BREAKER NUMBER (e.g. BREAKER NUMBER FOR CIRCUIT 26/28/30 IN PANEL 2SK IS "2SK-26").
  - FIELD-MOUNTED DISCONNECT SWITCHES ARE NUMBERED AFTER THE EQUIPMENT WHICH POWERS THEM, BUT WITH SUFFIX "DS" (e.g. 4MS-19DS).
  - FIELD-MOUNTED FUSED DISCONNECT SWITCHES ARE NUMBERED SIMILAR TO DISCONNECT SWITCHES, BUT WITH SUFFIX "FS" (e.g. 6SA-20FS). STAND ALONE FUSES ARE DESIGNATED SIMILARLY, BUT WITH SUFFIX "FU".
  - FIELD-MOUNTED BREAKERS ARE NUMBERED SIMILAR TO DISCONNECT SWITCHES, BUT WITH SUFFIX "BKR" (e.g. 6SA-13BKR).
  - TRANSFORMERS ARE NUMBERED AFTER THE EQUIPMENT WHICH POWERS THEM, BUT WITH A "T" PREFIX (e.g. T12.5MS-2). SOME OF THE EXISTING TRANSFORMERS ARE NUMBERED ACCORDING TO SEVERAL DIFFERENT CONVENTIONS. THE TRANSFORMER TABLE ON THIS DRAWING INCLUDES A COLUMN SHOWING THE OBSOLETE DESIGNATIONS FOR REFERENCE.
    - TRANSFORMER NEUTRAL GROUNDING RESISTORS ARE NAMED AFTER THE TRANSFORMER, BUT WITH SUFFIX "NGR".
  - IN GENERAL, POWER CABLES ARE LABELLED AFTER THE EQUIPMENT TO WHICH THEY ARE CONNECTED AT THEIR SOURCE END (e.g. CABLE 6SP1-2 IS CONNECTED TO BREAKER 2 IN PANEL 6SP1; CABLE 2PH2-7 IS CONNECTED TO 3 POLE BREAKER OCCUPYING CIRCUIT POSITIONS 7/9/11 IN PANEL 2PH2).
    - PARALLEL CABLES ARE DESIGNATED WITH SUFFIX -1, -2, ETC.
    - CABLES CONNECTED IN SERIES IN SAME CIRCUIT ARE DESIGNATED WITH SUFFIX -A, -B, ETC. (e.g. "A" CABLE FROM PANELBOARD TO A FIELD JUNCTION BOX, "B" CABLE, SUCH AS A FLEXIBLE CABLE, FROM JUNCTION BOX TO MOTOR).
    - EXCEPT WHERE INDICATED OTHERWISE, TRANSFORMER SECONDARY CABLES ARE LABELLED STARTING WITH SECONDARY VOLTAGE DESIGNATOR, FOLLOWED BY THE TRANSFORMER DESIGNATION (e.g. 2 T6SA-1).
    - IN ORDER TO MAKE CABLE NUMBERING SYSTEM WORK, DO NOT CHANGE BREAKER NUMBERS ARBITRARILY. DO NOT RE-USE OLD NUMBERS OF DELETED BREAKERS. ASSIGN NEW BREAKER NUMBERS WHICH HAVE NOT PREVIOUSLY BEEN USED.
  - WHEN USING CONSECUTIVE ALPHABETICAL DESIGNATORS (e.g. 2A, 2B, ETC.) DO NOT USE "O" OR "I" TO AVOID CONFUSION WITH "ZERO" AND "ONE".

ELECTRICAL EQUIPMENT TABLE					
EQUIPMENT GROUP	EQUIPMENT DESIGNATION	EQUIPMENT NAME/LOCATION	DRAWING	COMMENTS	
25/12.5KV SWITCHBOARD	25/12SES	SERVICE ENTRANCE SUBSTATION	2000	Refers to SES project for electrical details for noted drawings.	
	25/12PHS	PUMPHOUSE SUBSTATION	3000	Refers to SES project for electrical details for noted drawings.	
	25/12SSSR	SOUTH SUBSTATION REPLACEMENT	5010	Refers to SSSR project for electrical details for noted drawings.	
12.5KV SWITCHBOARD	12.5MS	MAIN 12.5 KV SWITCHBOARD	EMD E2		
	12.5SS	SOUTHSIDE UNIT-SUBSTATION H.V. SECTION	EMD E5		
	12.5NL	NORTH LANDING WHARF UNIT-SUBSTATION H.V. SECTION	EMD E4		
	2.4MS	MAIN SUBSTATION	EMD E2		
2.4KV SWITCHBOARD	2.4PH	PUMPHOUSE	EMD E3		
	2.4PHS	PUMPHOUSE SUBSTATION	3000	Refers to SSSR project for electrical details for noted drawings.	
	2.4SS	SOUTHSIDE SUBSTATION	EMD E5		
	2.4SC	SOUTH COMPRESSOR ROOM	EMD E5		
	2.4KV	SOUTH SUBSTATION REPLACEMENT	5010	Refers to SES project for electrical details for noted drawings.	
347/600V SWITCHBOARDS	6MS	MAIN SUBSTATION	EMD E2		
	6PH	PUMPHOUSE	EMD E3		
	6SC	SOUTH COMPRESSOR ROOM	EMD E5		
	6SES-1	SERVICE ENTRANCE SUBSTATION	2002	Refers to SES project for electrical details for noted drawings.	
	6PHS-1	PUMPHOUSE SUBSTATION	3002	Refers to SES project for electrical details for noted drawings.	
347/600V PANELBOARDS	6SSSR-1	SOUTH SUBSTATION REPLACEMENT	5011	Refers to SSSR project for electrical details for noted drawings.	
	6A	BIO BLAST BUILDING	EMD E2		
	6PHS-B	PUMPHOUSE MACHINE SHOP	3002	Was 6B. Refers to SES project for electrical details for noted drawings.	
	6C	KEEL BLOCK	EMD E2	(Was at Carpenters Shop)	
	6D	PARKING LOT 'A' KIOSK	9012	Refers to SES project for electrical details for noted drawings.	
	6Z	PENINSULA WASTE WATER SERVICES	EMD E2		
277/480V SWITCHBOARDS	6PHS-2	PUMPHOUSE SUBSTATION	3002	Refers to SES project for electrical details for noted drawings.	
	4MS	MAIN SUBSTATION	EMD E2		
	4S1	SOUTHSIDE UNIT-SUBSTATION L.V. SECTION	EMD E5		
	4S2	SOUTHSIDE SUBSTATION	EMD E5		
480V HARMONIC FILTER BANKS	4NL	NORTH LANDING WHARF UNIT-SUBSTATION L.V. SECTION	EMD E4		
	4SSSR-1	SOUTH SUBSTATION REPLACEMENT	5011	Refers to SSSR project for electrical details for noted drawings.	
	4SSSR-2	SOUTH SUBSTATION REPLACEMENT	5011	Refers to SSSR project for electrical details for noted drawings.	
	4MS-HFB	MAIN SUBSTATION HARMONIC FILTER ABNK	EMD E2		
	4S1-HFB	SOUTHSIDE SUBSTATION HARMONIC FILTER BANK	EMD E5		
480V PANELBOARDS	4SSSR-HFB	SOUTHSIDE SUBSTATION REPLACEMENT HARMONIC FILTER BANK	XXX	Refers to SSSR project for electrical details for noted drawings.	
	4NL-HFB	NORTH LANDING WHARF HARMONIC FILTER BANK	EMD E4		
	4A	ELECTRICAL SHOP	EMD E2	(was Bio Blast Building)	
	4B	K BUILDING	EMD E5		
120/208V SWITCHBOARDS	4C	BUTLER BUILDING	EMD E5		
	2MS	MAIN SUBSTATION 120/208V SWITCHBOARD	EMD E2		
	2PH	PUMPHOUSE 120/208V SWITCHBOARD	EMD E3		
	2NL1	NORTH LANDING WHARF 120/208V SWITCHBOARD	EMD E4		
	2NL2	NORTH LANDING WHARF 120/208V DISTRIBUTION PANEL	EMD E4		
347/600V STANDBY PANELS	2S1	SOUTHSIDE UNIT-SUBSTATION L.V. SECTION	EMD E5		
	2S2	SOUTHSIDE SUBSTATION 120/208V SWITCHBOARD	EMD E5		
	2SSSR	SOUTHSIDE SUBSTATION REPLACEMENT	5010	Refers to SES project for electrical details for noted drawings.	
	2A	ELECTRICAL SHOP	EMD E2	(was Bio Blast Building)	
	2B	PWGS OFFICE BUILDING	EMD E2	Obtain as-built panel schedule	
	2C	WASHROOM BUILDING	EMD E2		
	2E	BC FERRIES TRAILER MINI POWER CENTER	9012	Refers to SES project for electrical details for noted drawings.	
	2F	UPPER PARKING ELECTRICAL SHED	EMD E3		
	2FA	UPPER PARKING TRAILER	EMD E3		
	2G	GARAGE	EMD E3		
480V STANDBY PANELS	2H	PARKING LOT 'A' WASHROOM MINI POWER CENTER	9012	Refers to SES project for electrical details for noted drawings.	
	2PHS-A	PUMPHOUSE SUBSTATION	3002	Refers to SES project for electrical details for noted drawings.	
	2PHS-C	PUMPHOUSE 120/208V POWER PANEL	3002	Refers to SES project for electrical details for noted drawings.	
	2PHS-A-B	PUMPHOUSE MACHINE SHOP	3002	FORMERLY 2K	
	2PHS-A-H	PUMPHOUSE HEATING PANEL	3002	Refers to SES project for electrical details for noted drawings.	
	2J	PARKING LOT 'A' KIOSK SERVICE PANEL	9012	Refers to SES project for electrical details for noted drawings.	
	2M	BACK GATE GUARD HOUSE	EMD E4		
	2N	NORTH LANDING WHARF SUBSTATION	EMD E4		
	2O	KEEL BLOCK BUILDING	EMD E2	naming contrary to note 11	
	2OA	KEEL BLOCK BUILDING	EMD E2	naming contrary to note 4 and 4.1	
	2P	CARPENTER SHOP IN KEEL BUILDING	EMD E2		
	2Q	PROJECTS OFFICE LOWER TRAILER	?		
	2R	PROJECTS OFFICE UPPER TRAILER	?		
	---	NOTE 4.2			
	480V STANDBY PANELS	2T	COMPRESSOR No.4 ROOM	EMD E5	
2U		K BUILDING	EMD E5		
2V		BUTLER BUILDING	EMD E5		
2VA		BUTLER BUILDING	EMD E5		
6PHS-SP-A		PUMPHOUSE	3002	FORMERLY PANEL 6SA	
6SB		SOUTHSIDE SUBSTATION	EMD E6		
6SC		SOUTHSIDE GENERATOR G2 CONTROL PANEL	EMD E6		
6SD		SOUTHSIDE GENERATOR G2 ATS PANEL	EMD E6		
6SH		HIGH MAST LIGHTING PANEL	EMD E6		
6SP1		NORTHSIDE GENERATOR G1 ATS & STANDBY POWER DISTRIBUTION PANEL No.1	EMD E6		
6SP2		NORTHSIDE GENERATOR G1 STANDBY POWER DISTRIBUTION PANEL No.2	EMD E6		
6SES-SP-1		SERVICE ENTRANCE SUBSTATION	2002	Refers to SES project for electrical details for noted drawings.	
6PHS-SP-1		PUMPHOUSE SUBSTATION	3002	Refers to SES project for electrical details for noted drawings.	
6SSSR-SP-1		SOUTH SUBSTATION REPLACEMENT 347/600V PANEL	5011	Refers to SSSR project for electrical details for noted drawings.	
120/208V STANDBY PANELS		4SA	SOUTHSIDE SUBSTATION	EMD E6	
	4SSSR-SP-1	SOUTH SUBSTATION REPLACEMENT	5011	Refers to SSSR project for electrical details for noted drawings.	
	2SA	MAIN SUBSTATION	EMD E6		
	2SB	PUMPHOUSE	EMD E6		
	2SD	NORTH GENERATOR ROOM	EMD E6		
	2SE	NLW SUBSTATION 120/208V STANDBY PANEL	EMD E6		
	2SK	DEMARC BUILDING PANEL	2002	Was 2J. Refers to SES project for electrical details for noted drawings.	
	2SK	SOUTHSIDE SUBSTATION	EMD E6	Was 2S	
	2SL	SOUTH GENERATOR BUILDING	EMD E6		
	2SM	SOUTH MACHINE SHOP	EMD E6		
	2SN	SOUTH FIRST AID OFFICE	EMD E6		
	2SP	PUMPHOUSE BOTTOM FLOOR STANDBY POWER		Was 2L	
	2SQ	PUMPHOUSE 2nd FLOOR PANEL	EMD E6	Was 2M	
	2SR	NEW GUARD HOUSE PANEL	2002	Refers to SES project for electrical details for noted drawings.	
	2SS	COMMISSIONAIRES KIOSK PANEL	2002	Refers to SES project for electrical details for noted drawings.	
DISCONNECT SWITCHES	2ST	UPPER WALL PANEL	2002	Refers to SES project for electrical details for noted drawings.	
	2SES-SP-1	SERVICE ENTRANCE SUBSTATION 120/208V PANEL	2002	Refers to SES project for electrical details for noted drawings.	
	2PHS-SP-A	PUMPHOUSE SUBSTATION 120/208V PANEL	3002	Refers to SES project for electrical details for noted drawings.	
	2SSSR-SP-1	SOUTHSIDE SUBSTATION REPLACEMENT 120/208V PANL	5011	Refers to SSSR project for electrical details for noted drawings.	
	4MS-19DS	DOCK OUTLET #3 - EAST DS	EMD E2	Shown as sample only.	
FUSED DISCONNECT SWITCHES	T12.5MS-2DS	SHIP-SHORE TRANSFORMER SECONDARY DISCONNECT SWITCH	EMD E2	Integral with grounding switch T12.5MS-2GS	
	6SA-20FS	MAIN Gate GUARDHOUSE TRANSFORMER PRIMARY FU. SW.	EMD E6	Shown as sample only. See 1-Line diagrams for switches that are named	
MOTOR CONTROL CENTERS	4PH-MCC	CAPSTAN MCC	3002	Refers to SES project for electrical details for noted drawings.	
	2.4PHS-MCC1	PUMPHOUSE SUBSTATION	3000	Refers to SES project for electrical details for noted drawings.	
	2.4PHS-MCC2	PUMPHOUSE SUBSTATION	3000	Refers to SES project for electrical details for noted drawings.	
CRANE SWITCHBOARDS				Refer to manufacturers' drawings for equipment numbering conventions.	
UPS	2SES-UPS	SERVICE ENTRANCE SUBSTATION UPS	2002	Refers to SES project for electrical details for noted drawings.	
	2PHS-UPS	PUMPHOUSE SUBSTATION UPS	3002	Refers to SES project for electrical details for noted drawings.	
	2SSSR-UPS	SOUTHSIDE SUBSTATION REPLACEMENT UPS	5110	Refers to SSSR project for electrical details for noted drawings.	
	2.4PH-SS	COMPRESSOR #1 MOTOR SOFT START/PUMPHOUSE	EMD E3	Refer to manufacturer's drawings and manuals for details	
	2.4PHS-MCC1	PUMPHOUSE SUBSTATION MCC1	3000	Refers to SES project for electrical details for noted drawings.	
2.4KV MOTOR STARTER	2.4PHS-MCC2	PUMPHOUSE SUBSTATION MCC2	3000	Refers to SES project for electrical details for noted drawings.	

TRANSFORMER TABLE										
DESIGNATION	OBSOLETE NO.	SIZE	VOLTAGE	TYPE	INSULATION CLASS	IMPEDANCE	SERIAL #	MANUFACTURER	DRAWING NO.	COMMENTS/LOCATION
T25/12SSSR-1	-	-	25/12.5kV-2.4kV, 3Ø, DELTA/WYE	ANAF						5010 SOUTH SIDE SUBSTATION REPLACEMENT
T25/12SSSR-2	-	-	25/12.5kV-347/600V, 3Ø, DELTA/WYE	ANAF						5010 SOUTH SIDE SUBSTATION REPLACEMENT
T25/12SSSR-3	-	-	25/12.5kV-480V, 3Ø, DELTA/WYE	ANAF						5010 SOUTH SIDE SUBSTATION REPLACEMENT
T25/12SSSR-4	-	-	25/12.5kV-120/208V, 3Ø, DELTA/WYE	ANAF						5010 SOUTH SIDE SUBSTATION REPLACEMENT
T25/12SSSR-5	-	-	25/12.5kV-550V REGULATED	ANAF						5010 SOUTH SIDE SUBSTATION REPLACEMENT
T25/12SES-1		750KVA	25/12.5kV-600V, 3Ø, DELTA/WYE	ANN		5.0%				2000 SERVICE ENTRANCE SUBSTATION
T25/12PHS-1		5MVA	25/12.5kV-1386/2400V, 3Ø, DELTA/WYE	ANN		6.5%				3000 PUMPHOUSE SUBSTATION
T25/12PHS-2		750KVA	25/12.5kV-600V, 3Ø, DELTA/WYE	ANN		5.0%				3000 PUMPHOUSE SUBSTATION
T12.5MS-2		5MVA	12.47-12.47/11.6kV							EMD E2
T12.5MS-4	T04	5MVA	12.5kV/2.3kV, 3Ø, Delta/Wye	ONAN		6.37%	57843.01	F.P.E.	EMD E2	MS Transformer Yard
T12.5MS-6	T01	450KVA	1.25/12.5kV-120/208V, 3Ø, Delta/Wye	ANN	150SYS		57851	F.P.E.	EMD E2	MS Mezzanine
T12.5MS-7	T03	750KVA	12.5kV/347/600V, 3Ø, Delta/Wye	ANN	150SYS	6.0%	57850	F.P.E.	EMD E2	MS Mezzanine
T12.5MS-8	T02	1500KVA	12.5kV/277/480V, 3Ø, Delta/Wye	ANN	150SYS	6.3%	57849	F.P.E.	EMD E2	MS Mezzanine
T12.5NL	T17	1500/1725/12.5kVA	12.5kV/277/480V, 3Ø, Delta/Wye	ANN	165SYS	5.94%	58391.01		EMD E4	NL
T12.5SS-1	T21	2MVA	12.5kV/277/480V, 3Ø, Delta/Wye	ANN		6.0%	Cat #32730-1	F.P.E.	EMD E5	SS Unit-Sub
T2.4MS-21FS	T05	1MVA	2400-277/480V, 3Ø, Delta/Wye	ANN		5.7%/5.93%@170"	80T3A441	Westinghouse	EMD E2	150T Crane
T2.4MS-21FU	-	300KVA	2400-480V Delta/Delta	ANN		3%			EMD E2	150T Crane
T2.4MS-22	T06	600KVA	2.3kV-480V, 3Ø	ANN		5.15%			EMD E2	50T Crane
T2.4PH-12	-	15kVA	2400-480V, 3Ø	ANN	220° C	5.0%	Cat #19350	REX Manufacturing	EMD E3	Pumphouse
T2.4SC-1	T24	1MVA	2.3kV/600V, 3Ø	ANN					EMD E5	SC
T2.4SS-2	T23	500KVA	25/12.5kV-600V, 3Ø, DELTA/WYE	ANN		5.5%			EMD E5	30T Crane
T6A-7	T10	112.5kVA	600-120/208V, 3Ø, Delta/Wye	ANN		3.1%			EMD E2	Electrical Shop
T6A-8	T11	75kVA	600-480V, 3Ø, Auto Transformer	ANN		1.0%			EMD E2	Electrical Shop
T6G		30kVA	600-120/208V, 3Ø	ANN					EMD E3	Pumphouse Garage
T6MS9-FS-1		150kVA	600-120/208V, 3Ø	ANN	200° C	4.5%	Cat. #BA150JM	REX Manufacturing	EMD E2	Vic Ship Operations Building
T6PH-7	T14	118kVA	600-277/480V, 3Ø	ANN					EMD E3	
T6PH-15	T13	112.5kVA	600-120/208V, 3Ø	ANN		6.66%@170"			EMD E3	Upper Pkg. Elect. Shd.
T6PHS-1		500KVA	600V-2.4kV, DELTA/WYE	ANN		5.0%			3000	PUMPHOUSE SUBSTATION
T6PHS-2		112.5kVA	600V-2.4kV, DELTA/WYE	ANN					3002	PUMPHOUSE SUBSTATION



- GENERAL NOTES:**
- 25/12.5KV, 2.4KV SWITCHBOARDS ARE TO BE EQUIPPED WITH OPTICAL FIBRE ARC FLASH SENSORS CONNECTED TO THE SWITCHBOARD UPSTREAM BREAKER, TO BE CONFIGURED TO TRIGGER AN EMERGENCY TRIP OF THE BOARD MAIN FEEDER BREAKER IF AN ARC FLASH EVENT OCCURS.
  - ALL EQUIPMENT TO BE MANUFACTURED TO 25KV STANDARDS AND RATING. INTIAL CONNECTION IS AT 12.5KV. PROVIDE ALL REQUIRED FUSING, WIRING, JUMPERS, ETC. FOR BOTH VOLTAGE CONDITIONS.
- NOTES:**
- EXISTING LOAD TO BE RECONNECTED/TRANSFERED FROM EXISTING SSS.
  - CABLING TO SES SWITCHBOARD, SUPPLIED, INSTALLED, CONNECTED AND TERMINATED BY OTHERS. COORDINATE CONNECTION TESTING AND INSTALLED WITH THIS CONTRACTOR VIA DEPARTMENTAL REPRESENTATIVE.



Revision/Revisión	Description/Description	Date/Date
5	ISSUED FOR TENDER	15/01/28
4	ISSUED FOR 99% DESIGN REVIEW	16/01/06
3	ISSUED FOR 66% DESIGN REVIEW	15/11/25
2	ISSUED FOR 33% DESIGN REVIEW	15/10/28
1	ISSUED FOR DESIGN DEVELOPMENT	15/09/11
0		

Client/client

**ESQUIMALT  
GRAVING DOCK**

825 ADMIRALS ROAD  
VICTORIA, BC, V9A 2P1

Project title/Titre du projet  
**825 ADMIRALS ROAD VICTORIA BC  
ESQUIMALT GRAVING DOCK  
ELECTRICAL SAFETY UPGRADE**

**SOUTH SUBSTATION  
SWITCHGEAR  
REPLACEMENT  
(SSSR)**

Consultant Signature Box Only

Designed by/Concept par  
**I. BARNES**

Drawn by/Dessiné par  
**J. BIELING / S. SEYMOUR**

PW/GSC Project Manager/Administrateur de Projets TPSGC  
**Jamie LeBlanc**

PW/GSC Regional Manager, Architectural and Engineering Services/  
Gestionnaire régionale, Services d'architecture et de génie, TPSGC  
**Prestipal Paul**

Drawing title/Titre du dessin


**SINGLE LINE DIAGRAM  
HIGH VOLTAGE DISTRIBUTION**

Project No./No. du projet	Sheet/Feuille	Revision no./ La Révision no.
<b>R.062548.2</b>	<b>5010</b>	<b>5</b>










- GENERAL NOTES:**
- CONTRACTOR SHALL PROVIDE SHOP DRAWINGS OF PROTECTION AND COORDINATION FOR REVIEW.
  - DETAILS PROVIDED ARE GUIDELINES. CONTRACTOR IS RESPONSIBLE FOR ALL WIRING AND DEVICES REQUIRED TO ACCOMPLISH PROTECTION FUNCTIONS DETAILED.
  - SEE SHEET 5010 FOR SINGLE LINE DIAGRAM.
  - ALL 25/12SSSR POTENTIAL TRANSFORMERS SHALL BE RATED FOR 25/12.5kV (14.4kV L-N) AND MULTI-RATIO WINDINGS FOR OPERATION AND 25/12.5kV AND 12.5kV. ALL 25/12SSSR CURRENT TRANSFORMERS SHALL BE 25/12.5kV CLASS AND HAVE RATIOS FOR OPERATION AT 25/12.5kV AND 12.5kV.
  - ALL INSTRUMENT TRANSFORMERS MUST MEET REQUIREMENTS OF CSA-C60044.



1 25/12.5kV MAIN BREAKER THREE LINE DIAGRAM  
5013 N.T.S.

5	ISSUED FOR TENDER	15/01/28
4	ISSUED FOR 99% DESIGN REVIEW	16/01/06
3	ISSUED FOR 66% DESIGN REVIEW	15/11/25
2	ISSUED FOR 33% DESIGN REVIEW	15/10/28
1	ISSUED FOR DESIGN DEVELOPMENT	15/09/11
0		

Revision/ Révision	Description/Description	Date/Date
--------------------	-------------------------	-----------

Client/client

**ESQUIMALT GRAVING DOCK**

825 ADMIRALS ROAD  
VICTORIA, BC, V9A 2P1

Project title/Titre du projet  
825 ADMIRALS ROAD VICTORIA BC  
ESQUIMALT GRAVING DOCK  
ELECTRICAL SAFETY UPGRADE

**SOUTH SUBSTATION SWITCHGEAR REPLACEMENT (SSSR)**

Consultant Signature Box Only

Designed by/Concept par

I. BARNES

Drawn by/Dessiné par

J. BIELING / S. SEYMOUR

PWSCSC Project Manager/Administrateur de Projets TPSGC

Jamie LeBlanc

PWSCSC Regional Manager, Architectural and Engineering Services/  
Gestionnaire régionale, Services d'architectural et de génie, TPSGC

Preestipal Paul

Drawing title/Titre du dessin

**25/12.5kV MAIN BREAKER THREE LINE DIAGRAM**



Project No./No. du projet	Sheet/Feuille	Revision no./ La Révision no.
---------------------------	---------------	----------------------------------

R.062548.2

5013

5





- GENERAL NOTES:**
- CONTRACTOR SHALL PROVIDE SHOP DRAWINGS OF PROTECTION AND COORDINATION FOR REVIEW.
  - DETAILS PROVIDED ARE GUIDELINES. CONTRACTOR IS RESPONSIBLE FOR ALL WIRING AND DEVICES REQUIRED TO ACCOMPLISH PROTECTION FUNCTIONS DETAILED.
  - SEE SHEET 5010 FOR SINGLE LINE DIAGRAM.
  - ALL 25/12.5kV POTENTIAL TRANSFORMERS SHALL BE RATED FOR 25/12.5kV (14.4kV MAXIMUM) AND ALL 25/12.5kV TRANSFORMERS SHALL BE 25/12.5kV CLASS AND HAVE RATIOS FOR OPERATION AT 25/12.5kV AND 12.5kV.
  - ALL INSTRUMENT TRANSFORMERS MUST MEET REQUIREMENTS OF CSA-C60044.

5	ISSUED FOR TENDER	15/01/28
4	ISSUED FOR 99% DESIGN REVIEW	16/01/06
3	ISSUED FOR 66% DESIGN REVIEW	15/11/25
2	ISSUED FOR 33% DESIGN REVIEW	15/10/28
1	ISSUED FOR DESIGN DEVELOPMENT	15/09/11
0		
Revision/Revisión	Description/Description	Date/Date

**ESQUIMALT GRAVING DOCK**

825 ADMIRALS ROAD  
VICTORIA, BC, V9A 2P1

Project title/Titre du projet  
**825 ADMIRALS ROAD VICTORIA BC  
ESQUIMALT GRAVING DOCK  
ELECTRICAL SAFETY UPGRADE**

**SOUTH SUBSTATION  
SWITCHGEAR  
REPLACEMENT  
(SSSR)**

Consultant Signature Box Only

Designed by/Concept par  
**I. BARNES**

Drawn by/Dessiné par  
**J. BIELING / S. SEYMOUR**



PWSSC Project Manager/Administrateur de Projets TPSGC  
**Jamie LeBlanc**

PWSSC Regional Manager, Architectural and Engineering Services/  
Gestionnaire régionale, Services d'architecture et de génie, TPSGC  
**Pretpat Paul**

**25/12.5kV DISTRIBUTION  
TYPICAL THREE LINE DIAGRAMS**

Project No./No. du projet <b>R.062548.2</b>	Sheet/Feuille <b>5014</b>	Revision no./ La Révision no. <b>5</b>
--	------------------------------	--





**1**  
5016

SOUTH SIDE SUBSTATION REPLACEMENT  
600V TYPICAL THREE LINE DIAGRAM  
NTS

5	ISSUED FOR TENDER	15/01/28
4	ISSUED FOR 99% DESIGN REVIEW	16/01/06
3	ISSUED FOR 66% DESIGN REVIEW	15/11/25
2	ISSUED FOR 33% DESIGN REVIEW	15/10/28
1	ISSUED FOR DESIGN DEVELOPMENT	15/09/11
0		

Revision/Revisión	Description/Description	Date/Date
-------------------	-------------------------	-----------

Client/client  
**ESQUIMALT GRAVING DOCK**  
825 ADMIRALS ROAD  
VICTORIA, BC, V9A 2P1

Project title/Titre du projet  
**825 ADMIRALS ROAD VICTORIA BC  
ESQUIMALT GRAVING DOCK  
ELECTRICAL SAFETY UPGRADE**  
**SOUTH SUBSTATION  
SWITCHGEAR  
REPLACEMENT  
(SSSR)**



Consultant Signature Box Only  
Designed by/Concept par  
**I. BARNES**  
Drawn by/Dessiné par  
**J. BIELING / S. SEYMOUR**  
PWGSC Project Manager/Administrateur de Projets TPSGC  
**Jamie LeBlanc**  
PWGSC Regional Manager, Architectural and Engineering Services/  
Gestionnaire régionale, Services d'architectural et de génie, TPSGC  
**Preetpal Paul**

Drawing title/Titre du dessin  
**600V TYPICAL  
THREE LINE DIAGRAMS**

Project No./No. du projet <b>R.062548.2</b>	Sheet/Feuille <b>5016</b>	Revision no./ La Révision no. <b>5</b>
--	------------------------------	--







1 SOUTH SIDE SUBSTATION REPLACEMENT  
5018 120/208V TYPICAL THREE LINE DIAGRAM  
NTS

5	ISSUED FOR TENDER	15/01/28
4	ISSUED FOR 99% DESIGN REVIEW	16/01/06
3	ISSUED FOR 66% DESIGN REVIEW	15/11/25
2	ISSUED FOR 33% DESIGN REVIEW	15/10/28
1	ISSUED FOR DESIGN DEVELOPMENT	15/09/11
0		

Revision/Revisión	Description/Description	Date/Date
-------------------	-------------------------	-----------

Client/client  
**ESQUIMALT GRAVING DOCK**  
825 ADMIRALS ROAD  
VICTORIA, BC, V9A 2P1

Project title/Titre du projet  
**825 ADMIRALS ROAD VICTORIA BC  
ESQUIMALT GRAVING DOCK  
ELECTRICAL SAFETY UPGRADE**  
**SOUTH SUBSTATION  
SWITCHGEAR  
REPLACEMENT  
(SSSR)**

Consultant Signature Box Only

Designed by/Concept par  
**I. BARNES**

Drawn by/Dessiné par  
**J. BIELING / S. SEYMOUR**

PWSC Project Manager/Administrateur de Projets TPSGC  
**Jamie LeBlanc**


PWSC Regional Manager, Architectural and Engineering Services/  
Gestionnaire régionale, Services d'architectural et de génie, TPSGC  
**Preetpal Paul**

Drawing title/Titre du dessin

**120/208V TYPICAL  
THREE LINE DIAGRAM**


Project No./No. du projet <b>R.062548.2</b>	Sheet/Feuille <b>5018</b>	Revision no./ La Révision no. <b>5</b>
--	------------------------------	--





**GENERAL NOTES:**

- GROUND FAULT DETECTION SYSTEM TO BE EQUIPPED WITH CUSTOMIZABLE HIERARCHY LIST. ALLOWING LOADS WITH GREATER PRIORITY TO OPERATE WITH A SINGLE PHASE TO GROUND FAULT AND TO TRIP LOADS OF A LOWER PRIORITY WHICH DEVELOP A SIMILAR FAULT.
- GROUND FAULT SYSTEM TO EXPORT DATA TO THE SCADA SYSTEM, ALLOWING HMI TO DISPLAY ALL BREAKER STATUSES, AND HISTORICAL AND REAL TIME SYSTEM DATA. THIS DATA IS FOR STORAGE AND VIEWING PURPOSES ONLY.



1 SOUTH SIDE SUBSTATION REPLACEMENT  
5019 120/208V TYPICAL THREE LINE DIAGRAM  
NTS

Revision/	Description/Description	Date/Date
5	ISSUED FOR TENDER	15/01/28
4	ISSUED FOR 99% DESIGN REVIEW	16/01/06
3	ISSUED FOR 66% DESIGN REVIEW	15/11/25
2	ISSUED FOR 33% DESIGN REVIEW	15/10/28
1	ISSUED FOR DESIGN DEVELOPMENT	15/09/11
0		

Client/client

**ESQUIMALT GRAVING DOCK**

825 ADMIRALS ROAD  
VICTORIA, BC, V9A 2P1

Project title/Titre du projet  
**825 ADMIRALS ROAD VICTORIA BC  
ESQUIMALT GRAVING DOCK  
ELECTRICAL SAFETY UPGRADE**  
**SOUTH SUBSTATION  
SWITCHGEAR  
REPLACEMENT  
(SSSR)**

Consultant Signature Box Only

Designed by/Concept par  
**I. BARNES**

Drawn by/Dessiné par  
**J. BIELING / S. SEYMOUR**

PWCSC Project Manager/Administrateur de Projets TPSGC  
**Jamie LeBlanc**

PWCSC Regional Manager, Architectural and Engineering Services/  
Gestionnaire régionale, Services d'architecture et de génie, TPSGC  
**Preetpal Paul**


Drawing title/Titre du dessin

**120/208V TYPICAL  
THREE LINE DIAGRAM**


Project No./No. du projet	Sheet/Feuille	Revision no./ La Révision no.
<b>R.062548.2</b>	<b>5019</b>	<b>5</b>









- GENERAL NOTES:**
- BREAKER LOCATIONS ARE ILLUSTRATIVE ONLY. FINAL BREAKER LOCATIONS TO BE DETERMINED BY CONTRACTOR BASED ON SITE CONDITIONS AND MANUFACTURER SWITCHBOARD CONSTRUCTION TECHNIQUES.
  - ALL CIRCUIT BREAKERS TO HAVE ELECTRONIC TRIP UNITS COMPLETE WITH LSIG ELEMENT AND POWERHARMONIC/ENERGY METERING.
- KEYNOTES:**
- 1200AF/1200AT BREAKER C/W LSIG DIGITAL TRIP UNIT. 65KAIC MINIMUM INTERRUPT RATING @ 480V. EQUIPPED WITH LOAD SIDE REVENUE METERING CTS FOR CUSTOMER BILLING.
  - 600AF/500AT BREAKER C/W LSIG DIGITAL TRIP UNIT. 65KAIC MINIMUM INTERRUPT RATING @ 480V. EQUIPPED WITH LOAD SIDE REVENUE METERING CTS FOR CUSTOMER BILLING.
  - 400AF/400AT BREAKER C/W LSIG DIGITAL TRIP UNIT. 65KAIC MINIMUM INTERRUPT RATING @ 480V. EQUIPPED WITH LOAD SIDE REVENUE METERING CTS FOR CUSTOMER BILLING.
  - 250AF/250AT BREAKER C/W LSIG DIGITAL TRIP UNIT. 65KAIC MINIMUM INTERRUPT RATING @ 480V. EQUIPPED WITH LOAD SIDE REVENUE METERING CTS FOR CUSTOMER BILLING.
  - 250AF/200AT BREAKER C/W LSIG DIGITAL TRIP UNIT. 65KAIC MINIMUM INTERRUPT RATING @ 480V. EQUIPPED WITH LOAD SIDE REVENUE METERING CTS FOR CUSTOMER BILLING.
  - 250AF/150AT BREAKER C/W LSIG DIGITAL TRIP UNIT. 65KAIC MINIMUM INTERRUPT RATING @ 480V. EQUIPPED WITH LOAD SIDE REVENUE METERING CTS FOR CUSTOMER BILLING.
  - 100AF/60AT BREAKER C/W LSIG DIGITAL TRIP UNIT. 65KAIC MINIMUM INTERRUPT RATING @ 480V.
  - 100AF/30AT BREAKER C/W LSIG DIGITAL TRIP UNIT. 65KAIC MINIMUM INTERRUPT RATING @ 480V.
  - HIGH DENSITY REVENUE METERING CABINET.
  - 480V 3Ø, 3W 2x3000A PARALLEL BUS DUCT, 65 KAIC WITHSTAND.
  - SWITCHBOARD CELL, 480V 3Ø, 3W 3000A BUSSING, 65 KAIC WITHSTAND, C/W INDICATED BREAKERS. ALL LOAD SIDE FEEDERS ARE BOTTOM ENTRY. BUSSING TO BE TIN PLATED COPPER.
  - BOTTOM/TOP ENTRY ZONES
  - TOP ENTRY BUS DUCT
  - COMMUNICATION CONDUITS VIA FLOOR PENETRATION SLEEVES
  - DRAW OUT CIRCUIT BREAKER SWITCHBOARD CELL, 480V 3Ø 5000A BUSSING, 65 KAIC WITHSTAND, C/W INDICATED BREAKERS. ALL LOAD SIDE FEEDERS ARE BOTTOM ENTRY AND SIDE ENTRY. BUSSING TO BE TIN PLATED COPPER.
  - 2000AF BREAKER SPACE. BUS BARS INSTALLED BEHIND.
  - NOT USED
  - 4000AF/3000AT BREAKER C/W LSIG DIGITAL TRIP UNIT. 65KAIC MINIMUM INTERRUPT RATING @ 480V.
  - EXISTING 1000kVA 480V HARMONIC FILTER BANK TO BE RELOCATED FROM EXISTING SSS TO NEW SSSR BUILDING.
  - 480V 3Ø 2000A BUS DUCT, 65 KAIC WITHSTAND.
  - EMPTY BREAKER LOCATIONS. PROVIDE COVERS, BUSBARS TO EXTEND FULL HEIGHT OF CELL.
  - 400AF/400AT, 100% RATED BREAKER C/W LSIG DIGITAL TRIP UNIT. 65KAIC MINIMUM INTERRUPT RATING @ 480V. EQUIPPED WITH LOAD SIDE REVENUE METERING CTS FOR CUSTOMER BILLING.




1 480V SWITCHBOARD FRONT ELEVATION  
5031 SCALE 1:20



2 480V SWITCHBOARD FLOOR PENETRATIONS  
5031 SCALE 1:20



3 480V SWITCHBOARD PLAN VIEW  
5031 SCALE 1:20



4 480V SWITCHBOARD FOOTPRINT  
5031 SCALE 1:20



Revision/Revisions	Description/Description	Date/Date
5	ISSUED FOR TENDER	15/01/28
4	ISSUED FOR 90% DESIGN REVIEW	16/01/06
3	ISSUED FOR 66% DESIGN REVIEW	15/11/25
2	ISSUED FOR 33% DESIGN REVIEW	15/10/28
1	ISSUED FOR DESIGN DEVELOPMENT	15/09/11
0		

Client/client

**ESQUIMALT GRAVING DOCK**

825 ADMIRALS ROAD  
VICTORIA, BC, V9A 2P1

Project title/Titre du projet  
825 ADMIRALS ROAD VICTORIA BC  
ESQUIMALT GRAVING DOCK  
ELECTRICAL SAFETY UPGRADE

**SOUTH SUBSTATION SWITCHGEAR REPLACEMENT (SSSR)**

Consultant Signature Box Only

Designed by/Concept par  
I. BARNES

Drawn by/Dessiné par  
J. BIELING / S. SEYMOUR

PWGSC Project Manager/Administrateur de Projets TPSGC  
Jamie LeBlanc

PWGSC, Regional Manager, Architectural and Engineering Services/  
Gestionnaire régionale, Services d'architecture et de génie, TPSGC  
Prestipal Paul

Drawing title/Titre du dessin



**480V SWITCHBOARD DETAILS**

Project No./No. du projet	Sheet/Feuille	Revision no./no. de révision
R.062548.2	5031	5




- GENERAL NOTES:**
- BREAKER LOCATIONS ARE ILLUSTRATIVE ONLY. FINAL BREAKER LOCATIONS TO BE DETERMINED BY CONTRACTOR BASED ON SITE CONDITIONS AND MANUFACTURER SWITCHBOARD CONSTRUCTION TECHNIQUES.
  - ALL CIRCUIT BREAKERS TO HAVE ELECTRONIC TRIP UNITS COMPLETE WITH LSI ELEMENT AND POWERHARMONIC/ENERGY METERING.


- KEYNOTES:**
- 400AF/400AT BREAKER C/W LSI DIGITAL DIGITAL TRIP UNIT. 42KAIC MINIMUM INTERRUPT RATING @ 240V. EQUIPPED WITH LOAD SIDE REVENUE METERING CTS FOR CUSTOMER BILLING.
  - 250AF/200AT BREAKER C/W LSI DIGITAL DIGITAL TRIP UNIT. 42KAIC MINIMUM INTERRUPT RATING @ 240V. EQUIPPED WITH LOAD SIDE REVENUE METERING CTS FOR CUSTOMER BILLING.
  - 250AF/150AT BREAKER C/W LSI DIGITAL DIGITAL TRIP UNIT. 42KAIC MINIMUM INTERRUPT RATING @ 240V. EQUIPPED WITH LOAD SIDE REVENUE METERING CTS FOR CUSTOMER BILLING.
  - 250AF/125AT BREAKER C/W LSI DIGITAL DIGITAL TRIP UNIT. 42KAIC MINIMUM INTERRUPT RATING @ 240V. EQUIPPED WITH LOAD SIDE REVENUE METERING CTS FOR CUSTOMER BILLING.
  - 250AF/125AT BREAKER C/W LSI DIGITAL DIGITAL TRIP UNIT. 42KAIC MINIMUM INTERRUPT RATING @ 240V.
  - 100AF/60AT BREAKER C/W LSI DIGITAL DIGITAL TRIP UNIT. 42KAIC MINIMUM INTERRUPT RATING @ 240V.
  - 100AF/15AT BREAKER C/W LSI DIGITAL DIGITAL TRIP UNIT. 42KAIC MINIMUM INTERRUPT RATING @ 240V.
  - HIGH DENSITY REVENUE METERING CABINET.
  - 120/240V 30 4000A BUS DUCT. 42 KAIC WITHSTAND.
  - SWITCHBOARD CELL. 120/240V 30 3000A BUSSING. 42 KAIC WITHSTAND. C/W INDICATED BREAKERS. ALL LOAD SIDE FEEDERS ARE BOTTOM ENTRY. BUSSING TO BE TIN PLATED COPPER.
  - BOTTOM/TOP ENTRY ZONES
  - TOP ENTRY BUS DUCT
  - COMMUNICATION CONDUITS VIA FLOOR PENETRATION SLEEVES
  - EMPTY BREAKER LOCATIONS. PROVIDE COVERS, BUSBARS TO EXTEND FULL HEIGHT OF CELL.
  - 250AF/200AT, 100% RATED BREAKER C/W LSI DIGITAL DIGITAL TRIP UNIT. 42KAIC MINIMUM INTERRUPT RATING @ 240V. EQUIPPED WITH LOAD SIDE REVENUE METERING CTS FOR CUSTOMER BILLING.




2 120/208V SWITCHBOARD FLOOR PENETRATIONS  
5032 SCALE 1:20



3 120/208V SWITCHBOARD PLAN VIEW  
5032 SCALE 1:20



1 120/208V SWITCHBOARD FRONT ELEVATION  
5032 SCALE 1:20



4 120/208V SWITCHBOARD FOOTPRINT  
5032 SCALE 1:20

Revision/Revision	Description/Description	Date/Date
5	ISSUED FOR TENDER	15/01/28
4	ISSUED FOR 90% DESIGN REVIEW	16/01/06
3	ISSUED FOR 66% DESIGN REVIEW	15/11/25
2	ISSUED FOR 33% DESIGN REVIEW	15/10/28
1	ISSUED FOR DESIGN DEVELOPMENT	15/09/11
0		

Client/client

**ESQUIMALT GRAVING DOCK**

825 ADMIRALS ROAD  
VICTORIA, BC, V9A 2P1

Project title/Titre du projet  
**825 ADMIRALS ROAD VICTORIA BC  
ESQUIMALT GRAVING DOCK  
ELECTRICAL SAFETY UPGRADE**

**SOUTH SUBSTATION  
SWITCHGEAR  
REPLACEMENT  
(SSSR)**

Consultant Signature Box Only

Designed by/Concept par  
**I. BARNES**

Drawn by/Dessiné par  
**J. BIELING / S. SEYMOUR**


PWGSC Project Manager/Administrateur de Projets TPSGC  
**Jamie LeBlanc**

PWGSC, Regional Manager, Architectural and Engineering Services/  
Gestionnaire régionale, Services d'architecture et de génie, TPSGC  
**Preetipal Paul**

Drawing title/Titre du dessin


**120/208V SWITCHBOARD DETAILS**

Project No./No. du projet	Sheet/Feuille	Revision no./ no. de révision
R.062548.2	5032	5





**GENERAL NOTES:**  
 1. ALL CIRCUIT BREAKERS TO HAVE ELECTRONIC TRIP UNITS COMPLETE WITH LSI&G ELEMENT AND POWERHARMONIC&ENERGY METERING.


- KEYNOTES:**
- 1. 3000AF/2500AT. BREAKER, RATED AT 630V C/W LSI&G DIGITAL TRIP UNIT. 42KAIC MINIMUM INTERRUPT RATING @ 630V.
  - 2. HIGH DENSITY REVENUE METERING CABINET.
  - 3. 630V 3Ø 2500A BUS DUCT, 42KAIC WITHSTAND.
  - 4. SWITCHBOARD CELL, 630V 3Ø 2500A BUSSING, 42KAIC WITHSTAND, C/W INDICATED BREAKERS. ALL LOAD SIDE FEEDERS ARE BOTTOM ENTRY. BUSSING TO BE TIN PLATED COPPER.
  - 5. BOTTOM/TOP ENTRY ZONES
  - 6. TOP ENTRY BUS DUCT
  - 7. COMMUNICATION CONDUITS VIA FLOOR PENETRATION SLEEVES




2 430-630V REGULATED SWITCHBOARD FLOOR PENETRATIONS  
 5033 SCALE 1:20



3 430-630V REGULATED SWITCHBOARD PLAN VIEW  
 5033 SCALE 1:20



1 430-630V REGULATED SWITCHBOARD FRONT ELEVATION  
 5033 SCALE 1:20



4 430-630V REGULATED SWITCHBOARD FOOTPRINT  
 5033 SCALE 1:20

Revision/Revisión	Description/Description	Date/Date
5	ISSUED FOR TENDER	15/01/28
4	ISSUED FOR 99% DESIGN REVIEW	16/01/06
3	ISSUED FOR 66% DESIGN REVIEW	15/11/25
2	ISSUED FOR 33% DESIGN REVIEW	15/10/28
1	ISSUED FOR DESIGN DEVELOPMENT	15/09/11
0		

Client/client

**ESQUIMALT GRAVING DOCK**

825 ADMIRALS ROAD  
 VICTORIA, BC, V9A 2P1

Project title/Titre du projet  
**825 ADMIRALS ROAD VICTORIA BC  
 ESQUIMALT GRAVING DOCK  
 ELECTRICAL SAFETY UPGRADE**

**SOUTH SUBSTATION  
 SWITCHGEAR  
 REPLACEMENT  
 (SSSR)**

Consultant Signature Box Only

Designed by/Concept par  
**I. BARNES**

Drawn by/Dessiné par  
**J. BIELING / S. SEYMOUR**


PWSCSC Project Manager/Administrateur de Projets TPSGC  
**Jamie LeBlanc**

PWSCSC Regional Manager, Architectural and Engineering Services/  
 Gestionnaire régionale, Services d'architecture et de génie, TPSGC  
**Preetpal Paul**

Drawing title/Titre du dessin

**430-630V REGULATED  
 SWITCHBOARD DETAILS**



Project No./No. du projet	Sheet/Feuille	Revision no./ La Révision no.
R.062548.2	5033	5





- GENERAL NOTES:**
- ENCLOSURE DIMENSIONS ARE APPROXIMATE ONLY. FINAL ENCLOSURE SIZES TO BE PROVIDED IN SHOP DRAWINGS.
  - BATTERY CHARGER TO PROVIDE A MINIMUM OF 8 HOURS BACK-UP WITH SUFFICIENT CAPACITY TO TRIP ALL BREAKERS CONCURRENTLY.
  - DC DEVICES IN SWITCHGEAR SHALL BE WIRED FROM TERMINAL BLOCKS TO ENSURE DC TRIP CIRCUIT CANNOT BE COMPROMISED BY A METER OR OTHER DEVICE FAULT.
  - PROVIDE DEDICATED CIRCUIT BREAKERS FOR UPPER AND LOWER PORTIONS OF EACH SWITCHGEAR CELL AS INDICATED. SPARE BREAKERS SHALL BE PROVIDED PER PANEL SCHEDULE.
  - CONTRACTOR SHALL SUBMIT COMPLETE PANEL SCHEDULE INDICATING BREAKER IDS.

SOUTH SIDE SUBSTATION REPLACEMENT BATTERY BANK PANEL									
Voltage:	-	125VDC, 2W							
Location:	-	SOUTH SIDE SUBSTATION REPLACEMENT							
Circuits:	-	72							
Bus Size:	-	100A							
Main Breaker:	-	30A							
Description	Bkr	P	Cir	Cir	Bkr	P	Description		
25/12SSSR Cell 1 - Upper	15	2	1	2	15	2	25/12SSSR Cell 1 - Lower		
25/12SSSR Cell 2 - Upper	15	2	3	4	15	2	25/12SSSR Cell 2 - Lower		
25/12SSSR Cell 3 - Upper	15	2	5	6	15	2	25/12SSSR Cell 3 - Lower		
25/12SSSR Cell 4 - Upper	15	2	7	8	15	2	25/12SSSR Cell 4 - Lower		
25/12SSSR Cell 5 - Upper	15	2	9	10	15	2	25/12SSSR Cell 5 - Lower		
25/12SSSR Cell 6 - Upper	15	2	11	12	15	2	25/12SSSR Cell 6 - Lower		
25/12SSSR Cell 7 - Upper	15	2	13	14	15	2	25/12SSSR Cell 7 - Lower		
24SSSR Cell 1 - Upper	15	2	15	16	15	2	24SSSR Cell 1 - Lower		
24SSSR Cell 2 - Upper	15	2	17	18	15	2	24SSSR Cell 2 - Lower		
4SSSR-1 Cell 1 - Upper	15	2	19	20	15	2	4SSSR-1 Cell 1 - Lower		
4SSSR-1 Cell 2 - Middle	15	2	21	22	15	2	6SSSR-1 SCADA METER POWER		
4SSSR-2 SCADA METER POWER	15	2	23	24	15	2	2SSSR-1 SCADA METER POWER		
5SSSR-REG SCADA METER POWER	15	2	25	26	15	2	SSSR SCADA PANEL		
SSSR 480V GROUND FAULT SYSTEM	15	2	27	28	15	2	BATTERY CHARGER CABINET		
	15	2	29	30	15	2			
	15	2	31	32	15	2			
	15	2	33	34	15	2			
	15	2	35	36	15	2			
	15	2	37	38	15	2			
	15	2	39	40	15	2			
	15	2	41	42	15	2			
	15	2	43	44	15	2			
	15	2	45	46	15	2			
	15	2	47	48	15	2			
	15	2	49	50	15	2			
	15	2	51	52	15	2			
	15	2	53	54	15	2			
	15	2	55	56	15	2			
	15	2	57	58	15	2			
	15	2	59	60	15	2			
	15	2	61	62	15	2			
	15	2	63	64	15	2			
	15	2	65	66	15	2			
	15	2	67	68	15	2			
	15	2	69	70	15	2			
	15	2	71	72	15	2			



1 SOUTH SIDE SUBSTATION REPLACEMENT BATTERY BANK CHARGER PANEL SCHEDULE  
5013 5014 5015  
1 1  
5016 5017  
N.T.S.

2 SOUTH SIDE SUBSTATION REPLACEMENT DC PANEL, BATTERY BANK AND CHARGER CABINET ELEVATION  
5034  
N.T.S.

3 SOUTH SIDE SUBSTATION REPLACEMENT BATTERY BANK (DOOR NOT SHOWN)  
5034  
N.T.S.

Revision/Revisions	Description/Description	Date/Date
5	ISSUED FOR TENDER	15/01/28
4	ISSUED FOR 99% DESIGN REVIEW	16/01/06
3	ISSUED FOR 66% DESIGN REVIEW	15/11/25
2	ISSUED FOR 33% DESIGN REVIEW	15/10/28
1	ISSUED FOR DESIGN DEVELOPMENT	15/09/11
0		

Client/client

**ESQUIMALT GRAVING DOCK**

825 ADMIRALS ROAD  
VICTORIA, BC, V9A 2P1

Project title/Titre du projet  
825 ADMIRALS ROAD VICTORIA BC  
ESQUIMALT GRAVING DOCK  
ELECTRICAL SAFETY UPGRADE

**SOUTH SUBSTATION SWITCHGEAR REPLACEMENT (SSSR)**

Consultant Signature Box Only

Designed by/Concept par  
**I. BARNES**

Drawn by/Dessiné par  
**J. BIELING / S. SEYMOUR**

PWCSG Project Manager/Administrateur de Projets TPSGC  
**Jamie LeBlanc**


PWCSG Regional Manager, Architectural and Engineering Services/  
Gestionnaire régionale, Services d'architecture et de génie, TPSGC  
**Prestipal Paul**

Drawing title/Titre du dessin

**BATTERY BANK AND CHARGER DETAILS**

Project No./No. du projet	Sheet/Feuille	Revision no./ La Révision no.
R.062548.2	5034	5





Revision/Revisions	Description/Description	Date/Date
5	ISSUED FOR TENDER	15/01/28
4	ISSUED FOR 99% DESIGN REVIEW	16/01/06
3	ISSUED FOR 66% DESIGN REVIEW	15/11/25
2	ISSUED FOR 33% DESIGN REVIEW	15/10/28
1	ISSUED FOR DESIGN DEVELOPMENT	15/09/11
0		

**ESQUIMALT GRAVING DOCK**

825 ADMIRALS ROAD  
VICTORIA, BC, V9A 2P1

Project title/Titre du projet  
**825 ADMIRALS ROAD VICTORIA BC  
ESQUIMALT GRAVING DOCK  
ELECTRICAL SAFETY UPGRADE**

**SOUTH SUBSTATION  
SWITCHGEAR  
REPLACEMENT  
(SSSR)**

Consultant Signature Box Only

Designed by/Concept par  
**I. BARNES**

Drawn by/Dessiné par  
**J. BIELING / S. SEYMOUR**

PWSSC Project Manager/Administrateur de Projets TPSSC  
**Jamie LeBlanc**

PWSSC Regional Manager, Architectural and Engineering Services/  
Gestionnaire régionale, Services d'architecture et de génie, TPSSC  
**Pretpal Paul**


Drawing title/Titre du dessin

**EGD SITE SCADA SYSTEM RISER  
DIAGRAM**

Project No./No. du projet  
**R.062548.2**

Sheet/Feuille  
**5050**

Revision no./  
La Révision no.  
**5**



GENERAL NOTES:  
1. LIGHT LINES INDICATE EXISTING SCADA INFRASTRUCTURE.

PLANT MANAGER'S OFFICE (FUTURE SERVER LOCATION) CAT 5 TRAYS JACK

PUMP HOUSE COMMUNICATIONS ROOM

ION ENTERPRISE CLIENT MONITOR OPERATOR'S CONSOLE 10 BASE ETHERNET

ION ENTERPRISE SERVER

INCOMING OPTICAL FIBERS VIA NEW DUCT BANK

EXISTING SYSTEM TO BE REMOVED. NEW SYSTEM TO BE BUILT LOCATED IN SSSR EXCEPT WHERE NOTED

PUMP HOUSE SCADA NETWORK SWITCH 10/100/1000 T/SWITCH AT-8224XL

6 PORT MEDIA CONVERTER AT-MCP06/ST

FIBRE PATCH PANEL

PARKING LOT 'X' ELECTRICAL SHACK

SCADA-0101 to SCADA-0108

SCADA-0201 to SCADA-0208

SCADA-0301 to SCADA-0308

SCADA-0401 to SCADA-0408

SCADA-0501 to SCADA-0508

SCADA-0601 to SCADA-0608

SCADA-0701 to SCADA-0708

SCADA-0801 to SCADA-0808

SCADA-0901 to SCADA-0908

SCADA-1001 to SCADA-1008

SCADA-1101 to SCADA-1108

SCADA-1201 to SCADA-1208

SCADA-1301 to SCADA-1308

SCADA-1401 to SCADA-1408

SCADA-1501 to SCADA-1508

SCADA-1601 to SCADA-1608

SCADA-1701 to SCADA-1708

SCADA-1801 to SCADA-1808

SCADA-1901 to SCADA-1908

SCADA-2001 to SCADA-2008

SCADA-2101 to SCADA-2108

SCADA-2201 to SCADA-2208

SCADA-2301 to SCADA-2308

SCADA-2401 to SCADA-2408

SCADA-2501 to SCADA-2508

SCADA-2601 to SCADA-2608

SCADA-2701 to SCADA-2708

SCADA-2801 to SCADA-2808

SCADA-2901 to SCADA-2908

SCADA-3001 to SCADA-3008

SCADA-3101 to SCADA-3108

SCADA-3201 to SCADA-3208

SCADA-3301 to SCADA-3308

SCADA-3401 to SCADA-3408

SCADA-3501 to SCADA-3508

SCADA-3601 to SCADA-3608

SCADA-3701 to SCADA-3708

SCADA-3801 to SCADA-3808

SCADA-3901 to SCADA-3908

SCADA-4001 to SCADA-4008

SCADA-4101 to SCADA-4108

SCADA-4201 to SCADA-4208

SCADA-4301 to SCADA-4308

SCADA-4401 to SCADA-4408

SCADA-4501 to SCADA-4508

SCADA-4601 to SCADA-4608

SCADA-4701 to SCADA-4708

SCADA-4801 to SCADA-4808

SCADA-4901 to SCADA-4908

SCADA-5001 to SCADA-5008

SCADA-5101 to SCADA-5108

SCADA-5201 to SCADA-5208

SCADA-5301 to SCADA-5308

SCADA-5401 to SCADA-5408

SCADA-5501 to SCADA-5508

SCADA-5601 to SCADA-5608

SCADA-5701 to SCADA-5708

SCADA-5801 to SCADA-5808

SCADA-5901 to SCADA-5908

SCADA-6001 to SCADA-6008

SCADA-6101 to SCADA-6108

SCADA-6201 to SCADA-6208

SCADA-6301 to SCADA-6308

SCADA-6401 to SCADA-6408

SCADA-6501 to SCADA-6508

SCADA-6601 to SCADA-6608

SCADA-6701 to SCADA-6708

SCADA-6801 to SCADA-6808

SCADA-6901 to SCADA-6908

SCADA-7001 to SCADA-7008

SCADA-7101 to SCADA-7108

SCADA-7201 to SCADA-7208

SCADA-7301 to SCADA-7308

SCADA-7401 to SCADA-7408

SCADA-7501 to SCADA-7508

SCADA-7601 to SCADA-7608

SCADA-7701 to SCADA-7708

SCADA-7801 to SCADA-7808

SCADA-7901 to SCADA-7908

SCADA-8001 to SCADA-8008

SCADA-8101 to SCADA-8108

SCADA-8201 to SCADA-8208

SCADA-8301 to SCADA-8308

SCADA-8401 to SCADA-8408

SCADA-8501 to SCADA-8508

SCADA-8601 to SCADA-8608

SCADA-8701 to SCADA-8708

SCADA-8801 to SCADA-8808

SCADA-8901 to SCADA-8908

SCADA-9001 to SCADA-9008

SCADA-9101 to SCADA-9108

SCADA-9201 to SCADA-9208

SCADA-9301 to SCADA-9308

SCADA-9401 to SCADA-9408

SCADA-9501 to SCADA-9508


SCADA-9601 to SCADA-9608

SCADA-9701 to SCADA-9708


SCADA-9801 to SCADA-9808

SCADA-9901 to SCADA-9908

SCADA-10001 to SCADA-10008



- GENERAL NOTES:**
- CONNECT SCADA AND NETWORKING EQUIPMENT SYSTEM TO PROTECTION AND CONTROL POWER SUPPLY. SEE SPECIFICATION FOR PROTECTION AND CONTROL POWER SUPPLY REQUIREMENTS.
  - BREAKER AND METER ID'S TO MATCH BREAKER NUMBER BASED ON POSITION IN SWITCHBOARD LINE UP. EXACT NUMBERS TO BE DETERMINED ON SITE DURING INSTALLATION BASED ON FINAL BREAKER LOCATIONS IN SWITCHBOARDS.



**1** SSSR SCADA SYSTEM CONNECTION RISER  
5051 N.T.S.

Revision/Revisions	Description/Description	Date/Date
5	ISSUED FOR TENDER	15/01/28
4	ISSUED FOR 99% DESIGN REVIEW	16/01/06
3	ISSUED FOR 66% DESIGN REVIEW	15/11/25
2	ISSUED FOR 33% DESIGN REVIEW	15/10/28
1	ISSUED FOR DESIGN DEVELOPMENT	15/09/11
0		

**ESQUIMALT GRAVING DOCK**  
825 ADMIRALS ROAD VICTORIA, BC, V9A 2P1

Project title/Titre du projet  
**825 ADMIRALS ROAD VICTORIA BC ESQUIMALT GRAVING DOCK ELECTRICAL SAFETY UPGRADE**

**SOUTH SUBSTATION SWITCHGEAR REPLACEMENT (SSSR)**

Consultant Signature Box Only

Designed by/Concept par  
**I. BARNES**

Drawn by/Dessiné par  
**J. BIELING / S. SEYMOUR**

PWSSC Project Manager/Administrateur de Projets TPSGC  
**Jamie LeBlanc**

PWSSC Regional Manager, Architectural and Engineering Services/Gestionnaire régionale, Services d'architectural et de génie, TPSGC  
**Preetpal Paul**


**SSSR SCADA SYSTEM CONNECTION RISER**

Project No./No. du projet	Sheet/Feuille	Revision no./La Révision no.
<b>R.062548.2</b>	<b>5051</b>	<b>5</b>











KEY NOTES:


- 1 2x27mm C. IN SLAB BETWEEN 125VDC PANEL AND HIGH VOLTAGE SWITCHGEAR.
- 2 1x53mm C. IN SLAB BETWEEN DC CHARGER AND DC BATTERY BANK.
- 3 1x53mm C. IN SLAB BETWEEN DC CHARGER AND 125VDC PANEL 2SSSR-SP-1
- 4 1x53mm C. CONCEALED IN WALL BETWEEN DC CHARGER AND PANEL
- 5 BUS DUCT FLOOR PENETRATION, COORDINATE WITH TRANSFORMER SECONDARY TERMINAL LOCATIONS
- 6 CONDUIT FLOOR PENETRATION, COORDINATE WITH TRANSFORMER PRIMARY AND HIGH VOLTAGE SWITCH GEAR CELL LOCATIONS.
- 7 1x103mm C. BETWEEN REGULATOR SECONDARY AND TRANSFORMER PRIMARY TERMINALS.
- 8 1x129mm SLEEVE BETWEEN SWITCHGEAR CELLS AND HIGH VOLTAGE WIREWAY. COORDINATE SLEEVE LOCATION WITH MANUFACTURER'S SHOP DRAWINGS TO DETERMINE REQUIRED LOCATION.
- 9 CCTV CAMERA TO MONITOR HIGH VOLTAGE GEAR DURING REMOTE OPERATION.
- 10 TRANSFORMER NEUTRAL GROUNDING RESISTORS. 1016x1143x40mm (HxWxD)




1 SECOND FLOOR ELECTRICAL LAYOUT  
SCALE 1:50



2 SECOND FLOOR PARTIAL ELEVATION DETAIL 1 OF 3  
SCALE 1:50



3 SECOND FLOOR PARTIAL ELEVATION DETAIL 2 OF 3  
SCALE 1:50



4 SECOND FLOOR PARTIAL ELEVATION DETAIL 3 OF 3  
SCALE 1:50

Revision/Revision	Description/Description	Date/Date
5	ISSUED FOR TENDER	15/01/28
4	ISSUED FOR 90% DESIGN REVIEW	16/01/06
3	ISSUED FOR 66% DESIGN REVIEW	15/11/25
2	ISSUED FOR 33% DESIGN REVIEW	15/10/28
1	ISSUED FOR DESIGN DEVELOPMENT	15/09/11
0		

Client/client

**ESQUIMALT GRAVING DOCK**

825 ADMIRALS ROAD  
VICTORIA, BC, V9A 2P1

Project title/Titre du projet  
**825 ADMIRALS ROAD VICTORIA BC  
ESQUIMALT GRAVING DOCK  
ELECTRICAL SAFETY UPGRADE**

**SOUTH SUBSTATION  
SWITCHGEAR  
REPLACEMENT  
(SSSR)**

Consultant Signature Box Only

Designed by/Concept par  
**I. BARNES**

Drawn by/Dessiné par  
**J. BIELING / S. SEYMOUR**


PWGSC Project Manager/Administrateur de Projets TPSGC  
**Jamie LeBlanc**



PWGSC, Regional Manager, Architectural and Engineering Services/  
Gestionnaire régionale, Services d'architecture et de génie, TPSGC  
**Preetipal Paul**

Drawing title/Titre du dessin


**SECOND FLOOR  
ELECTRICAL EQUIPMENT LAYOUT**

Project No./No. du projet	Sheet/Feuille	Revision no./ no. de révision
R.062548.2	5103	5







2 25/12.5kV PULLBOX ELEVATIONS  
5104 SCALE 1:20




3 25/12.5kV PULLBOX PLAN VIEW  
5104 SCALE 1:20




4 2.4kV PULLBOX ELEVATIONS  
5104 SCALE 1:20



5 2.4kV PULLBOX PLAN VIEW  
5104 SCALE 1:20



6 600V PULL BOX ELEVATIONS  
5104 SCALE 1:20



7 600V PULL BOX PLAN VIEW  
5104 SCALE 1:20

KEYNOTES DETAIL 2/5104 TO 7/5104:


- 1 NEW SSSR HIGH VOLTAGE SERVICE. 3#250KCM XLPE.
- 2 4x129mm C. TO SECOND FLOOR HIGH VOLTAGE WIREWAY 25KV SECTION. REFER TO SHEET 5102 FOR ADDITIONAL DETAILS.
- 3 1x129mm C. TO EXISTING SOUTH SIDE SUB SERVICE TUNNEL.
- 4 3#1, 12.5KV TECK REROUTED FROM SERVICE TUNNEL. TEMPORARY SSS BACKFEED.
- 5 4x129mm C. DUCT BANK - SEE SHEET 5106 AND 5416 FOR ADDITIONAL DETAIL.
- 6 ENSURE BOX AND CONDUITS ARE LOCATED TO MEET 12x O.D BENDING RADIUS OF 12KV, 5KV OR 600V TECK CABLE.
- 7 1x129mm C. TO SECOND FLOOR HIGH VOLTAGE WIREWAY, 2.4KV SECTION.
- 8 3#2 5KV TECK CABLE TO TRAVELING CRANE TRAILING CABLE SPLICE BOX. REFER TO SHEET 5107 FOR ADDITIONAL DETAILS.
- 9 1x129mm C. TO 6SSSR-SP-1
- 10 3#2/0 600V TECK CABLE TO CAISSON #2, AND CAISSON #3 SPLICE BOX IN SERVICE TUNNEL. REFER TO SHEET 5107 FOR ADDITIONAL INFORMATION

NOTES DETAIL 1/5104:


- 1. CABLE TRAY LOCATIONS ARE PRELIMINARY. CONTRACTOR TO CONFIRM LAYOUT WITH MANUFACTURERS SWITCHGEAR AND SHOP DRAWINGS AND MAKE ADJUSTMENTS ACCORDINGLY. ENSURE ALL CLEARANCES AND ACCESS SPACING IS MAINTAINED. CABLE TRAY ADJUSTMENTS TO BE MADE TO MATCH EQUIPMENT AT NO ADDITIONAL COST TO THE OWNER.

KEYNOTES DETAIL 1/5104:

- 1 SSSR SOUTH WALL HIGH VOLTAGE CONDUIT ENTRY. REFER TO ELEVATION FOR EXACT LOCATION.
- 2 SSSR SOUTH WALL LOW VOLTAGE CONDUIT ENTRY. CABLE TRAYS FOR 120/208V, 480V AND 600V SWITCHBOARD. TRAYS TO BUTT UP AS CLOSE AS POSSIBLE TO WALL. CO-ORDINATE EXACT CABLE ARRANGEMENTS AND LAYOUT WITH CONDUCTOR BENDING AND SPACING REQUIREMENTS.
- 3 SSSR SOUTH WALL COMMUNICATION CONDUIT ENTRY. TRAYS TO BUTT UP AS CLOSE AS POSSIBLE TO WALL. CO-ORDINATE EXACT CABLE ARRANGEMENTS AND LAYOUT WITH CONDUCTOR BENDING AND SPACING REQUIREMENTS.
- 4 TRANSITION FROM 600V TO 120/208 CABLE TRAY
- 5 120/208V CABLE TRAYS OVER EACH OTHER. ENSURE TRAYS ARE NEATLY SUSPENDED AND ARRANGED TO ALLOW FOR LEVEL TRANSITIONS AND ENTRY IN SWITCHBOARDS. REFER TO SHEET 5105 TO CABLE TRAY ELEVATION DETAILS.
- 6 SSSR WEST WALL LOW VOLTAGE CONDUIT ENTRY. CABLE TRAYS FOR 120/208V AND 480V SWITCHBOARD. TRAYS TO BUTT UP AS CLOSE AS POSSIBLE TO WALL. CO-ORDINATE EXACT CABLE ARRANGEMENTS AND LAYOUT WITH CONDUCTOR BENDING AND SPACING. TRAYS MUST PASS UNDER ACCESS STAIRWAY. CO-ORDINATE TRAY ELEVATIONS WITH STAIRCASE TO ALLOW FOR ACCESS SPACING.
- 7 SSSR NORTH WALL LOW VOLTAGE CABLE TRAYS TO MERGE WITH WEST WALL TRAYS
- 8 SSSR EAST WALL 120/208V WINDOWS IN NEW FOUNDATION TO HOLES CORED IN EXISTING SSS SUBSTATION TUNNEL WALL. TRAYS TO BUTT UP AS CLOSE AS POSSIBLE TO WALL. CO-ORDINATE EXACT CABLE ARRANGEMENTS AND LAYOUT WITH CONDUCTOR BENDING AND SPACING.
- 9 SSSR SOUTH WALL 480V TRAY TO RUN BELOW 4SSSR-2 SWITCHBOARD.
- 10 SSSR EAST WALL 480V WINDOWS IN NEW FOUNDATION TO HOLES CORED IN EXISTING SSS SUBSTATION TUNNEL WALL. TRAYS TO BUTT UP AS CLOSE AS POSSIBLE TO WALL. CO-ORDINATE EXACT CABLE ARRANGEMENTS AND LAYOUT WITH CONDUCTOR BENDING AND SPACING.
- 11 SSSR NORTH WALL 480V TRAY TO MERGE WITH TRAYS UNDER 4SSSR-2 SWITCHBOARD.
- 12 SSSR WEST WALL COMMUNICATION TRAY TO MERGE WITH SOUTH WALL COMMUNICATION TRAYS.
- 13 SSSR WEST WALL 480V TRAY TO MERGE WITH TRAYS UNDER 4SSSR-2.
- 14 1x103mm EMT CONDUITS FROM SWITCHBOARD METERING AND CONTROL CABINETS. TO RUN TO NEARBY COMMUNICATIONS CABLE TRAYS AS SHOWN FOR DATA WIRING. CO-ORDINATE CONDUIT ROUTE WITH CABLE TRAY TO ALLOW FOR REQUIRED SPACING AND ACCESS.
- 15 SSSR NORTH WALL LOW VOLTAGE AND COMMUNICATION CONDUIT ENTRY. LOW VOLTAGE TRAYS TO BUTT UP AS CLOSE AS POSSIBLE TO WALL. CO-ORDINATE EXACT CABLE ARRANGEMENTS AND LAYOUT WITH CONDUCTOR BENDING AND SPACING. COMMUNICATION CABLES TO PASS DIRECTION INTO COMMUNICATION CABLE TRAY WHICH RUNS THE LENGTH OF THE NORTH WALL.
- 16 430-630V CABLE TRAY FROM NORTH WALL CONDUIT PENETRATION TO BASE OF 5SSSR-REG SWITCHBOARD.
- 17 CO-ORDINATE CABLE TRAY LOCATION AND LAYOUT WITH FLOOR PENETRATIONS INTO SSSR COMMUNICATIONS ROOM. ALL CABLE TO BE ARRANGED NEATLY FOR PASS-THROUGH INTO UPPER FLOOR.
- 18 SSSR 25/12.5KV PULL BOX. REFER TO ELEVATION DETAILS FOR ADDITIONAL INFORMATION
- 19 SSSR 2.4KV PULL BOX. REFER TO ELEVATION DETAILS FOR ADDITIONAL INFORMATION
- 20 SSSR 600V PULL BOX. REFER TO ELEVATION DETAILS FOR ADDITIONAL INFORMATION. CO-ORDINATE CONDUIT ROUTE WITH COMMUNICATIONS TRAY ALONG NORTH WALL TO ALLOW ENTRY IN 6SSSR-SP-1 SWITCHBOARD.



1 CABLE PIT ELECTRICAL DETAILS  
5104 SCALE 1:50



Revision/Revision	Description/Description	Date/Date
5	ISSUED FOR TENDER	15/01/28
4	ISSUED FOR 90% DESIGN REVIEW	16/01/06
3	ISSUED FOR 66% DESIGN REVIEW	15/11/25
2	ISSUED FOR 33% DESIGN REVIEW	15/10/28
1	ISSUED FOR DESIGN DEVELOPMENT	15/09/11
0		

Client/client

**ESQUIMALT GRAVING DOCK**

825 ADMIRALS ROAD VICTORIA, BC, V9A 2P1

Project title/Titre du projet  
**825 ADMIRALS ROAD VICTORIA BC ESQUIMALT GRAVING DOCK ELECTRICAL SAFETY UPGRADE**

**SOUTH SUBSTATION SWITCHGEAR REPLACEMENT (SSSR)**

Consultant Signature Box Only

Designed by/Concept par  
**I. BARNES**

Drawn by/Dessiné par  
**J. BIELING / S. SEYMOUR**



PWGSC Project Manager/Administrateur de Projets TPSGC  
**Jamie LeBlanc**

PWGSC, Regional Manager, Architectural and Engineering Services/  
Gestionnaire régionale, Services d'architecture et de génie, TPSGC  
**Preetpal Paul**

Drawing title/Titre du dessin

**CABLE PIT**


Project No./No. du projet	Sheet/Feuille	Revision no./Lo. Révision
R.062548.2	5104	5




5 BASEMENT WALL ELEVATION – EAST WALL  
5105 SCALE 1:20

KEY NOTES DETAIL 5/5105 AND 6/5105:


- 1 3#18 TECK CABLE TO SWITCHBOARD 4SSSR-2, 30 T CRANE TRENCH HEAT
- 2 2#18 TECK CABLE TO SWITCHBOARD 4SSSR-2, 30T CRANE PILOT WIRE
- 3 3x1#250KCM TECK CABLES TO SWITCHBOARD 4SSSR-2, 400A 480V #3 CENTER
- 4 3x1#250KCM TECK CABLES TO SWITCHBOARD 4SSSR-2, 400A 480V #3 SOUTHEAST
- 5 3x3#30 TECK CABLES TO SWITCHBOARD 4SSSR-2, NEW DS2-E 480V, 400A SERVICE
- 6 2#10 TECK CABLE TO SWITCHBOARD 2SSSR-SP-1, TUNNEL LIGHTS B
- 7 3#12 TECK CABLE TO SWITCHBOARD 2SSSR-SP-1M, PUMP REC. 25K 41 BLUE ALARM LIGHT
- 8 4#18 TECK CABLE TO SWITCHBOARD 2SSSR-SP-1, FUEL STATION GAS AND DIESEL SE DOCK
- 9 2#18 TECK CABLE TO SWITCHBOARD 2SSSR-SP-1, CABLE WINCH & BLUE ALARM LIGHTS
- 10 3#18 TECK CABLE TO SWITCHBOARD 2SSSR-SP-1, ROPE LOCKER
- 11 3#18 TECK CABLE TO SWITCHBOARD 2SSSR-SP-1, ROPE LIGHT AND SOUTHEAST DOCK STAIRS
- 12 2#18 TECK CABLE TO SWITCHBOARD 2SSSR-SP-1, TUNNEL LIGHTS AND EM BATTERY UNITS
- 13 3#12 TECK CABLE TO SWITCHBOARD 2SSSR-1, 125A 120/208V #3 SOUTHWEST
- 14 3#10, TECK CABLE TO SWITCHBOARD 2SSSR-1, 125A 120/208V #3 CENTER
- 15 3#30 TECK CABLE TO SWITCHBOARD 2SSSR-1, 125A 120/208V #3 SOUTHEAST
- 16 4#350KCM TECK CABLES TO SWITCHBOARD 2SSSR-1, NEW DS2-E 120/208 200A SERVICE
- 17 3#12 5KV TECK CABLE TO SWITCHBOARD 2.4SSSR-1, TO 30T CRANE
- 18 3#20 TECK CABLE TO SWITCHBOARD 6SSSR-SP-1, CAISSON POWER
- 19 2x3#4.0 TECK CABLES TO SWITCHBOARD 6SSSR-1, NEW DS2-E 600V 400A SERVICE




6 BASEMENT CABLE TRAY ENDS – EAST WALL  
5105 SCALE 1:20



1 CABLE TRAY FRONT RIGHT VIEW  
5105 NOT TO SCALE



2 CABLE TRAY BACK LEFT VIEW  
5105 NOT TO SCALE



Revision/Revision	Description/Description	Date/Date
5	ISSUED FOR TENDER	15/01/28
4	ISSUED FOR 90% DESIGN REVIEW	16/01/06
3	ISSUED FOR 66% DESIGN REVIEW	15/11/25
2	ISSUED FOR 33% DESIGN REVIEW	15/10/28
1	ISSUED FOR DESIGN DEVELOPMENT	15/09/11
0		

Client/client

**ESQUIMALT GRAVING DOCK**

825 ADMIRALS ROAD  
VICTORIA, BC, V9A 2P1

Project title/Titre du projet  
**825 ADMIRALS ROAD VICTORIA BC  
ESQUIMALT GRAVING DOCK  
ELECTRICAL SAFETY UPGRADE**

**SOUTH SUBSTATION  
SWITCHGEAR  
REPLACEMENT  
(SSSR)**

Consultant Signature Box Only

Designed by/Concept par  
**I. BARNES**

Drawn by/Dessiné par  
**J. BIELING / S. SEYMOUR**

PWGSC Project Manager/Administrateur de Projets TPSGC  
**Jamie LeBlanc**

PWGSC, Regional Manager, Architectural and Engineering Services/  
Gestionnaire régionale, Services d'architecture et de génie, TPSGC  
**Preetpal Paul**



Drawing title/Titre du dessin

**CABLE PIT TRAY AND WALL  
ELEVATIONS**


Project No./No. du projet	Sheet/Feuille	Revision no./ no. de révision
R.062548.2	5105	5








1 EXISTING TUNNEL NEW SPLICE BOXES PLAN VIEW SCALE 1:20




2 EXISTING TUNNEL NEW SPLICE BOXES PLAN VIEW WITH CONDUCTORS SCALE 1:20




3 EXISTING TUNNEL NEW SPLICE BOX ELEVATIONS SCALE 1:20

KEY NOTES

- 1 3x#8 TECK TUNNEL LIGHTING C-D 25K 8,10
- 2 2PR #18 INSTRUMENT CABLE
- 3 3x12PR #22 TEL TO DRYDOCK SECTIONS + 1EA 12X82.5 FIBER
- 4 1x100PR TELEPHONE TO PB 67 VIA PIPE #20 "SS-USL"
- 5 1xFIBER OPTIC CABLE TO PB 67 VIA PIPE #19
- 6 3x#250MCM MI CABLE 4SS2-11 #2 SOUTHWEST
- 7 3x#250MCM MI CABLE 4SS2-5 #1 SOUTHEAST
- 8 3x#250MCM MI CABLE 4SS2-6 #1 CENTER
- 9 3x#250MCM MI CABLE 4SS2-7 #1 SOUTHWEST
- 10 3x#3 MI CABLE 2SS2-6 #2 SOUTHWEST
- 11 3x#3 MI CABLE 2SS2-1 #1 SOUTHEAST
- 12 3x#1 MI CABLE 2SS2-2 #1 CENTER
- 13 3x#10 MI CABLE 2SS2-3 #1 SOUTHWEST
- 14 3x#10 MI CABLE 25K 33.35 SOUTHWEST DOCK STAIR ROPELIGHT
- 15 12mm FA DATA
- 16 12mm SCADA SYSTEM DATA 3C 16S8.
- 17 25mm EMT WITH 1-2C16 SHIELDED BELDEN
- 18 2x4SS2-71 -JM1 4c#350MCM
- 19 2x2SS2-61 -JM1 4c#350MCM
- 20 2x4SS2-72 -JM2 4c#350MCM
- 21 2x2SS2-62 -JM2 4c#350MCM
- 22 NOT USED
- 23 NOT USED
- 24 NOT USED
- 25 150mm Ø AIRLINE
- 26 4x#14 TECK 2000A BREAKER REMOTE TRIP/CLOSE FROM 2000A SPLITTER
- 27 4x#28 25K-29 & 31 FUEL STATION GAS AND DIESEL SE DOCK
- 28 3x#10 MI CABLE 30 T CRANE TRENCH HEAT 4SS2-21
- 29 2x#10 MI CABLE 25K 12 TUNNEL LIGHTS B
- 30 3x#10 MI CABLE 25K 17 CABLE WINCH & BLUE ALARM LIGHTS
- 31 3x#10 MI 25K 19-21 ROPE LOCKER
- 32 2x#10 MI CABLE 25K 14 TUNNEL LIGHTS AND EM BATTERY UNITS
- 33 2.4KV MS 5KV CARE CRANE SWBD. FEEDER, TO BE REMOVED
- 34 2x#12 TECK 25K 43 SCADA WATER METER SOUTH TUNNEL
- 35 2.4SS2 TECK 5KV TO 30T CRANE TO BE REPLACED WITH NEW FROM 2.4SSSR SWITCHBOARD
- 36 3x#20 TECK 1000V 6S82 CAISSON POWER TO BE REPLACED WITH NEW FROM 6SSSR-SP-1
- 37 2c PYROTEX 30T CRANE PILOT WIRE
- 38 2000A DRYDOCK 480V SPLITTER 4SSS 2-27 5x3x#250MCM MI
- 39 3x#12 TECK 25K 39 PUMP REC. 25K 41 BLUE ALARM LIGHT
- 40 3x#250MCM MI CABLE (3x1c#250CM TECK SPLICE) 4SS2-10 500A 480V #2 CENTER
- 41 3x#250MCM MI CABLE (3x1c#250CM TECK SPLICE) 4SS2-9 500A 480V #2 SOUTHEAST
- 42 3x#250MCM MI CABLE (3x1c#250CM TECK SPLICE) 4SS2-14 500A 480V #2 SOUTHWEST
- 43 3x#250MCM MI (3x1c#250CM TECK SPLICE) CABLE 4SS2-13 500A 480V #3 CENTER
- 44 3x#250MCM MI (3x1c#250CM TECK SPLICE) CABLE 4SS2-12 500A 480V #3 SOUTHWEST
- 45 3x#3 MI (3c#1 TECK SPLICE) CABLE 2SS2-5 125A 120/208V #2 SOUTH CENTER
- 46 3x#3 MI (3c#1 TECK SPLICE) CABLE 2SS2-4 125A 120/208V #2 SOUTHEAST
- 47 3x#3 MI (3c#1 TECK SPLICE) CABLE 2SS2-9 125A 120/208V #3 SOUTHWEST



4 EXISTING TUNNEL CABLE SECTION SCALE 1:20



5 REVISED TUNNEL CABLE SECTION SCALE 1:20

- 48 3c#1 MI (3c#20 TECK SPLICE) CABLE 2SS2-8 125A 120/208V #3 CENTER
- 49 3c#10 MI (3c#30 TECK SPLICE) CABLE 2SS2-7 125A 120/208V #3 SOUTHEAST
- 50 3c#10 (3c#5 TECK SPLICE) MI CABLE 25K 34 ROPE LIGHT AND SOUTHEAST DOCK STAIRS
- 51 CSA TYPE 3R MARINE GRADE ALUMINUM SPLICE BOX, TO BE MINIMUM DIMENSIONS SHOWN ON DRAWING. MOUNTED TO WALL OF EXISTING SERVICE TUNNEL TO BE SIDE ENTRY.
- 52 WALL PENETRATIONS TO BE CORED BETWEEN EXISTING SERVICE TUNNEL WALL AND FOUNDATION WINDOWS IN SSSR BUILDING. REFER TO SHEET 5106 FOR WINDOW ELEVATION DETAILS. (TYPICAL)
- 53 WALL PENETRATIONS TO BE A FORMED WINDOW IN CONCRETE FOUNDATION OF SSSR. (TYPICAL)
- 54 CSA TYPE 3R MARINE GRADE ALUMINUM SPLICE FOR, TO BE MINIMUM DIMENSIONS SHOWN ON DRAWING. MOUNTED TO WALL OF EXISTING SERVICE TUNNEL TO BE BOTTOM ENTRY.
- 55 CSA TYPE 3R MARINE GRADE ALUMINUM SPLICE FOR, TO BE MINIMUM DIMENSIONS SHOWN ON DRAWING. MOUNTED TO CEILING OF EXISTING SERVICE TUNNEL TO BE BOTTOM ENTRY.
- 56 TECK CABLE ARMORED WATERTIGHT GLAND CONNECTOR, FOR ENTRY OF TECK CABLES IN SERVICES BOXES, (TYPICAL FOR ALL TECK CABLES).
- 57 MINERAL INSULATED CABLE TO TECK CABLE SPLICE. FOLLOW MANUFACTURER'S RECOMMENDED GUIDELINES FOR CUTTING COPPER OUTER SHEATH, FORMING MINERAL INSULATION AND SPLICING INTERNAL CONDUCTORS. SPLICE COVER TO BE INSULATED HEAT SHRINK AND MUST BE WATERTIGHT. (TYPICAL FOR ALL MI-TECK SPLICES)
- 58 MINERAL INSULATED CABLE ARMORED WATERTIGHT CONNECTOR, FOR ENTRY OF MI CABLES INTO SERVICES BOXES, (TYPICAL FOR ALL MI CABLES).
- 59 FIRESTOP AND VAPOR SEAL CONDUITS AS REQUIRED.
- 60 NOT USED
- 61 SEPARATE MINERAL INSULATED CABLE PRIOR TO ENTRY INTO SERVICE BOX TO ALLOW WORKING ROOM AROUND WATER TIGHT CONNECTOR. (TYPICAL FOR ALL MI CABLES)
- 62 TECK TO TECK SPLICE, AS PER MANUFACTURER'S RECOMMENDED METHOD. TO BE HEAT SHRUNK AND WATERTIGHT SPLICE.
- 63 NEW DS2-E 480V, 400A SERVICE 3x3c#30 TECK CABLES MOUNTED TO EXISTING SERVICE TUNNEL WALLS. RUN CONDUIT FROM NEW 4SSSR-2 SWITCHBOARD TO NEW DS2-E DOCK SERVICE ASSEMBLY IN EXISTING SERVICE TUNNELS.
- 64 NEW DS2-E 600V, 400A SERVICE 2x3c#40 TECK CABLES MOUNTED TO EXISTING SERVICE TUNNEL WALLS. RUN CONDUIT FROM NEW 4SSSR-2 SWITCHBOARD TO NEW DS2-E DOCK SERVICE ASSEMBLY IN EXISTING SERVICE TUNNELS.
- 65 NEW DS2-E 120/208, 200A SERVICE 4c#350CM TECK CABLES MOUNTED TO EXISTING SERVICE TUNNEL WALLS. RUN CONDUIT FROM NEW 4SSSR-2 SWITCHBOARD TO NEW DS2-E DOCK SERVICE ASSEMBLY IN EXISTING SERVICE TUNNELS.
- 66 NEW DS2-E TELECOM SERVICES  
TEL -16PR#22  
DATA -4c#AT6  
FIBRE -FUTURE (PROVIDE SPACE)  
F/A -2x2c#12  
EMERGENCY -2X2C#12
- 67 EXISTING SERVICE CABLES TO BE DISCONNECT AND DEMOLISHED FROM BASE OF SSS SWITCHBOARD TO DOCK TUNNEL SERVICE BOXES OR TO SPLICE POINT INTO NEW DUCT BANK. REFER TO SHEET 5108 FOR DOCK TUNNEL SPLICE DETAILS.
- 68 EXISTING TECK CABLES TO BE MEGGER TESTED FOR RELIABILITY, DISMOUNTED FROM WALL AND PULLED VIA NEW DUCT BANK AND CABLE TRAYS AND RECONNECTED TO APPROPRIATE SWITCHBOARDS IN NEW SSSR SUBSTATION. REFER TO SHEET 5108 FOR DOCK TUNNEL TECK RELOCATION DETAILS.
- 69 EXISTING 24KV TECK FROM MAIN SUB-STATION TO SSS TO BE DEMOLISHED. REMOVE FROM ALL TUNNELS AND MAIN SUB-BREAKER RENAME AS SPARE.



Revision/Revision	Description/Description	Date/Date
5	ISSUED FOR TENDER	15/01/28
4	ISSUED FOR 90% DESIGN REVIEW	16/01/06
3	ISSUED FOR 66% DESIGN REVIEW	15/11/25
2	ISSUED FOR 33% DESIGN REVIEW	15/10/28
1	ISSUED FOR DESIGN DEVELOPMENT	15/09/11
0		

Client/client

**ESQUIMALT GRAVING DOCK**  
  
825 ADMIRALS ROAD  
VICTORIA, BC, V9A 2P1

Project title/Titre du projet  
**825 ADMIRALS ROAD VICTORIA BC  
ESQUIMALT GRAVING DOCK  
ELECTRICAL SAFETY UPGRADE**

**SOUTH SUBSTATION  
SWITCHGEAR  
REPLACEMENT  
(SSSR)**

Consultant Signature Box Only

Designed by/Concept par  
**I. BARNES**

Drawn by/Dessiné par  
**J. BIELING / S. SEYMOUR**

PWGSC Project Manager/Administrateur de Projets TPSGC  
**Jamie LeBlanc**



PWGSC, Regional Manager, Architectural and Engineering Services/  
Gestionnaire régionale, Services d'architecture et de génie, TPSGC  
**Preetpal Paul**

Drawing title/Titre du dessin


**EXISTING TUNNEL CABLE SPLICING  
AND PULL BOX DETAILS**

Project No./No. du projet	Sheet/Feuille	Revision no./no. de révision
<b>R.062548.2</b>	<b>5107</b>	<b>5</b>







1 SERVICE TUNNEL SPLICE BOX PLAN VIEW  
SCALE 1:20



2 SERVICE TUNNEL SPLICE BOX ELEVATION VIEW  
SCALE 1:20



3 SERVICE TUNNEL DUCT BANK ENTRY  
SCALE 1:20



4 SERVICE TUNNEL DUCT BANK ELEVATION  
SCALE 1:20




5 SERVICE TUNNEL EXISTING SERVICES  
SCALE 1:20

6 SERVICE TUNNEL TECK REMOUNTING  
SCALE 1:20

7 SERVICE TUNNEL AFTER SPLICE BOXES  
SCALE 1:20

8 SERVICE TUNNEL WITH NEW DS-2W  
SCALE 1:20



9 SERVICE TUNNEL WITH NEW DS-2C  
SCALE 1:20

- KEY NOTES:**
- 1. SPLICE BOX M1 CABLE END ENTRY DETAIL. ENSURE ADEQUATE WORKING SPACE AROUND MI CABLE WATERTIGHT CONNECT.
  - 2. 1220mmx700mmx340mm TYPE 3R MARINE GRADE ALUMINUM WALL MOUNTED SPLICE BOX. TO BE FRONT AND BOTTOM ACCESSIBLE VIA REMOVABLE PANELS AND C/W DRAINAGE HOLE IN BOTTOM OF BOX.
  - 3. MI TO TECK CABLE SPLICE. FOLLOW MANUFACTURERS RECOMMENDED GUIDELINES. SPLICE COVER TO BE HEAT SHRINK WATER TIGHT RUBBER.
  - 4. EXISTING COOLING WATER FEEDLINE TO REMAIN.
  - 5. EXISTING COMPRESSOR AIR LINE TO REMAIN.
  - 6. EXISTING POTABLE WATER LINE TO REMAIN.
  - 7. EXISTING SEWER LINE TO REMAIN.
  - 8. DUCT BANK CONDUIT ORIENTATION CHANGES BETWEEN SSSR AND ENTRY INTO SERVICE TUNNEL. THIS WILL REQUIRE ROTATION OF COMMUNICATION CONDUITS DURING INSTALLATION OF DUCT BANK.
  - 9. PROVIDE CABLE SUPPORT, SPACERS, AND ASSOCIATED HARDWARE TO ALLOW FOR NEAT, EASY TO MAINTAIN ENTRY INTO DUCT BANK FROM EXISTING TUNNEL. PROVIDE CHANNEL STEEL SUPPORT STRUCTURE TO ALLOW FOR CABLE CO-ORDINATION AND CROSSING. CARE MUST BE TAKEN TO COMPLY WITH CABLE BENDING RADIUS AND SUPPORT DISTANCE REQUIREMENTS.

CONDUIT AND CABLE SCHEDULE							
CONDUIT ROUTE	CONDUIT ID	SIZE (mm)	TYPE	SYSTEM NOMINAL VOLTAGE	NEW CONDUCTORS	EXISTING CONDUCTORS	COMMENTS
SSSR-SERVICE TUNNEL LV	1-1	129	LV	208V	REUSE EXISTING	4c#350KCM TECK	JM1 - 120/208V CIRCUIT
	1-2	129	LV	208V	REUSE EXISTING	4c#350KCM TECK	JM1 - 120/208V CIRCUIT
	1-3	103	LV	208V	3c#2/0 TECK	3c#1 MI CABLE	EXISTING DOCK SERVICES #1 CENTER
	1-4	103	LV	208V	3c#8 TECK	3c#10 MI CABLE	SOUTH WEST DOCK STAIR ROPELIGHT
	1-5	103	LV	120/208V	4c#350KCM	NEW SERVICE	120/208V, 400A DS2-W
	1-6	103	LV	480V	3c#4/0 TECK	3c#250KCM MI CABLE	EXISTING DOCK SERVICES #1 SOUTH WEST 1 OF 2
	1-7	103	LV	480V	3c#4/0 TECK	3c#250KCM MI CABLE	EXISTING DOCK SERVICES #1 CENTER 1 OF 2
	1-8	103	LV	480V	3c#4/0 TECK	3c#250KCM MI CABLE	EXISTING DOCK SERVICES #1 SOUTH EAST 1 OF 2
	1-9	103	LV	480V	3c#3/0	NEW SERVICE	480V, 400A DS2-W
	1-10	103	LV	480V	3c#3/0	NEW SERVICE	480V, 400A DS2-C
	1-11	103	LV	480V	3c#3/0	NEW SERVICE	480V, 400A DS2-C
	2-1	129	LV	208V	REUSE EXISTING	4c#350KCM TECK	JM2 - 120/208V CIRCUIT
	2-2	129	LV	208V	REUSE EXISTING	4c#350KCM TECK	JM2 - 120/208V CIRCUIT
	2-3	103	LV	208V	3c#2/0 TECK	3c#1 MI CABLE	EXISTING DOCK SERVICES #1 SOUTH EAST
	2-4	103	LV	208V	3c#3/0 TECK	3c#1/0 MI CABLE	EXISTING DOCK SERVICES #1 SOUTH WEST
	2-5	103	LV	120/208V	4c#350KCM	NEW SERVICE	120/208V, 400A DS2-C
	2-6	103	LV	480V	3c#4/0 TECK	3c#250KCM MI CABLE	EXISTING DOCK SERVICES #1 SOUTH WEST 2 OF 2
	2-7	103	LV	480V	3c#4/0 TECK	3c#250KCM MI CABLE	EXISTING DOCK SERVICES #1 CENTER 2 OF 2
	2-8	103	LV	480V	3c#4/0 TECK	3c#250KCM MI CABLE	EXISTING DOCK SERVICES #1 SOUTH EAST 2 OF 2
	2-9	129	LV	480V	3c#3/0	NEW SERVICE	480V, 400A DS2-W
	2-10	103	LV	480V	3c#3/0	NEW SERVICE	480V, 400A DS2-W
	2-11	129	LV	480V	3c#3/0	NEW SERVICE	480V, 400A DS2-C
	3-1	129	LV	430-630V	3c#500KCM TECK	NEW SERVICE	2000A REGULATED DOCK SERVICE, DS2-C
	3-2	129	LV	430-630V	3c#500KCM TECK	NEW SERVICE	2000A REGULATED DOCK SERVICE, DS2-C
	3-3	129	LV	430-630V	3c#500KCM TECK	NEW SERVICE	2000A REGULATED DOCK SERVICE, DS2-C
	3-4	129	LV	430-630V	3c#500KCM TECK	NEW SERVICE	2000A REGULATED DOCK SERVICE, DS2-C
	3-5	129	LV	408V	REUSE EXISTING	3c#350KCM TECK	JM1 - 480V CIRCUIT
	3-6	129	LV	408V	REUSE EXISTING	3c#350KCM TECK	JM1 - 480V CIRCUIT
	3-7	103	LV	600V	REUSE EXISTING	3c#2/0 TECK	600V CAISSON CONNECTION
	3-8	103	LV	600V	3c#4/0	NEW SERVICE	600V, 400A DS2-W
3-9	103	LV	600V	3c#4/0	NEW SERVICE	600V, 400A DS2-W	
3-10	103	LV	600V	FUTURE	NEW SERVICE	FUTURE HIGH MAST #1	
3-11	103	LV	N/A	FUTURE	NEW SERVICE	SPARE	
4-1	129	LV	430-630V	3c#500KCM TECK	NEW SERVICE	2000A REGULATED DOCK SERVICE, DS2-C	
4-2	129	LV	430-630V	3c#500KCM TECK	NEW SERVICE	2000A REGULATED DOCK SERVICE, DS2-C	
4-3	129	LV	430-630V	3c#500KCM TECK	NEW SERVICE	2000A REGULATED DOCK SERVICE, DS2-C	
4-4	129	LV	430-630V	3c#500KCM TECK	NEW SERVICE	2000A REGULATED DOCK SERVICE, DS2-C	
4-5	129	LV	408V	REUSE EXISTING	3c#350KCM TECK	JM2 - 480V CIRCUIT	
4-6	129	LV	408V	REUSE EXISTING	3c#350KCM TECK	JM2 - 480V CIRCUIT	
4-7	103	LV	N/A	FUTURE	NEW SERVICE	SPARE	
4-8	103	LV	N/A	FUTURE	NEW SERVICE	SPARE	
4-9	103	LV	N/A	FUTURE	NEW SERVICE	SPARE	
4-10	103	LV	N/A	FUTURE	NEW SERVICE	SPARE	
4-11	103	LV	N/A	FUTURE	NEW SERVICE	SPARE	
SSSR-SERVICE TUNNEL COMM.	1-1	103	COMM	N/A	4xCAT5e	NEW SERVICE	DS2-W DATA SERVICES
	1-2	103	COMM	N/A	16PR#22	NEW SERVICE	DS2-W COMM SERVICES
	1-3	103	COMM	N/A	FUTURE	NEW SERVICE	DS2-W FIBRE SERVICES
	2-1	103	COMM	N/A	4xCAT5e	NEW SERVICE	DS2-C DATA SERVICES
	2-2	103	COMM	N/A	16PR#22	NEW SERVICE	DS2-C COMM SERVICES
	2-3	103	COMM	N/A	FUTURE	NEW SERVICE	DS2-C FIBRE SERVICES
	3-1	27	COMM	N/A	2x2#12	NEW SERVICE	DS2-W F/A SERVICES
3-2	27	COMM	N/A	2x2#12	NEW SERVICE	DS2-W EMERGENCY SERVICES	
3-3	103	COMM	N/A	SPARE	NEW SERVICE	FUTURE (FIBRE ONLY)	
4-1	27	COMM	N/A	2x2#12	NEW SERVICE	DS2-C F/A SERVICES	
4-2	27	COMM	N/A	2x2#12	NEW SERVICE	DS2-C EMERGENCY SERVICES	
4-3	103	COMM	N/A	SPARE	NEW SERVICE	FUTURE (FIBRE ONLY)	

Revision/Revisions	Description/Description	Date/Date
5	ISSUED FOR TENDER	15/01/28
4	ISSUED FOR 90% DESIGN REVIEW	16/01/06
3	ISSUED FOR 66% DESIGN REVIEW	15/11/25
2	ISSUED FOR 33% DESIGN REVIEW	15/10/28
1	ISSUED FOR DESIGN DEVELOPMENT	15/09/11
0		

**ESQUIMALT GRAVING DOCK**

825 ADMIRALS ROAD  
VICTORIA, BC, V9A 2P1

Project title/Titre du projet  
**825 ADMIRALS ROAD VICTORIA BC  
ESQUIMALT GRAVING DOCK  
ELECTRICAL SAFETY UPGRADE**

**SOUTH SUBSTATION  
SWITCHGEAR  
REPLACEMENT  
(SSSR)**

Consultant Signature Box Only

Designed by/Concept par  
**I. BARNES**






Drawn by/Dessiné par  
**J. BIELING / S. SEYMOUR**

PWSC Project Manager/Administrateur de Projets TPSGC  
**Jamie LeBlanc**

PWSC, Regional Manager, Architectural and Engineering Services/  
Gestionnaire régionale, Services d'architecture et de génie, TPSGC  
**Preetpal Paul**

**DOCK SERVICE TUNNEL CABLE AND  
CONDUIT WORK**





**GENERAL PHASING NOTES**  
1. MOUNT RECEPTACLE 600mm A.F.F.

**KEY NOTES:**

- 129mm COMMUNICATION SLEEVE BETWEEN TELECOM ROOM AND SSSR CABLE PIT. ENSURE SLEEVES ARE PROPERLY SEALED TO PREVENT WATER/VAPOUR MOVEMENT AFTER INSTALLATION OF ALL COMMUNICATION CABLES. (TYPICAL).
- IF ANY SERVER RACKS ARE REMOVED FROM THIS CONTRACT INSTALL JUNCTION BOXES WITH FOURPLEX CIRCUIT CONDUCTORS PRE PULLED AND TERMINATED IN JUNCTION BOXES. FOR FUTURE DROPS INTO RACKS. (TYPICAL).



Revision/	Description/Description	Date/Date
5	ISSUED FOR TENDER	15/01/28
4	ISSUED FOR 90% DESIGN REVIEW	16/01/06
3	ISSUED FOR 66% DESIGN REVIEW	15/11/25
2	ISSUED FOR 33% DESIGN REVIEW	15/10/28
1	ISSUED FOR DESIGN DEVELOPMENT	15/09/11
0		

Client/client

**ESQUIMALT GRAVING DOCK**

825 ADMIRALS ROAD  
VICTORIA, BC, V9A 2P1

Project title/Titre du projet  
**825 ADMIRALS ROAD VICTORIA BC  
ESQUIMALT GRAVING DOCK  
ELECTRICAL SAFETY UPGRADE**

**SOUTH SUBSTATION  
SWITCHGEAR  
REPLACEMENT  
(SSSR)**

Consultant Signature Box Only

Designed by/Concept par  
**I. BARNES**

Drawn by/Dessiné par  
**J. BIELING / S. SEYMOUR**

PWGSC Project Manager/Administrateur de Projets TPSGC  
**Jamie LeBlanc**

PWGSC, Regional Manager, Architectural and Engineering Services/  
Gestionnaire régionale, Services d'architecture et de génie, TPSGC  
**Preetpal Paul**


Drawing title/Titre du dessin

**SSSR  
ELECTRICAL SERVICES**


Project No./No. du projet  
**R.062548.2**

Sheet/Feuille  
**5109**


Revision no./  
no. de révision  
**5**




- GENERAL NOTES FOR EGD NEW FIRE ALARM SYSTEM:**
1. PROVIDE 35mm RPVC RACEWAYS AND 250x250x150RPVC PULL BOXES IN EACH MANHOLE TO SEPARATE FIRE ALARM SYSTEM WIRING FROM OTHER COMMS SYSTEMS WIRING.
  2. REPLACE THE EXISTING GRAPHIC ANNUNCIATOR AT MAIN GATE WITH A NEW UPDATED GRAPHIC. PROVIDE ALL NEW DRIVERS AND COMPONENTS REQUIRED TO INTERFACE WITH THE EXISTING EDWARDS EST 3 PANEL. RE-USE EXISTING CPU, DRIVERS, BOOSTERS ETC. ADD ADDITIONAL LEDs AS REQUIRED.
  3. PROVIDE REQUIRED BOOSTER PANELS FOR NOTIFICATION DEVICES AND ISOLATION MODULES FOR THE NEW DATA LOOP.
  4. PROVIDE POWER SUPPLY FOR THE GRAPHIC ANNUNCIATOR FROM BOOSTER PANEL.
  5. TIE IN EXISTING BUILDINGS TO NEW DATA LOOP.
  6. REPROGRAM EXISTING DEVICES TO NEW ADDRESSABLE LOOP AS REQUIRED.




2 SSSR NEW FIRE ALARM SYSTEM  
5110 NTS




1 SSSR ACCESS CONTROL SYSTEM  
5110 NTS



4 SSSR DATA RACK ELEVATION  
5110 NTS



3 SSSR BIX BOARD ELEVATION  
5110 NTS



5 SSSR SCADA PANEL ELEVATION  
5110 NTS

Revision/Revisions	Description/Description	Date/Date
5	ISSUED FOR TENDER	15/01/28
4	ISSUED FOR 99% DESIGN REVIEW	16/01/06
3	ISSUED FOR 66% DESIGN REVIEW	15/11/25
2	ISSUED FOR 33% DESIGN REVIEW	15/10/28
1	ISSUED FOR DESIGN DEVELOPMENT	15/09/11
0		


Client/client  
**ESQUIMALT GRAVING DOCK**  
825 ADMIRALS ROAD  
VICTORIA, BC, V9A 2P1  
Project title/Titre du projet  
**825 ADMIRALS ROAD VICTORIA BC  
ESQUIMALT GRAVING DOCK  
ELECTRICAL SAFETY UPGRADE**  
**SOUTH SUBSTATION  
SWITCHGEAR  
REPLACEMENT  
(SSSR)**

Consultant Signature Box Only  
Designed by/Concept par  
**I. BARNES**  
Drawn by/Dessiné par  
**J. BIELING / S. SEYMOUR**  
PWGSC Project Manager/Administrateur de Projets TPSGC  
**Jamie LeBlanc**  
PWGSC Regional Manager, Architectural and Engineering Services/  
Gestionnaire régionale, Services d'architectural et de génie, TPSGC  
**Preetpal Paul**

Drawing title/Titre du dessin  
**SECURITY, COMMUNICATIONS AND  
SCADA SYSTEM DETAILS**

Project No./No. du projet	Sheet/Feuille	Revision no./ La Révision no.
<b>R.062548.2</b>	<b>5110</b>	<b>5</b>





**SOUTH SIDE SUBSTATION REPLACEMENT MECHANICAL EQUIPMENT SCHEDULE**

Q #	DESCRIPTION	EQUIPMENT LOCATION	LOAD			VOLTS	UNIT			STARTER			DISC.			CONTROL			SUPPLY PANEL			WIRE & CONDUIT			NOTE												
			MCA	KW	HP		PHASE	SUPPLY	MOUNT	CONNECT	TYPE	FIRE ALARM	PANEL #	PANEL LOCATION	AMPS		P	CCT NO'S	WIRE SIZE	NO.	CONDUIT SIZE (mm)	TOTAL AMPS															
IAC-1	INDOOR EVAPORATOR	SSSR COMM. ROOM	-	-	FRAC	208	1	M	M	E	M	M	M	M	M	M	M	M	M	M	M	M	M	M	INT	-	-	2SSSR-SP-1	SSSR MAIN FLOOR	40	1	1,3	8	4	21	-	1,5
CU-1	CONDENSING UNIT	SSSR WEST EXTERIOR	-	-	-	208	1	M	M	E	M	M	M	M	M	M	M	M	M	M	M	M	M	M	INT	-	-	2SSSR-SP-1	SSSR MAIN FLOOR	15	1	42	12	3	21	2,2	2
CP-1	CONDENSATE PUMP	SSSR COMM. ROOM	-	-	FRAC	120	1	M	M	E	M	M	M	M	M	M	M	M	M	M	M	M	M	M	INT	-	-	2SSSR-SP-1	SSSR MAIN FLOOR	15	1	44	10	3	21	2,2	4
SF-1	SUPPLY FAN	SSSR MAIN FLOOR	-	-	5	600	3	M	M	E	M	M	M	M	M	M	M	M	M	M	M	M	M	M	INT	-	-	6SSSR-SP-1	SSSR MAIN FLOOR	15	3	22,24,26	12	12	21	6,1	-
SF-2	SUPPLY FAN	SSSR MAIN FLOOR	-	-	FRAC	120	1	M	M	E	M	M	M	M	M	M	M	M	M	M	M	M	M	M	INT	-	-	2SSSR-SP-1	SSSR MAIN FLOOR	15	1	44	10	3	21	2,2	4
AHU-1	AIR HANDLING UNIT	SSSR ROOF	-	-	25	600	3	M	M	E	M	M	M	M	M	M	M	M	M	M	M	M	M	M	INT	-	-	6SSSR-SP-1	SSSR MAIN FLOOR	70	3	28,30,32	4	4	35	35	2,3
EHU-1	ELECTRIC UNIT HEATER	SSSR MAIN FLOOR	-	5.0	-	600	1	M	M	E	M	M	M	M	M	M	M	M	M	M	M	M	M	M	INT	-	-	6SSSR-SP-1	SSSR MAIN FLOOR	30	3	34,36,38	10	3	21	8,3	-
EHU-2	ELECTRIC UNIT HEATER	SSSR MAIN FLOOR	-	5.0	-	600	1	M	M	E	M	M	M	M	M	M	M	M	M	M	M	M	M	M	INT	-	-	6SSSR-SP-1	SSSR MAIN FLOOR	30	3	40,42,44	10	3	21	8,3	-
EHU-3	ELECTRIC UNIT HEATER	SSSR SECOND FLOOR	-	5.0	-	600	1	M	M	E	M	M	M	M	M	M	M	M	M	M	M	M	M	M	INT	-	-	6SSSR-SP-1	SSSR MAIN FLOOR	30	3	46,48,50	10	3	21	8,3	-
EHU-4	ELECTRIC UNIT HEATER	SSSR SECOND FLOOR	-	5.0	-	600	1	M	M	E	M	M	M	M	M	M	M	M	M	M	M	M	M	M	INT	-	-	6SSSR-SP-1	SSSR MAIN FLOOR	30	3	52,54,56	10	3	21	8,3	-
BBH-1	BASEBOARD HEATER	SSSR COMM. ROOM	-	1	-	120	1	M	M	E	M	M	M	M	M	M	M	M	M	M	M	M	M	M	INT	-	-	2SSSR-SP-1	SSSR MAIN FLOOR	15	1	25	12	3	21	8,3	5
CTRL-1	CONTROL PANEL	SSSR COMM. ROOM	-	-	-	120	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	2SSSR-SP-1	SSSR MAIN FLOOR	15	1	27	12	3	21	2,2	2	
TP	ELEC TRAP PRIMER	SSSR CABLE PIT	-	-	FRAC	120	1	M	M	E	M	M	M	M	M	M	M	M	M	M	M	M	M	M	INT	-	-	2SSSR-SP-1	SSSR MAIN FLOOR	15	1	29	12	3	21	2,2	-
P-1	SUMP PUMP	SSSR CABLE PIT	-	-	.5	208	3	M	M	E	M	M	M	M	M	M	M	M	M	M	M	M	M	M	INT	-	-	2SSSR-SP-1	SSSR MAIN FLOOR	15	3	39,41,43	10	4	21	2,4	-
P-2	SUMP PUMP	SSSR CABLE PIT	-	-	.5	208	3	M	M	E	M	M	M	M	M	M	M	M	M	M	M	M	M	M	INT	-	-	2SSSR-SP-1	SSSR MAIN FLOOR	15	3	45,47,49	10	4	21	2,4	-
MAU-1	MAKE UP AIR UNIT	SSSR MAIN FLOOR	-	20	-	600	3	M	M	E	M	M	M	M	M	M	M	M	M	M	M	M	M	M	INT	-	-	6SSSR-SP-1	SSSR MAIN FLOOR	25	3	31,33,35	10	4	21	19,3	-

E DENOTES BY ELECTRICAL CONTRACTOR  
 T = THERMOSTAT  
 HOA = MAGNETIC STARTER WITH HAND-OFF-AUTO SELECTOR  
 SW = H.P. RATED SWITCH  
 DDC = DIRECT DIGITAL CONTROL  
 INT = DEVICE IS INTEGRAL TO EQUIPMENT SUPPLIED BY MECHANICAL CONTRACTOR  
 FLOW = FLOW SWITCH  
 MOT = MOTION DETECTOR

NOTES  
 1. DIVISION 26 TO PROVIDE WEATHERPROOF DISCONNECT SWITCH AND SINGLE POINT POWER CONNECT AT OUTDOOR UNIT. PROVIDE LINE VOLTAGE POWER WIRING BETWEEN INDOOR AND OUTDOOR UNITS.  
 2. DIVISION 26 TO PROVIDE DEDICATED ELECTRICAL RECEPTACLE ADJACENT TO DEVICE.  
 3. PROVIDE SEPARATE 120V CCT FOR CONTROLS  
 4. MOTION SENSOR CONTROLLED  
 5. INTERLOCK TO PREVENT SIMULTANEOUS OPERATION  
 CONFIRM ALL BREAKER SIZES WITH MECHANICAL SHOP DRAWINGS AND REVISE BREAKER SIZES AS NEEDED AT NO ADDITIONAL COST.

**LUMINAIRE SCHEDULE (ALL NEW FIXTURES TO BE 120V/240V)**

TYPE	EXAMPLE REPLACEMENT FIXTURE PICTURES	REPLACEMENT FIXTURE PERFORMANCE REQUIREMENTS	WIRE SIZE		NO.	CONDUIT SIZE (mm)	TOTAL AMPS	NOTE		
			WIRE SIZE	NO.						
LA		3000 LUMEN, 3500K, 80CRI LED SUSPENDED 4' STRIP LIGHT CW DIFFUSER LENS. L70 AT MINIMUM 100,000 HOURS.	15	1	42	12	3	21	2,2	2
LB		4500 LUMEN, 3500K, 70CRI LED DIE CAST ALUMINUM IP66 BUILDING MOUNTED FIXTURE WITH IES TYPE III DISTRIBUTION CORROSION RESISTANT HOUSING WITH MOLDED ACRYLIC LENS. L80 AT MINIMUM 100,000 HOURS. SUITABLE FOR OPERATION AT -20°C. DARK SKY RATED	30	3	34,36,38	10	3	21	8,3	-
LC		3000 LUMEN, 3500K, 80CRI LED KIOSK MOUNTED 4' STRIP LIGHT CW DIFFUSER LENS. L70 AT MINIMUM 100,000 HOURS.	15	1	27	12	3	21	2,2	2
LD		1500 LUMEN, 3500K, 80CRI LED KIOSK MOUNTED 2' STRIP LIGHT CW DIFFUSER LENS. L70 AT MINIMUM 100,000 HOURS.	15	1	29	12	3	21	2,2	-
LE		1200 LUMEN/METER, 3000K, 70CRI IP 66 RATED STRIP LIGHT FOR DOCK SERVICE ASSEMBLES. L70 AT MINIMUM 100,000 HOURS.	15	3	39,41,43	10	4	21	2,4	-
			15	3	45,47,49	10	4	21	2,4	-
			25	3	31,33,35	10	4	21	19,3	-

ALL FIXTURES TO HAVE MINIMUM 10 YEAR WARRANTY

**PANELBOARD SCHEDULE**

DESCRIPTION	BRK	POLE	CCT	POLE	BRK	DESCRIPTION
SSSR MAIN FLOOR LTS	15	1	01	02	1	SSSR MAIN FLOOR REC.
SSSR COMM ROOM LTS	15	1	03	04	1	SSSR MAIN FLOOR REC.
SSSR 2ND FLOOR LTS	15	1	05	06	1	SSSR COMM. REC. #1
SSSR CABLE PIT LTS	15	1	07	08	1	SSSR COMM. REC. #2
SSSR OUTDOOR LTS	15	1	09	10	1	SSSR COMM. REC. #3
SSSR EXIT LTS	15	1	11	12	1	SSSR COMM. REC. #4
SSSR LOCKS/OPEN	15	1	13	14	1	SSSR COMM. REC. #5
SSSR MOTOR DAMPERS	20	1	15	16	1	SSSR 2ND FL REC.
SW DRYDOK STAIRS	15	1	17	18	1	SSSR 2ND FL REC.
SE DRYDOK STAIRS	15	1	19	20	1	SSSR CABLE PIT REC.
IAC-1/CU-1	40	2	21	22	3	TUG #1
			23	24		
BBH-1	15	1	25	26		
MEQ. CONTROL PANEL	15	1	27	28	3	TUG #2
SPARE	15	1	29	30		
TP	15	1	31	32		
AHU-1 CONTROLS	15	1	33	34	2	TUG REC.
SECURITY ALARM PANEL	15	1	35	36		
FIRE ALARM PANEL	15	1	37	38	2	TUG REC.
P-1	15	3	39	40		
			41	42	1	CTRL-1
			43	44	1	SF-2
P-2	15	3	45	46	2	PANEL '2SL'
			47	48		
			49	50	3	PANEL '2K'
SSSR DDC SYSTEM	30	1	51	52		
SSSR BATTERY PACK	15	1	53	54		
SPARE	15	1	55	56	3	PANEL '2SM'
SPARE	15	1	57	58		
SPARE	15	1	59	60		

**PANELBOARD SCHEDULE**


DESCRIPTION	BRK	POLE	CCT	POLE	BRK	DESCRIPTION
SEWAGE PUMP	100	3	01	02	3	20 SPARE
			03	04		
			05	06		
SPARE	15	3	07	08	3	20 SPARE
			09	10		
			11	12		
SPARE	15	3	13	14	3	20 SPARE
			15	16		
			17	18		
SPARE	15	3	19	20	3	20 SPARE
			21	22		
			23	24		
SPARE	15	3	25	26	3	20 SPARE
			27	28		
			29	30		
SPARE	15	3	31	32	3	20 SPARE
			33	34		
			35	36		
			37	38		
			39	40		
			41	42		
			43	44		
			45	46		
			47	48		
			49	50		
			51	52		
			53	54		
			55	56		
			57	58	1	15 SPARE
			59	60	1	15 SPARE

**PANELBOARD SCHEDULE**


DESCRIPTION	BRK	POLE	CCT	POLE	BRK	DESCRIPTION
4SSSR-SP-1 XFMR	200	3	01	02	3	150 2SSSR-SP-1 XFMR
			03	04		
			05	06		
CAISSONS 2, 3	175	3	07	08	1	15 JETTY EAST CAT. PRO.
			09	10	1	15 JETTY WEST CAT. PRO.
			11	12	3	100 SSSR HIGH MAST LIGHTING CONTROLLER
CAISSON 1	175	3	13	14		
			15	16		
			17	18	2	30 125VDC STATION
LIFT STATION C.P.	15	3	19	20		
			21	22	3	15 SF-1
			23	24		
LIFT STATION C.P.	15	3	25	26		
			27	28	3	70 AHU-1
			29	30		
MAU-1	25	3	31	32		
			33	34	3	15 EUH-1
			35	36		
SPARE	15	3	37	38		
			39	40	3	15 EUH-2
			41	42		
SPARE	15	3	43	44		
			45	46	3	15 EUH-3
			47	48		
SPARE	20	3	49	50		
			51	52	3	15 EUH-4
			53	54		
SPARE	20	3	55	56		
			57	58	1	15 SPARE
			59	60	1	15 SPARE

SSSR SWITCHGEAR SCHEDULE									
VOLTAGE		CELL NO.	EQ	DESCRIPTION OF USE	RELAY	METER	NAMEPLATE		
RATED	USED						ENGRAVING	SIZE	
25KV	12.5KV	1	TOP	VCB	3000/4000kVA TRANSFORMER (480V)	MFP	DMS 2	250mmX 70mm	
			BOT	VCB	750/1000kVA TRANSFORMER (2.4kV)	MFP	DMS 2		
		2	TOP	-	SPACE				
			BOT	VCB	SPARE				
		3	TOP	VCB	SPARE				
			BOT	VCB	LVSP #6: (MULTI-SWITCH)		DMS 2		
		4	TOP	VCB	2250/3000kVA TRANSFORMER (600V)	MFP	DMS 2		
			BOT	VCB	750/1000kVA TRANSFORMER (120/208V)	MFP	DMS 2		
		5	TOP	VCB	LVSP #3: (MULTI-SWITCH)		DMS 2		
			BOT	VCB	LVSP #4: HV REG & 1000/1500kVA XFMR (450-630V SHIP POWER)	MFP	DMS 2		
		6	TOP	VCB	LVSP #5: (MULTI-SWITCH)		DMS 2		
			BOT	VCB	EXISTING SOUTHSIDE SUB (TEMP 12.5KV)	MFP			
		5KV	2.4KV	7	TOP	VT	BUS VOLTAGE		
					CT	BUS LOAD			
BOT	VCB			FROM SES	MFP	DMS 2			
TOP	VT			FUSED VTS					
1	2	TOP	VCB	FROM 750/1000kVA TRANSFORMER (2.4kV)	MFP	DMS 2			
		BOT	VCB	SPARE					
2	2	TOP	VCB	SPARE					
		BOT	VCB	30 T CRANE	MFP	DMS 2			


1 SWITCHGEAR SCHEDULE  
5112 N.T.S.



2 25/12.5kV METAL CLAD SWITCHGEAR ELEVATION  
5112 SCALE 1:25



3 5kV METAL CLAD SWITCHGEAR ELEVATION  
5112 SCALE 1:25



4 CUT SECTION ELEVATION  
5112 SCALE 1:25


GENERAL NOTES:  
1. REFER TO DRAWING 5010 FOR SINGLE LINE DIAGRAM.

KEYNOTES:  
○ POTENTIAL TRANSFORMER PRIMARY TO MATCH AVAILABLE VOLTAGE  
○ SECONDARY VOLTAGE (120VAC) IS COMMON TO ALL METERING IN RESPECTIVE CELLS

Public Works and Government Services Canada | Travaux publics et Services gouvernementaux Canada

REAL PROPERTY SERVICES  
Pacific Region  
SERVICES IMMOBILIERS  
Region de Pacifique

CALGARY | VANCOUVER | VICTORIA  
Designing A Better Tomorrow



Revision/Revision	Description/Description	Date/Date
5	ISSUED FOR TENDER	15/01/28
4	ISSUED FOR 90% DESIGN REVIEW	16/01/06
3	ISSUED FOR 66% DESIGN REVIEW	15/11/25
2	ISSUED FOR 33% DESIGN REVIEW	15/10/28
1	ISSUED FOR DESIGN DEVELOPMENT	15/09/11
0		

Client/client

**ESQUIMALT GRAVING DOCK**

825 ADMIRALS ROAD  
VICTORIA, BC, V9A 2P1

Project title/Titre du projet  
825 ADMIRALS ROAD VICTORIA BC  
ESQUIMALT GRAVING DOCK  
ELECTRICAL SAFETY UPGRADE

**SOUTH SUBSTATION SWITCHGEAR REPLACEMENT (SSSR)**

Consultant Signature Box Only

Designed by/Concept par  
**I. BARNES**

Drawn by/Dessiné par  
**J. BIELING / S. SEYMOUR**

PWGSC Project Manager/Administrateur de Projets TPSGC  
**Jamie LeBlanc**

PWGSC, Regional Manager, Architectural and Engineering Services/  
Gestionnaire régionale, Services d'architecture et de génie, TPSGC  
**Preetpal Paul**



Drawing title/Titre du dessin

**HIGH VOLTAGE SWITCHGEAR DETAILS AND ELEVATIONS**


Project No./No. du projet	Sheet/Feuille	Revision no./no. de révision
R.062548.2	5112	5



GENERAL NOTES:  
 1. REFER TO DRAWING 5011 FOR SINGLE LINE DIAGRAM.  
 2. DIMENSIONS ARE PRELIMINARY AND FOR ILLUSTRATIVE PURPOSES ONLY. CONFIRM ALL DIMENSIONS WITH MANUFACTURER SHOP DRAWINGS AND CONFIRM SPACE AND SEPARATION DISTANCES AND CORRECT AS REQUIRED AT NO ADDITIONAL COST.



1  
5113  
SSSR STANDBY POWER PANELS ELEVATION 1



2  
5113  
SSSR STANDBY POWER PANELS ELEVATION 2

5	ISSUED FOR TENDER	15/01/28
4	ISSUED FOR 99% DESIGN REVIEW	16/01/06
3	ISSUED FOR 66% DESIGN REVIEW	15/11/25
2	ISSUED FOR 33% DESIGN REVIEW	15/10/28
1	ISSUED FOR DESIGN DEVELOPMENT	15/09/11
0		

Revision/	Description/Description	Date/Date
-----------	-------------------------	-----------

Client/client

**ESQUIMALT GRAVING DOCK**

**825 ADMIRALS ROAD VICTORIA, BC, V9A 2P1**

Project title/Titre du projet  
**825 ADMIRALS ROAD VICTORIA BC ESQUIMALT GRAVING DOCK ELECTRICAL SAFETY UPGRADE**

**SOUTH SUBSTATION SWITCHGEAR REPLACEMENT (SSSR)**

Consultant Signature Box Only

Designed by/Concept par  
**I. BARNES**

Drawn by/Dessiné par  
**J. BIELING / S. SEYMOUR**

PWCSG Project Manager/Administrateur de Projets TPSGC  
**Jamie LeBlanc**

PWCSG Regional Manager, Architectural and Engineering Services/  
 Gestionnaire régionale, Services d'architecture et de génie, TPSGC  
**Preetpal Paul**

Drawing title/Titre du dessin

**LOW VOLTAGE STANDBY POWER PANELS DETAILS AND ELEVATIONS**

Project No./No. du projet <b>R.062548.2</b>	Sheet/Feuille <b>5113</b>	Revision no./ La Révision no. <b>5</b>
--	------------------------------	--




**GENERAL PHASING NOTES AND PROPOSED SEQUENCE OF WORK**


1. ALL OUTAGES ARE TO BE OF MINIMAL DISRUPTION TO THE DOCK OPERATIONS AND ARE TO BE DONE DURING OFF HOURS WHENEVER POSSIBLE.
2. WHEN TRANSITIONING FROM THE SSS TO THE SSSR, ALL REQUIRED SUPPORTING WORKS OR INFRASTRUCTURE MUST BE COMPLETED, TESTED AND OPERATIONAL IN ADVANCE OF THE SWITCHOVER.
3. AS CONSTRUCTION PROGRESS POWER SHALL NOT BE INTERRUPTED TO EXISTING OPERATIONS.

**KEY NOTES:**


1. EXISTING 350kW 600V 3Ø GENERATOR. DURING CONSTRUCTION OF NEW SSSR BUILDING THIS EXISTING STRUCTURE WILL REQUIRE FOUNDATION WORK, DEFUEL AND TEMPORARILY DECOMMISSION AND DISCONNECT EXISTING 350kW GENERATOR. PROVIDE TEMPORARY 50kW PORTABLE GENERATOR CONNECTED TO EXISTING AUTOMATIC TRANSFER SWITCH AND GENERATOR AUTO-START CONTACTOR. PROVIDE TEMPORARY BREAKER FOR GENERATOR PROTECTION AND CO-ORDINATION. AFTER FOUNDATION WORK IS COMPLETE REFUEL, RECONNECT AND RECOMMISSION EXISTING GENERATOR.
2. EXISTING PANEL '2SL'. TO BE RECONNECTED TO NEW SSSR BUILDING.
3. NEW 4c#6 TECK IN NEW 53mm EMT CONDUIT FROM NEW CABLE TRAY TO EXISTING PANEL '2SL'
4. NEW 2x350KCM TECK FROM NEW CABLE TRAY TO EXISTING AUTOMATIC TRANSFER SWITCH, STANDBY POWER FROM GENERATOR TO 6SSSR-SP-1
5. NEW 2x350KCM TECK FROM NEW CABLE TRAY TO EXISTING AUTOMATIC TRANSFER SWITCH, NORMAL POWER FEED FROM PANEL 6SSSR.
6. EXISTING 600V 600A 3Ø 4W TRANSFER SWITCH TO REMAIN. CONNECT NEW FEEDERS TO EXISTING TERMINAL LUGS AND TEST TRANSFER SWITCH AND GENERATOR OPERATION.
7. CREATE WINDOW IN EXISTING GENERATOR BUILDING BRICK WORK TO ALLOW FOR INSTALLATION OF NEW ANGLED LADDER TYPE CABLE TRAY. REFER TO CUT SECTION 25114 FOR CABLE AND CONDUIT LAYOUT IN CABLE TRAY. ENSURE WINDOW PENETRATION IS FILLED AND SEALED AFTER INSTALLATION OF CONDUITS AND CABLES.
8. NEW 600x100mm OUTDOOR RATED LADDER TYPE CABLE TRAY RUN BETWEEN EXISTING GENERATOR BUILDING AND NEW SSSR BUILDING. COORDINATE PENETRATION WITH NEW BUILDING TO ALLOW FOR ALL CONDUIT BENDING RADII AND TO AVOID NEW WALL MOUNTED EQUIPMENT. TRAY TO BE SUITABLE GROUNDED AND BONDED.
9. NEW CABLE TRAY WINDOW IN NEW SSSR BUILDING BRICK WORK TO ALLOW FOR INSTALLATION OF NEW ANGLED LADDER TYPE CABLE TRAY. REFER TO CUT SECTION 25114 FOR CABLE AND CONDUIT LAYOUT IN CABLE TRAY. ENSURE WINDOW PENETRATION IS FILLED AND SEALED AFTER INSTALLATION OF CONDUITS AND CABLES.
10. NEW 2x350KCM TECK FROM NEW CABLE TRAY TO NEW 600V MANUAL TRANSFER SWITCH. (SEE KEY NOTE 4 FOR OTHER END OF CONNECTION)
11. NEW 4c#6 TECK IN NEW 53mm EMT CONDUIT FROM NEW CABLE TRAY TO NEW PANEL 2SSSR-SP-1, FROM EXISTING PANEL '2SL'. (SEE KEY NOTE 3 FOR OTHER END OF CONNECTION)
12. NOT USED
13. 2x4c#250KCM TECK IN NEW 2x129mm EMT CONDUIT MOUNTED TO CEILING. TO RUN IN FRONT OF HIGH VOLTAGE CABLE WIREWAY.
14. 2x4c#250KCM TECK TO ENTER NEW 6SSSR-1 SWITCHBOARD VIA SWITCHBOARD TOP ENTRY COMPARTMENT. COORDINATE OVERHEAD ENTRY DETAILS WITH SWITCHBOARD MANUFACTURER'S SHOP DRAWINGS.
15. EXISTING CABLE TRAY FROM EXISTING SSS BUILDING TO BE DECOMMISSIONED AND REMOVED. SEAL EXISTING WALL PENETRATIONS WITH CONCRETE GROUT.
16. 3x53mm EMT CONDUITS MOUNTED IN CABLE TRAY STUBBING OFF INSIDE SSSR AND GENERATOR BUILDINGS. TWO BE FIRE STOPPED AND LEFT EMPTY FOR FUTURE COMMUNICATION CABLES, 1 FOR NEW GENERATOR SCADA AND DIGITAL BREAKER CATSE TO NEW SCADA CONTROL PANEL.
17. 200A, 600V CAM-LOCK TEMPORARY GENERATOR CONNECTION BOX. REFER TO 25011 FOR ADDITIONAL INFORMATION. ENCLOSURE TO BE OF MARINE GRADE ALUMINUM AND OF CSA 3R RATED CONSTRUCTION.
18. 4c#30 Cu. AWG CABLE IN 53mm EMT CONDUIT CONCEALED WITHIN BUILDING FABRIC.
19. TEMPORARY GENERATOR CONNECTION TO NEW MANUAL TRANSFER SWITCH.
20. INSTALL NEW MAIN BREAKER ON GENERATOR. ATTACHED TO ALTERNATOR WITH MINIMUM LEAD LENGTHS POSSIBLE. PERFORM ARC FAULT ANALYSIS AND SELECT BREAKER TO ACHIEVE APPROPRIATE ARC FAULT CO-ORDINATION WITH DOWNSTREAM DEVICES. INSTALL M2 TYPE PROTECTION METER AT SAME LOCATION. REUSE EXISTING FEEDERS BETWEEN GENERATOR AND TRANSFER SWITCH.
21. 2c#ATSE IN 1x27mm CONDUIT CONCEALED IN NEW BUILDING WALL. FROM NEW SCADA SYSTEM PANEL TO JUNCTION BOX CONNECTING TO 1x53mm CABLE TRAY CONDUIT.



2 SSSR-GENERATOR BUILDING CABLE TRAY  
SCALE 1:110



1 MAIN FLOOR GENERATOR CONNECTION  
SCALE 1:50



Revision/ Révision	Description/Description	Date/Date
5	ISSUED FOR TENDER	15/01/28
4	ISSUED FOR 99% DESIGN REVIEW	16/01/06
3	ISSUED FOR 66% DESIGN REVIEW	15/11/25
2	ISSUED FOR 33% DESIGN REVIEW	15/10/28
1	ISSUED FOR DESIGN DEVELOPMENT	15/09/11
0		

Client/client

**ESQUIMALT GRAVING DOCK**

825 ADMIRALS ROAD  
VICTORIA, BC, V9A 2P1

Project title/Titre du projet  
**825 ADMIRALS ROAD VICTORIA BC  
ESQUIMALT GRAVING DOCK  
ELECTRICAL SAFETY UPGRADE**

**SOUTH SUBSTATION  
SWITCHGEAR  
REPLACEMENT  
(SSSR)**

Consultant Signature Box Only

Designed by/Concept par  
**I. BARNES**

Drawn by/Dessiné par  
**J. BIELING / S. SEYMOUR**

PWGSC Project Manager/Administrateur de Projets TPSGC  
**Jamie LeBlanc**


PWGSC Regional Manager, Architectural and Engineering Services/  
Gestionnaire régionale, Services d'architectural et de génie, TPSGC  
**Preetpal Paul**

Drawing title/Titre du dessin

**GENERATOR RECONNECTION**

Project No./No. du projet	Sheet/Feuille	Revision no./ La Révision no.
<b>R.062548.2</b>	<b>5114</b>	<b>5</b>





Revision/ Révision	Description/Description	Date/Date
5	ISSUED FOR TENDER	15/01/28
4	ISSUED FOR 99% DESIGN REVIEW	16/01/06
3	ISSUED FOR 66% DESIGN REVIEW	15/11/25
2	ISSUED FOR 33% DESIGN REVIEW	15/10/28
1	ISSUED FOR DESIGN DEVELOPMENT	15/09/11
0		

Client/client

**ESQUIMALT GRAVING DOCK**

825 ADMIRALS ROAD VICTORIA, BC, V9A 2P1

Project title/Titre du projet  
**825 ADMIRALS ROAD VICTORIA BC ESQUIMALT GRAVING DOCK ELECTRICAL SAFETY UPGRADE**

**SOUTH SUBSTATION SWITCHGEAR REPLACEMENT (SSSR)**

Consultant Signature Box Only

Designed by/Concept par  
**I. BARNES**

Drawn by/Dessiné par  
**J. BIELING / S. SEYMOUR**



PWGSC Project Manager/Administrateur de Projets TPSGC  
**Jamie LeBlanc**

PWGSC Regional Manager, Architectural and Engineering Services/ Gestionnaire régionale, Services d'architecture et de génie, TPSGC  
**Preetipal Paul**



Drawing title/Titre du dessin

**DOCK SERVICE ASSEMBLIES 1 OF 2 (DS2-E, DS2-W)**


Project No./No. du projet	Sheet/Feuille	Revision no./La Révision no.
R.062548.2	5115	5




3 DOCK SERVICE ASSEMBLY COVER OFF ELEVATION SCALE 1:20




4 DOCK SERVICE ASSEMBLY EXTERIOR ELEVATION SCALE 1:20




5 600V DOCK SERVICES CELL SECTION CUT SCALE 1:20




6 600V DOCK SERVICES CELL ELEVATION VIEW SCALE 1:20




7 600V DOCK SERVICES CELL PLAN VIEW SCALE 1:20




8 480V DOCK SERVICES CELL SECTION CUT SCALE 1:20




9 480V DOCK SERVICES CELL ELEVATION VIEW SCALE 1:20




10 480V DOCK SERVICES CELL PLAN VIEW SCALE 1:20




11 120/208V DOCK SERVICES CELL SECTION CUT SCALE 1:20




12 120/208V DOCK SERVICES CELL ELEVATION VIEW SCALE 1:20




13 120/208V DOCK SERVICES CELL PLAN VIEW SCALE 1:20



14 TELECOM DOCK SERVICES CELL SECTION CUT SCALE 1:20



15 TELECOM DOCK SERVICES CELL ELEVATION VIEW SCALE 1:20









16 TELECOM DOCK SERVICES CELL PLAN VIEW SCALE 1:20


KEYNOTES

- DOCK SERVICE ASSEMBLY, TO BE MADE OF WELDED STAINLESS STEEL AND OF NEMA 4X RATED CONSTRUCTION, MINIMUM 12.5mm THICK STEEL FOR OUTER COMPARTMENT WALLS. EACH CELL TO BE A SEPARATE ELECTRICAL ZONE ALLOWING WORK ON ONE CELL WHILE THE REMAINDER ARE ENERGIZED, ALL CROSS CELL WIRING TO BE IN CONDUIT.
- 12.5mm STAINLESS STEEL CELL SEPARATION WALL, ASSEMBLIES TO BE CONSTRUCTED WITH SEPARATION WALLS BETWEEN EACH CELL AND BETWEEN CELLS AND DOCK WALLS. TO BE USED TO MOUNT HINGES ON ALL CELL ACCESS DOORS. TO BE USED TO MOUNT SAFETY HARNESS ATTACHMENT POINTS. CONTRACTOR TO RETAIN THE SERVICES OF A STRUCTURAL ENGINEER TO DESIGN SAFETY ATTACHMENT POINTS AND SUBMITTED STAMPED SHOP DRAWINGS OF FINAL DESIGN FOR APPROVAL PRIOR TO MANUFACTURING.
- STAINLESS STEEL ACCESS HATCH, TO HAVE CHECKER PLATE TOP COVER SURFACE TO REDUCE SLIP CHANCE. TO BE SEALED AND GASKETED TO PREVENT LIQUID OR SOLIDS FROM ENTERING CELL COMPARTMENT. TO BE REMOVABLE BY MEANS OF SCREWS LOCATED AT PERIMETER OF PLATE. CHECKER PLATE TO BE PAINTED WITH NON-SLIP MATERIAL.
- TECK CONDUCTORS FOR ELECTRICAL SERVICE. REFER TO SINGLE LINE DIAGRAM AND SHEET 5108 FOR ADDITIONAL DETAILS (TYPICAL).
- 103mm RIGID STEEL CONDUIT BETWEEN TUNNEL AND BOTTOM OF DOCK SERVICE CELL, CORE HOLE FROM CELL SIDE INTO SERVICE TUNNEL AND INSTALL CONDUIT, ENSURE CONDUIT IS COMPLETE WITH BELL END AND SMOOTH FINISHED TO PREVENT ABRASION TO CONDUCTORS (TYPICAL).
- CONDUITS TO ENTER CELL ANGLED TO ALLOW FOR EASY BENDING OF STRIPPED TECK CABLE. ENSURE EDGES OF PENETRATION AS SEALED WITH WATERPROOF POLYURETHANE CAULKING (TYPICAL).
- REMOVE TECK CONDUCTOR EXTERIOR RUBBER SHEATH AND INTERLOCKING ARMOR
- BOND TECK CABLE ARMOR TO CELL GROUND BAR.
- BOND TECK CABLE CONCENTRIC COPPER BOND WIRES TO CELL GROUND BAR.
- ASSEMBLY INSULATION AND VAPOR BARRIER, TO BE OF NON-CONDUCTIVE MATERIALS.
- HEXAGONAL LAG-BOLT, USED TO SECURE ASSEMBLY LID, LID TO BE COMPLETELY SEALED AND GASKETED. LAG BOLT TO ENTER INTO KIOSK INTO BLANK FASTENING POCKET TO REDUCE WATER INGRESS. (TYPICAL)
- TERMINATE TECK CONDUCTOR TO MOLDED CASE SWITCH TERMINAL LUGS USING 2-HOLE COMPRESSION STYLE TERMINAL CONNECTORS. HEAT SHRINK TERMINATION USING MANUFACTURER'S RECOMMENDED METHODS.
- SERVICE ASSEMBLY LID HINGE, MODIFY EXISTING CONCRETE AS REQUIRED TO ENSURE 110° OPENING ANGLE IS POSSIBLE. HINGE TO BE OF RUGGED AND DURABLE CONSTRUCTION
- 400A, 600V 3P MOLDED CASE SWITCH, 100% RATED, 65 KAIC INTERRUPT CAPABILITY C/W MANUAL OPEN/CLOSE TURN HANDLE AND INTERLOCKED WITH CAM-LOCK CONNECTORS TO PREVENT OPERATION UNTIL CONNECTION IS MADE.
- 2x3x#30 Cu CONDUCTORS FROM MOLDED CASE SWITCH TERMINAL LUGS TO TERMINAL LUGS ON CAM-LOCK PLUG. CONDUCTORS TO TERMINATE ON MOLDED CASE SWITCH AND CAM-LOCK LUGS USING 2-HOLE COMPRESSION STYLE TERMINAL CONNECTORS. HEAT SHRINK TERMINATIONS USING MANUFACTURER'S RECOMMENDED METHODS.
- CAM-LOCK TERMINAL LUGS, TO BE TIN PLATED COPPER AND RATED FOR 400A LOADS @ 100% RATING.
- 400A, 600V RATED CAM-LOCK STYLE RECEPTACLES, SINGLE POLE PER PHASE 250KCM. C/W DOUBLE THROW MICRO SWITCH FOR SAFETY INTERLOCKING OF MOLDED CASE SWITCH. RECEPTACLES FOR 0A, 0B, 0C, 0G WIRE CONNECTIONS. 0G RECEPTACLES TO BE REVERSED FROM POWER PHASES AND USE MALE CONNECTIONS ON EQUIPMENT FACE.
- DOCK SERVICE "DLO" OR SIMILAR STYLE CABLES BY OTHERS FOR CONNECTION TO SERVICE CELL.
- REMOVE EXISTING CONCRETE IN DOCK WALL AND INSTALL STAINLESS STEEL CABLE TROUGH TO ALLOW CABLES TO CONNECT TO CAM-LOCK RECEPTACLES WITH ACCESS DOOR CLOSED. ENSURE MINIMUM BENDING RADIUS IS POSSIBLE TO ACHIEVE FOR CABLES GOING TO ANY RECEPTACLE.
- 25mm STRUCTURAL STEEL RIGID BAR INSTALLED IN ASSEMBLY TO ALLOW ASSEMBLY TO WITHSTAND COMPRESSION FORCES FROM THERMAL EXPANSION OF EXISTING CONCRETE DOCK.
- STATUS LIGHT, PUSH TO TEST, DUAL COLOR (RED CLOSED, GREEN OPEN)
- DOOR HANDLE, C/W LOCK.
- REINFORCED SAFETY GLASS VIEWING WINDOW, SEALED AND GASKETED.
- 100W STRIP HEATER C/W INTEGRATED THERMOSTAT IN EACH CELL.
- CELL GROUND BUS BAR MOUNTED NEAR BACK OF CELL, TO BE OF TIN PLATED COPPER CONSTRUCTION MOUNTED ON INSULATED STANDOFFS.
- TO INSTALL CELL CONTRACTOR WILL BE REQUIRED TO REMOVE EXISTING GRANITE DOCK EDGE PROTECTION STONES AND CHISEL AWAY EXISTING CONCRETE TO CREATE A VOID OF SUFFICIENT SIZE TO ALLOW ASSEMBLIES TO BE INSTALLED FLUSH WITH FACE AND TOP OF DOCK WALL. DRILL INTO DOCK AND ATTACH ASSEMBLY USING CONCRETE DOWELS AND FILL SPACES WITH CONCRETE GROUT. CARE IS TO BE TAKEN TO AVOID DAMAGING ADJACENT GRANITE STONES OR PENETRATING INTO SERVICE TUNNEL, TYPICAL OF ALL ASSEMBLIES
- 400A, 480V 3P MOLDED CASE SWITCH, 100% RATED, 65 KAIC INTERRUPT CAPABILITY C/W MANUAL OPEN/CLOSE TURN HANDLE AND INTERLOCKED WITH CAM-LOCK CONNECTORS TO PREVENT OPERATION UNTIL CONNECTION IS MADE.
- 2x3x#30 Cu CONDUCTORS FROM MOLDED CASE SWITCH TERMINAL LUGS TO TERMINAL LUGS ON CAM-LOCK PLUG. CONDUCTORS TO TERMINATE ON MOLDED CASE SWITCH AND CAM-LOCK LUGS USING 2-HOLE COMPRESSION STYLE TERMINAL CONNECTORS. HEAT SHRINK TERMINATIONS USING MANUFACTURER'S RECOMMENDED METHODS.
- 400A, 480V RATED CAM-LOCK STYLE RECEPTACLES, SINGLE POLE PER PHASE 250KCM. C/W DOUBLE THROW MICRO SWITCH FOR SAFETY INTERLOCKING OF MOLDED CASE SWITCH. RECEPTACLES FOR 0A, 0B, 0C, 0G WIRE CONNECTIONS. 0G RECEPTACLES TO BE REVERSED FROM POWER PHASES AND USE MALE CONNECTIONS ON EQUIPMENT FACE.
- 400A, 480V RATED CAM-LOCK STYLE RECEPTACLES FOR GROUNDING CONNECTION, TO BE CONNECTED TO CELL GROUND BUS VIA #20Cu CONDUCTOR.
- 200A, 208V 3P MOLDED CASE SWITCH, 100% RATED, 65 KAIC INTERRUPT CAPABILITY C/W MANUAL OPEN/CLOSE TURN HANDLE AND INTERLOCKED WITH CAM-LOCK CONNECTORS TO PREVENT OPERATION UNTIL CONNECTION IS MADE.
- 3x#30 Cu CONDUCTORS FROM MOLDED CASE SWITCH TERMINAL LUGS TO TERMINAL LUGS ON CAM-LOCK PLUG. CONDUCTORS TO TERMINATE ON MOLDED CASE SWITCH AND CAM-LOCK LUGS USING 2-HOLE COMPRESSION STYLE TERMINAL CONNECTORS. HEAT SHRINK TERMINATIONS USING MANUFACTURER'S RECOMMENDED METHODS.
- 200A, 240V RATED CAM-LOCK STYLE RECEPTACLES, SINGLE POLE PER PHASE 250KCM. C/W DOUBLE THROW MICRO SWITCH FOR SAFETY INTERLOCKING OF MOLDED CASE SWITCH. RECEPTACLES FOR 0A, 0B, 0C, 0N, 0G WIRE CONNECTIONS. 0N, 0G RECEPTACLES TO BE REVERSED FROM POWER PHASES AND USE MALE CONNECTIONS ON EQUIPMENT FACE.
- 200A, 240 RATED CAM-LOCK STYLE RECEPTACLES FOR GROUNDING CONNECTION, TO BE CONNECTED TO CELL GROUND BUS VIA #20Cu CONDUCTOR.
- CONDUITS TO ENTER CELL ANGLED TO ALLOW FOR EASY BENDING OF TELECOM CABLES.
- INSTALL DRAIN HOLE TO ALLOW WATER OR CONDENSATION TO DRAIN FROM SERVICE ASSEMBLY INTO CABLE ENTRY TROUGH.
- ALLOW 1m NEATLY SPOOLED SLACK IN ALL TELECOM AND ALARM CABLES FOR SPLICING.
- WEATHERPROOF CAT5 AND CAT3 TELECOM RECEPTACLES C/W SCREW ON CAPS
- KIOSK FLOOR TO HAVE 0.5° SLOPE TO PREVENT ANY WATER FROM POOLING
- 16xCAT3 WEATHERPROOF TELEPHONE RECEPTACLES, TO MATCH EXISTING STYLE ON SITE.
- 4xCAT5 WEATHERPROOF CAT5 ETHER NET RECEPTACLES.
- 2xCAT3 WEATHERPROOF FIRE ALARM CONNECTION RECEPTACLES. C/W DUMMY WIRED TO END OF LINE RESISTOR.
- 2xCAT3 WEATHERPROOF EMERGENCY ALARM CONNECTION RECEPTACLES. C/W DUMMY WIRED TO END OF LINE RESISTOR.
- 1x103mm RIGID STEEL TELECOM CONDUIT FOR 12PR #22 TELECOM WIRES
- 1x103mm RIGID STEEL DATA CONDUIT FOR 6xCAT5 ARMORED TECK CABLE
- 1x103mm RIGID STEEL CONDUIT FOR FUTURE FIBER OPTICS
- 1x27mm RIGID STEEL CONDUIT FOR FIRE ALARM SYSTEM
- 1x27mm RIGID STEEL CONDUIT FOR EMERGENCY ALARM
- LED STRIP MOUNTED INSIDE ASSEMBLY DOOR C/W SWITCH FOR DOOR OPEN DETECTION. TYPE 'LE' FIXTURE, REFER TO SHEET S111 FOR ADDITIONAL INFORMATION.
- REMOVABLE SAFETY RAILING, TYPICAL OF ALL ASSEMBLIES REFER TO DETAILS 85116 AND 95116 FOR ADDITIONAL INFORMATION.
- FIBERGLASS NO-SLIP DECKING MATERIAL. REFER TO DETAIL 95116 FOR ADDITIONAL INFORMATION.
- 1x29mm RIGID STEEL CONDUIT FOR 120/208V CIRCUIT
- LIFTING KEY SLOTS. TWO PER ASSEMBLY. PROVIDE TWO LIFTING KEYS TO PWGSC SITE STAFF FOR EACH DOCKSIDE ASSEMBLY (6) AT END OF PROJECT.
- DOOR OPEN LIMIT ARM, INSTALLED TO PREVENT ASSEMBLY COVER OPENING MORE THAN 110°. C/W LOCK POINT TO PREVENT WING FROM CLOSING THE LID.
- RETAIN SERVICES OF A STRUCTURAL ENGINEER TO CERTIFY STRENGTH AND INTEGRITY OF SYSTEM. MUST BE APPROVED PRIOR TO MANUFACTURING.






430-630V DOCK SERVICES CELL SECTION CUT (SCALE 1:20)



430-630V DOCK SERVICES CELL ELEVATION VIEW (SCALE 1:20)




430-630V DOCK SERVICES CELL PLAN VIEW (SCALE 1:20)


KEYNOTES

- 1 DOCK REGULATED SERVICE ASSEMBLY, TO BE MADE OF WELDED STAINLESS STEEL AND OF NEHA 4X RATED CONSTRUCTION, MINIMUM 12.5mm THICK STEEL FOR OUTER COMPARTMENT WALLS. EACH CELL TO BE A SEPARATE ELECTRICAL ZONE ALLOWING WORK ON ONE CELL WHILE THE REMAINDER ARE ENERGIZED. ALL CROSS CELL WIRING TO BE IN CONDUIT.
- 2 12.5mm STAINLESS STEEL CELL SEPARATION WALL ASSEMBLIES TO BE CONSTRUCTED WITH SEPARATION WALLS BETWEEN EACH CELL AND BETWEEN CELLS AND DOCK WALLS. TO BE USED TO MOUNT HINGES ON ALL CELL ACCESS DOORS. TO BE USED TO MOUNT SAFETY HARNESS ATTACHMENT POINTS. CONTRACTOR TO RETAIN THE SERVICES OF A STRUCTURAL ENGINEER TO DESIGN SAFETY ATTACHMENT POINTS AND SUBMIT STAMPED SHOP DRAWINGS OF FINAL DESIGN FOR APPROVAL PRIOR TO MANUFACTURING.
- 3 STAINLESS STEEL ACCESS HATCH, TO HAVE CHECKER PLATE TOP COVER SURFACE TO REDUCE SLIP CHANCE. TO BE SEALED AND GASKETED TO PREVENT LIQUID OR SOLIDS FROM ENTERING CELL COMPARTMENT. TO BE REMOVABLE BY MEANS OF SCREWS LOCATED AT PERIMETER OF PLATE. CHECKER PLATE TO BE PAINTED WITH NON-SLIP MATERIAL.
- 4 8x3x5000CM Cu. TECK CONDUCTORS FOR 430-630V 2000A REGULATED SERVICE. REFER TO SINGLE LINE DIAGRAM AND SHEET 5108 FOR ADDITIONAL DETAILS.
- 5 RIGID STEEL CABLE COMPARTMENT BETWEEN TUNNEL AND BOTTOM OF DOCK SERVICE CELL. CORE HOLE FROM CELL SIDE INTO SERVICE TUNNEL AND INSTALL COMPARTMENT. ENSURE COMPARTMENT EDGES ARE SMOOTH FINISHED TO PREVENT ABRASION TO CONDUCTORS.
- 6 CONDUITS TO ENTER CELL ANGLED TO ALLOW FOR EASY BENDING OF STRIPPED TECK CABLE. ENSURE EDGES OF PENETRATION ARE SEALED WITH WATERPROOF POLYURETHANE CAULKING.
- 7 BOND TECK CABLE ARMOR TO CELL GROUND BAR.
- 8 BOND TECK CABLE CONCENTRIC COPPER BOND WIRES TO CELL GROUND BAR.
- 9 TERMINATE TECK CONDUCTOR TO CAM-LOCK CONNECTOR TERMINAL LUGS USING 2-HOLE COMPRESSION STYLE TERMINAL CONNECTORS. HEAT SHRINK TERMINATION USING MANUFACTURER'S RECOMMENDED METHODS.
- 10 1x#250CM Cu. GROUND CONDUCTOR DAISY CHAINED BETWEEN GROUNDING CAM-LOCK RECEPTACLES AND TO CELL GROUND BUS.
- 11 2x1000A TIN PLATED COPPER BUS BARS MOUNTED TO CAM-LOCK RECEPTACLE TERMINAL BUS.
- 12 CAM-LOCK TERMINAL LUGS, TO BE TIN PLATED COPPER AND RATED FOR 400A LOADS.
- 13 400A @ 100% 630V RATED CAM-LOCK STYLE RECEPTACLES, SINGLE POLE PER PHASE 250KCM CW DOUBLE THROW MICRO SWITCH FOR SAFETY INTERLOCKING OF MOLDED CASE SWITCH. RECEPTACLES FOR 0A, 0B, 0C, 0G WIRE CONNECTIONS. 0G RECEPTACLES TO BE REVERSED FROM POWER PHASES AND USE MALE CONNECTIONS ON EQUIPMENT FACE.
- 14 25mm STRUCTURAL STAINLESS STEEL PIPE WELDED IN TOP AND BOTTOM OF ASSEMBLY FACE TO PROVIDE RIGID STRUCTURE.
- 15 DOCK SERVICE "DLO" OR SIMILAR STYLE CABLES BY OTHERS FOR CONNECTION TO SERVICE CELL.
- 16 REMOVE EXISTING CONCRETE IN DOCK WALL AND INSTALL STAINLESS STEEL CABLE TROUGH TO ALLOW CABLES TO CONNECT TO CAM-LOCK RECEPTACLES WITH ACCESS DOOR CLOSED. ENSURE MINIMUM BENDING RADIUS IS POSSIBLE TO ACHIEVE FOR CABLES GOING TO ANY RECEPTACLE.
- 17 PILOT LIGHT, PUSH TO TEST, INDICATES ALL CAM-LOCK RECEPTACLES FOR A, B, C AND GROUND PHASES ARE CONNECTED FOR ONE 400A CONNECTION. REFER TO REGULATED VOLTAGE SYSTEM CONTROL LOGIC DIAGRAMS FOR ADDITIONAL DETAILS.
- 18 MUSHROOM HEAD EMERGENCY POWER OFF BUTTON C/W KEY DISENGAGE.
- 19 CONNECTION POINTS FOR REMOTE MOUNTED EMERGENCY POWER OFF, TRIP ON OPEN SIGNAL C/W SHORTING CAP.
- 20 PILOT LIGHT, PUSH TO TEST, RED - POWER ON
- 21 PILOT LIGHT, PUSH TO TEST, GREEN - POWER OFF
- 22 PILOT LIGHT, PUSH TO TEST, AMBER - BREAKER TRIPPED DUE TO FAULT CONDITION
- 23 REMOVE TECK CONDUCTOR EXTERIOR RUBBER SHEATH AND INTERLOCKING ARMOR
- 24 CELL GROUND BUS BAR MOUNTED NEAR BACK OF CELL TO BE OF TIN PLATED COPPER CONSTRUCTION MOUNTED ON INSULATED STANDOFFS.
- 25 TO INSTALL CELL CONTRACTOR WILL BE REQUIRED TO REMOVE EXISTING GRANITE DOCK EDGE PROTECTION STONES AND CHISEL AWAY EXISTING CONCRETE TO CREATE A VOID OF SUFFICIENT SIZE TO ALLOW ASSEMBLIES TO BE INSTALLED FLUSH WITH FACE AND TOP OF DOCK WALL. DRILL INTO DOCK AND ATTACH ASSEMBLY USING CONCRETE DOWELS AND FILL SPACES WITH CONCRETE GROUT. CARE IS TO BE TAKEN TO AVOID DAMAGING ADJACENT GRANITE STONES OR PENETRATING INTO SERVICE TUNNEL.


- 26 100W STRIP HEATER C/W INTEGRATED THERMOSTAT.
- 27 LED STRIP MOUNTED INSIDE ASSEMBLY DOOR C/W SWITCH FOR DOOR OPEN DETECTION. TYPE 'LE' FIXTURE. REFER TO SHEET 5111 FOR ADDITIONAL INFORMATION.
- 28 REMOVABLE SAFETY RAILING, TYPICAL OF ALL ASSEMBLIES REFER TO DETAIL 8/5116 FOR ADDITIONAL INFORMATION.
- 29 NO-SLIP DECKING MATERIAL. REFER TO DETAIL 8/5116 FOR ADDITIONAL INFORMATION.
- 30 EXISTING DOCK CONCRETE AND ASPHALT SURFACE TO REMAIN.
- 31 EXISTING DOCK GRANITE EDGE PROTECTION STONES TO REMAIN.
- 32 EXISTING DOCK LEDGE WALKWAY, TO BE MODIFIED WITH NO-SLIP DECKING MATERIAL IN FRONT OF NEW SERVICE ASSEMBLIES.
- 33 NEW SAFETY HANDRAIL TO SLOP DOWN NEAR ENDS TO REDUCE RISK OF SNAGGING ROPES AND POWER CABLES. CONFIRM EXACT SLOPE ANGLE AND FINAL HANDRAIL DIMENSIONS WITH ENGINEER AND PWGSC SITE REPRESENTATIVE PRIOR TO MANUFACTURE.
- 34 NO-SLIP PLATES INSTALLED ON EXISTING GRANITE PROTECTION STONES. CORE INTO STONES AND ANCHOR NO-SLIP PLATES, PLATES TO BE MOUNTED SUCH THAT THEY CAN BE EASILY REPLACED AS NEEDED.
- 35 STAINLESS STEEL LADDER RUNGS INSTALLED IN EXISTING CONCRETE WALL AND IN GRANITE PROTECTION STONES. CORE INTO CONCRETE OR GRANITE MINIMUM 80mm AND SECURELY ANCHOR RUNGS.
- 36 NO-SLIP DECKING MATERIAL TO BE INSTALLED ON EXISTING DRYDOCK LEDGE.
- 37 REMOVABLE HANDRAILS TO BE INSTALLED IN METAL POST HOLES COMPLETE WITH STAINLESS STEEL LOCKING PIN SECURED TO POST HOLES WITH STAINLESS STEEL CHAIN TO BE INSTALLED INTO EXISTING DOCK LEDGE CONCRETE.
- 38 REMOVABLE STAINLESS STEEL SAFETY RAILING, TO BE DESIGNED TO WORKSAFE BC REQUIREMENTS, TO BE MINIMUM 1000mm FROM FACE OF NEW SERVICE ASSEMBLY AS PER CEC REQUIREMENTS FOR WORKING SPACE AROUND ELECTRICAL EQUIPMENT.
- 39 TECK TO CAM LOCK BUSSING CONNECTION DETAIL, SINGLE PAIR OF CABLES SHOWN FOR CLARITY.
- 40 REFER TO SHEET 5115 FOR 480V, 120V AND COMMUNICATION SERVICE ASSEMBLY DETAILS.
- 41 EXISTING DOCK RAILING TO BE REMOVED AND REINSTALLED AFTER INSTALLATION OF DOCK SERVICE ASSEMBLIES.
- 42 EXISTING DOCK TRAILING POST HOLES, CO-ORDINATE WITH EXISTING LOCATIONS TO ALLOW FOR REUSE OF EXISTING RAILINGS.
- 43 IF A POST HOLE IS REQUIRED IN THE CENTRAL SPAN OVER THE NEW SERVICE ASSEMBLY ENSURE IT IS INSTALLED ON THE CELL SEPARATION WALLS.
- 44 ASSEMBLY INSULATION AND VAPOR BARRIER, TO BE OF NON-CONDUCTIVE MATERIALS.
- 45 HEXAGONAL LAG-BOLT, USED TO SECURE ASSEMBLY LID TO BE COMPLETELY SEALED AND GASKETED. LAG BOLT TO ENTER INTO KIOSK INTO BLANK FASTENING POCKET TO REDUCE WATER INGRESS. (TYPICAL)
- 46 SERVICE ASSEMBLY LID HINGE, MODIFY EXISTING CONCRETE AS REQUIRED TO ENSURE 110° OPENING ANGLE IS POSSIBLE. HINGE TO BE OF RUGGED AND DURABLE CONSTRUCTION.
- 47 LIFTING KEY SLOTS, TWO PER ASSEMBLY, PROVIDE TWO LIFTING KEYS TO PWGSC SITE STAFF FOR EACH DOCKSIDE ASSEMBLY (6) AT END OF PROJECT.
- 48 DOOR OPEN LIMIT ARM, INSTALLED TO PREVENT ASSEMBLY COVER OPENING MORE THAN 110°. C/W LOCK POINT TO PREVENT WING FROM CLOSING THE LID.
- 49 INSTALL DRAIN HOLE TO ALLOW WATER OR CONDENSATION TO DRAIN FROM SERVICE ASSEMBLY INTO CABLE ENTRY TROUGH.
- 50 KIOSK FLOOR TO HAVE 0.5° SLOPE TO PREVENT ANY WATER FROM POOLING
- 51 25mm STRUCTURAL STEEL RIGID BAR INSTALLED IN ASSEMBLY TO ALLOW ASSEMBLY TO WITHSTAND COMPRESSION FORCES FROM THERMAL EXPANSION OF EXISTING CONCRETE DOCK.
- 52 RETAIN SERVICES OF A STRUCTURAL ENGINEER TO CERTIFY STRENGTH AND INTEGRITY OF SYSTEM. MUST BE APPROVED PRIOR TO MANUFACTURING.



DOCK SERVICES SAFETY SYSTEMS PLAN VIEW (REGULATED SERVICE SHOWN) (SCALE 1:20)



DOCK SERVICES SAFETY SYSTEMS SECTION VIEW (SCALE 1:20)



Revision/Revisions	Description/Description	Date/Date
5	ISSUED FOR TENDER	15/01/28
4	ISSUED FOR 90% DESIGN REVIEW	16/01/06
3	ISSUED FOR 60% DESIGN REVIEW	15/11/25
2	ISSUED FOR 30% DESIGN REVIEW	15/10/28
1	ISSUED FOR DESIGN DEVELOPMENT	15/09/11
0		

Client/client

**ESQUIMALT GRAVING DOCK**

825 ADMIRALS ROAD  
VICTORIA, BC, V9A 2P1

Project title/Titre du projet  
**825 ADMIRALS ROAD VICTORIA BC  
ESQUIMALT GRAVING DOCK  
ELECTRICAL SAFETY UPGRADE**

**SOUTH SUBSTATION  
SWITCHGEAR  
REPLACEMENT  
(SSSR)**

Consultant Signature Box Only

Designed by/Concept par  
**I. BARNES**

Drawn by/Dessiné par  
**J. BIELING / S. SEYMOUR**




PWGSC Project Manager/Administrateur de Projets TPSGC  
**Jamie LeBlanc**

PWGSC, Regional Manager, Architectural and Engineering Services/  
Gestionnaire régionale, Services d'architecture et de génie, TPSGC  
**Preetpal Paul**

Drawing title/Titre du dessin

**DOCK SERVICE ASSEMBLIES 2 OF 2  
(DS2-C)**

Project No./No. du projet	Sheet/Feuille	Revision no./ no. de révision
<b>R.062548.2</b>	<b>5116</b>	<b>5</b>



5	ISSUED FOR TENDER	15/01/28
4	ISSUED FOR 99% DESIGN REVIEW	16/01/06
3	ISSUED FOR 66% DESIGN REVIEW	15/11/25
2	ISSUED FOR 33% DESIGN REVIEW	15/10/28
1	ISSUED FOR DESIGN DEVELOPMENT	15/09/11
0		

Revision/	Description/Description	Date/Date
-----------	-------------------------	-----------

Client/client

**ESQUIMALT  
GRAVING DOCK**

**825 ADMIRALS ROAD  
VICTORIA, BC, V9A 2P1**

Project title/Titre du projet  
**825 ADMIRALS ROAD VICTORIA BC  
ESQUIMALT GRAVING DOCK  
ELECTRICAL SAFETY UPGRADE**

**SOUTH SUBSTATION  
SWITCHGEAR  
REPLACEMENT  
(SSSR)**

Consultant Signature Box Only

Designed by/Concept par  
**I. BARNES**

Drawn by/Dessiné par  
**J. BIELING / S. SEYMOUR**

PWCS Project Manager/Administrateur de Projets TPSGC  
**Jamie LeBlanc**

PWCS Regional Manager, Architectural and Engineering Services/  
Gestionnaire régionale, Services d'architecture et de génie, TPSGC  
**Preetpal Paul**

Drawing title/Titre du dessin

**DOCK SERVICE ASSEMBLIES 3D  
MODEL**


Project No./No. du projet	Sheet/Feuille	Revision no./ La Révision no.
<b>R.062548.2</b>	<b>5117</b>	<b>5</b>





KEYNOTES:

- 1 1x53mm CONDUIT FROM SSSR VIA WALL PENETRATION TO NEW LIFT STATION CONTROL PANEL FOR 600V POWER CIRCUIT.
- 2 1x53mm CONDUIT FROM SSSR VIA WALL PENETRATION TO NEW LIFT STATION CONTROL PANEL FOR CONTROL CIRCUITS.
- 3 SUPPLY AND INSTALL RPVC TO GRS CONDUIT ADAPTER COUPLINGS.
- 4 SUPPLY AND INSTALL NEMA 4X RATED SUMP PUMP CONTROL PANEL, MOUNTED TO NEW SSSR BUILDING ON GROUT LINES OF BLOCKS ONLY. SUPPLY AND INSTALL POWER WIRING, WIRE ALL CONTROLS AND ALARMS. COMMISSION AND TEST PUMP OPERATION TO THE SATISFACTION OF EGD SITE REPRESENTATIVE.
- 5 PANEL TO BE EQUIPPED WITH HIGH WATER LEVEL ALARM STROBE LIGHT.
- 6 27mm EYS SEAL
- 7 27mm GRS CONDUIT
- 8 SUPPLY AND INSTALL 300mm X 300mm X 150mm NEMA 4X RATED TERMINAL AND CONNECTION BOX.
- 9 SUPPLY AND INSTALL 1x53mm RPVC CONDUIT TO SUMP CHAMBER FOR LIFT STATION PUMP POWER. SEE SHEET 5101 FOR CONDUIT ROUTE.
- 10 SUPPLY AND INSTALL 1x53mm RPVC CONDUIT TO SUMP CHAMBER FOR LIFT STATION FLOAT CONTACTS. SEE SHEET 5101 FOR CONDUIT ROUTE.
- 11 53mm GRS CONDUIT.
- 12 53mm RPVC CONDUIT TO NEW LIFT STATION WET WELL FOR FUTURE



1 LIFT STATION CONTROL PANEL ELEVATION DETAIL  
5120 SCALE 1:10

5	ISSUED FOR TENDER	15/01/28
4	ISSUED FOR 99% DESIGN REVIEW	16/01/06
3	ISSUED FOR 66% DESIGN REVIEW	15/11/25
2	ISSUED FOR 33% DESIGN REVIEW	15/10/28
1	ISSUED FOR DESIGN DEVELOPMENT	15/09/11
0		

Revision/Revision	Description/Description	Date/Date
-------------------	-------------------------	-----------

Client/client

**ESQUIMALT GRAVING DOCK**

825 ADMIRALS ROAD  
VICTORIA, BC, V9A 2P1

Project title/Titre du projet  
825 ADMIRALS ROAD VICTORIA BC  
ESQUIMALT GRAVING DOCK  
ELECTRICAL SAFETY UPGRADE

**SOUTH SUBSTATION SWITCHGEAR REPLACEMENT (SSSR)**

Consultant Signature Box Only

Designed by/Concept par  
**I. BARNES**

Drawn by/Dessiné par  
**J. BIELING / S. SEYMOUR**

PWCSG Project Manager/Administrateur de Projets TPSGC  
**Jamie LeBlanc**






PWCSG, Regional Manager, Architectural and Engineering Services/  
Gestionnaire régionale, Services d'architecture et de génie, TPSGC  
**Preitipal Paul**

Drawing title/Titre du dessin

**LIFT STATION CONTROL PANEL**

Project No./No. du projet <b>R.062548.2</b>	Sheet/Feuille <b>5120</b>	Revision no./ La Révision no. <b>5</b>
--	------------------------------	--





1 SSSR 480, 120/208V BUILDING MOUNTED SERVICE ASSEMBLY EXTERIOR ELEVATION SCALE 1:20

2 SSSR 480, 120/208V BUILDING MOUNTED SERVICE ASSEMBLY INTERIOR ELEVATION SCALE 1:20

3 SSSR 480V BUILDING MOUNTED SERVICE ASSEMBLY INTERIOR ELEVATION SCALE 1:20

4 SSSR 120/208V BUILDING MOUNTED SERVICE ASSEMBLY INTERIOR ELEVATION SCALE 1:20

Revision/ Révision	Description/Description	Date/Date
5	ISSUED FOR TENDER	15/01/28
4	ISSUED FOR 99% DESIGN REVIEW	16/01/06
3	ISSUED FOR 66% DESIGN REVIEW	15/11/25
2	ISSUED FOR 33% DESIGN REVIEW	15/10/28
1	ISSUED FOR DESIGN DEVELOPMENT	15/09/11
0		

Client/client

**ESQUIMALT GRAVING DOCK**  
**825 ADMIRALS ROAD VICTORIA, BC, V9A 2P1**

Project title/Titre du projet  
**825 ADMIRALS ROAD VICTORIA BC ESQUIMALT GRAVING DOCK ELECTRICAL SAFETY UPGRADE**  
**SOUTH SUBSTATION SWITCHGEAR REPLACEMENT (SSSR)**

Consultant Signature Box Only

Designed by/Concept par  
**I. BARNES**

Drawn by/Dessiné par  
**J. BIELING / S. SEVMOUR**

PWSSC Project Manager/Administrateur de Projets TPSGC  
**Jamie LeBlanc**

PWSSC Regional Manager, Architectural and Engineering Services/ Gestionnaire régionale, Services d'architecture et de génie, TPSGC  
**Preetpal Paul**

Drawing title/Titre du dessin

**LIFT STATION CONTROL PANEL**




Project No./No. du projet	Sheet/Feuille	Revision no./ La Révision no.
<b>R.062548.2</b>	<b>5121</b>	<b>5</b>

KEYNOTES:


- 1 A0, B0, C0 and Ground cables. Rated 480V, 400A. DOCK SERVICE "DLO" OR SIMILAR STYLE CABLES BY OTHERS FOR CONNECTION TO SERVICE.
- 2 A0, B0, C0, N0, and Ground cables. Rated 120/208V, 200A. DOCK SERVICE "DLO" OR SIMILAR STYLE CABLES BY OTHERS FOR CONNECTION TO SERVICE.
- 3 OUTDOOR WEATHERPROOF ELECTRICAL HAZARD SIGN, C/W ARC FLASH INFORMATION LABEL. CONFIRM EXACT WORDING AND DIMENSIONS WITH PUBLIC WORKS DEPARTMENTAL REPRESENTATIVE.
- 4 NEMA 3R RATED MARINE GRADE ALUMINUM ENCLOSURE MOUNTED TO EXTERIOR OF NEW SOUTH SIDE SUBSTATION. REFER TO DRAWING DETAILS FOR ENCLOSURE DIMENSIONS. CONFIRM DIMENSIONS WITH MANUFACTURER EQUIPMENT SIZES AND ADJUST AS NEEDED AT NO ADDITIONAL COST. DOORS TO BE COMPLETELY GASKETED AND CAPABLE OF 180 DEGREES OF SWING TO ALLOW FOR ACCESS.
- 5 120/208V COMPARTMENT ACCESS HANDLE C/W LOCKABLE HASP.
- 6 480V COMPARTMENT ACCESS HANDLE C/W LOCKABLE HASP.
- 7 400A, 480V RATED CAM-LOCK STYLE RECEPTACLES, SINGLE POLE PER PHASE 250KCM. C/W DOUBLE THROW MICRO SWITCH FOR SAFETY INTERLOCKING OF BREAKER (TYPICAL FOR 480V CELL). MICRO SWITCHES WIRES IN SERIES TO TRIGGER BREAKER TRIP IF ANY CAM-LOCK PLUG IS PULLED FROM ITS SOCKET WHILE SYSTEM WHILE BREAKER IS CLOSED.
- 8 NEMA 12 CAM-LOCK SPLICE BOX SHOWING INTERNAL WIRING. REFER TO DRAWINGS FOR MINIMUM DIMENSIONS. ENSURE MINIMUM BENDING RADIUS AND WORKING SPACE IS ALLOWED INSIDE SPLICE BOX. CONFIRM DIMENSIONS WITH MANUFACTURER EQUIPMENT SIZES AND ADJUST AS NEEDED AT NO ADDITIONAL COST.
- 9 400A, 480V RATED NON-FUSED DISCONNECT SWITCH IN NEMA 12 ENCLOSURE. C/W KEY INTERLOCK TO PREVENT OPENING OF SWITCH WHILE UPSTREAM BREAKER IS CLOSED.
- 10 53mm CONDUIT WALL SLEEVES BETWEEN INTERIOR JUNCTION BOX AND OUTDOOR SERVICE ASSEMBLY. EDGES TO BE SEALED WITH WATERTIGHT CAULKING TO PREVENT LEAKS AND INTERIOR TO BE SEALED AFTER CONDUCTORS ARE INSTALLED TO PREVENT VAPOUR MIGRATION.
- 11 2x3#3/0 Conductors from 480V, 400A DISCONNECT SWITCH SECONDARY TERMINALS TO CAM-LOCK TERMINALS.
- 12 1#3/0 Conductors CONNECTED TO CAM-LOCK TERMINALS VIAL IRREVERSIBLE COMPRESSION STYLE LUG PER 2 PHASE (TYPICAL).
- 13 200A, 120/208V RATED NON-FUSED DISCONNECT SWITCH IN NEMA 12 ENCLOSURE. C/W KEY INTERLOCK TO PREVENT OPENING OF SWITCH WHILE UPSTREAM BREAKER IS CLOSED.
- 14 53mm EMT CONDUIT BETWEEN DISCONNECT SWITCH AND CAM-LOCK SPLICE BOX.
- 15 3#3/0 Conductors from 120/208V, 200A DISCONNECT SWITCH SECONDARY TERMINALS TO CAM-LOCK TERMINALS.
- 16 1#3/0 Conductor CONNECTED TO CAM-LOCK TERMINALS VIAL IRREVERSIBLE COMPRESSION STYLE LUG, ONE PER PHASE (TYPICAL).
- 17 480V AND 120/208V SECTION DIVIDER WALL BETWEEN BOTH SERVICE COMPARTMENTS. EACH COMPARTMENT TO BE TREATED AS SEPARATE CELL TO ALLOW FOR WORK/MAINTENANCE ON ONE CELL WHILE OTHER IS ENERGIZED.
- 18 EPDM TYPE RUBBER GASKET SEAL INSTALLED IN BOTTOM OF EACH CELL. TO BE STIFF TO PREVENT INTRUSION OF WATER/WEATHER AND DEBRIS BUT ALLOW CABLE TO BE PULLED THROUGH AND CONNECTED TO CAM-LOCK PLUGS.
- 19 2x53mm EMT CONDUIT FROM INTERIOR JUNCTION BOX TO 480V SWITCHBOARD. REFER TO 5101 FOR CONDUIT ROUTE.
- 20 CONDUIT JUNCTION BOX
- 21 ANGLED ROOF TO PREVENT WATER POOLING.

- 22 DRIP GUARD AT EDGE OF ROOF.
- 23 FUSED DISCONNECT SWITCH HANDLE. ENSURE CLEARANCE IS MAINTAINED TO ALLOW EASY OPERATION.
- 24 ANGLE CAM-LOCK PLUGS AT 30° TO ALLOW FOR EASE OF CONNECTION.
- 25 WATER DRAIN HOLE AT BOTTOM OF WALL MOUNTED SERVICE ASSEMBLY.
- 26 1x53mm EMT CONDUIT FROM INTERIOR JUNCTION BOX TO 120/208V SWITCHBOARD. REFER TO 5101 FOR CONDUIT ROUTE.
- 27 NOT USED
- 28 1" WELDED ALUMINUM PIPE MOUNTED BELOW NEW BUILDING MOUNTED SERVICE ASSEMBLY. MOUNT BEHIND RUBBER GASKET SEAL TO ALLOW CABLES TO BE TIED OFF TO PREVENT ACCIDENTAL/NUISANCE DISCONNECTION.
- 29 PIPE SUPPORT STRUT ANCHORED TO CELL SEPARATION WALL.
- 30 250W STRIP HEATER WITH THERMOSTAT.
- 31 200A, 120/208V RATED CAM-LOCK STYLE RECEPTACLES, SINGLE POLE PER PHASE 250KCM. C/W DOUBLE THROW MICRO SWITCH FOR SAFETY INTERLOCKING OF BREAKER. (TYPICAL FOR 120/208V CELL). MICRO SWITCHES WIRES IN SERIES TO TRIGGER BREAKER TRIP IF ANY CAM-LOCK PLUG IS PULLED FROM ITS SOCKET WHILE SYSTEM WHILE BREAKER IS CLOSED. SEPARATE TRIP FOR EACH DISCONNECT.
- 32 2" TYPE 'LD' LED STRIP LIGHT, C/W LIMIT SWITCH FOR AUTOMATIC ON WHEN DOOR IS OPENED. REFER TO SHEET 5111 FOR ADDITIONAL DETAILS
- 33 4" TYPE 'LC' LED STRIP LIGHT, C/W LIMIT SWITCH FOR AUTOMATIC ON WHEN DOOR IS OPENED. REFER TO SHEET 5111 FOR ADDITIONAL DETAILS
- 34 1x27mm CONDUIT FROM BUILDING MOUNTED SERVICE ASSEMBLY TO 120/208V SWITCHBOARD FOR REMOTE TRIPPING OF 120/208V SERVICE BREAKERS.
- 35 1x27mm CONDUIT FROM BUILDING MOUNTED SERVICE ASSEMBLY TO 120/208V SWITCHBOARD FOR HEATING AND LIGHTING CIRCUIT.
- 36 1x27mm CONDUIT FROM BUILDING MOUNTED SERVICE ASSEMBLY TO 480V SWITCHBOARD FOR REMOTE TRIPPING OF 480V SERVICE BREAKER.






2 5122 NTS 480V HARMONIC FILTER BANK EXTERIOR ELEVATION



1 5122 SCALE 1:20 EXISTING SSS 480V HARMONIC FILTER BANK PARTIAL SINGLE LINE DIAGRAM



3 5122 SCALE 1:20 REFURBISHED SSSR 480V HARMONIC FILTER BANK PARTIAL SINGLE LINE DIAGRAM

- KEYNOTES:
- EXTENT OF EXISTING HARMONIC FILTER BANK SYSTEM TO BE RELOCATED TO NEW SUBSTATION BUILDING, REFURBISHED AND RE-COMMISSIONED.
  - EXISTING ZSCT GROUND FAULT PROTECTION SYSTEM SENSORS, TO BE REMOVED AND REPLACED WITH NEW DURING REFURBISHMENT. CO-ORDINATE NEW EQUIPMENT WITH BUS AMPERAGE RATING AS WELL AS PHYSICAL DIMENSIONS OF BUS BARS AND CONDUCTORS.
  - EXISTING PROTECTION CTS AND 50S1 PROTECTION RELAY TO BE REMOVED AND REPLACED DURING REFURBISHMENT. CO-ORDINATE NEW EQUIPMENT WITH BUS AMPERAGE RATING AS WELL AS PHYSICAL DIMENSIONS OF BUS BARS AND CONDUCTORS.
  - EXISTING MERLIN GERIN 2000A BREAKER TO REMAIN. EXISTING SHUNT TRIP TO BE RE-USED WITH NEW PROTECTION DEVICES. RE-COMMISSIONED AND CONFIRM CORRECT OPERATION AS PART OF FILTER BANK REFURBISHMENT.
  - DISCONNECT EXISTING BUS DUCT AS PART OF HARMONIC FILTER BANK RELOCATION. ENSURE TERMINALS ARE SPACES AND ORIENT AS REQUIRED TO CONNECT TO NEW BUS DUCT IN SSSR.
  - EXISTING ION 7700 PROTECTION AND CONTROL METER, TO BE REPLACED WITH NEW DMS STYLE METER FOR PROTECTION AND REPORTING TO SCADA SYSTEM.
  - EXISTING ESTAMATE POWER FACTOR CORRECTION SYSTEM CONTROLLER TO BE REPLACED WITH NEW POWER FACTOR CORRECTION CONTROLLER (PFCC).
  - EXISTING CTS TO BE DISPOSED OF AS PART OF SSS DEMOLITION.
  - NEW CTS LOCATED IN 4SSSR-1 SWITCHBOARD FOR PFCC INPUT.
  - EXISTING BREAKER TO BE RECONNECTED TO NEW 2000A BUS DUCT.
  - EXISTING BREAKER SHUNT TRIP TO BE CONNECTED TO NEW DMS PROTECTION METER.
  - NEW DMS PROTECTION AND MONITORING METER, TO BE USED FOR DIGITAL METERING AND PROTECTION ON 2000A MAIN BREAKER TO ALLOW FOR CO-ORDINATION AND EQUIPMENT PROTECTION. TO COMMUNICATE WITH NEW PFCC SYSTEM AND REPORT BACK, TO SCADA WITH THE FOLLOWING DATA (VOLTAGE, AMPERES, kVA, kVAR, PFCC STATUS AND ALARMS, CAPACITOR STEPS).
  - PFCC AND DMS TO BE CAPABLE OF COMMUNICATION VIA RS-485. SYSTEM IS TO COMMUNICATE BETWEEN THESE TWO DEVICES VIA DIGITAL MEANS.
  - POWER FACTOR CORRECTION CONTROLLER, SELECTED TO REPLACE EXISTING ESTAMATE SYSTEM, TO BE CAPABLE OF DIGITAL COMMUNICATION WITH DMS AND SCADA SYSTEM. REFER TO SPECIFICATIONS FOR ADDITIONAL INFORMATION.
  - PROVIDE NEW PT 120/480V FOR DMS PROTECTION METER INPUTS.
  - REUSE EXISTING 120/480V PT FOR PFCC INPUT.

Revision/Revision	Description/Description	Date/Date
5	ISSUED FOR TENDER	15/01/28
4	ISSUED FOR 99% DESIGN REVIEW	16/01/06
3	ISSUED FOR 66% DESIGN REVIEW	15/11/25
2	ISSUED FOR 33% DESIGN REVIEW	15/10/28
1	ISSUED FOR DESIGN DEVELOPMENT	15/09/11
0		

Client/client  
**ESQUIMALT GRAVING DOCK**  
 825 ADMIRALS ROAD  
 VICTORIA, BC, V9A 2P1



Project title/Titre du projet  
**825 ADMIRALS ROAD VICTORIA BC  
 ESQUIMALT GRAVING DOCK  
 ELECTRICAL SAFETY UPGRADE**  
**SOUTH SUBSTATION  
 SWITCHGEAR  
 REPLACEMENT  
 (SSSR)**

Consultant Signature Box Only  
 Designed by/Concept par  
**I. BARNES**  
 Drawn by/Dessiné par  
**J. BIELING / S. SEYMOUR**  
 PWGSC Project Manager/Administrateur de Projets TPSGC  
**Jamie LeBlanc**  
 PWGSC Regional Manager, Architectural and Engineering Services/  
 Gestionnaire régionale, Services d'architecture et de génie, TPSGC  
**Preetpal Paul**

Drawing title/Titre du dessin  
**HARMONIC FILTER BANK EXISTING  
 AND REVISED SINGLE LINE DIAGRAM**

Project No./No. du projet	Sheet/Feuille	Revision no./ La Révision no.
R.062548.2	5122	5





SOUTH SIDE SUBSTATION REPLACEMENT LIGHTING CONTROL PANEL

Revision/Revisions	Description/Description	Date/Date
5	ISSUED FOR TENDER	15/01/28
4	ISSUED FOR 99% DESIGN REVIEW	16/01/06
3	ISSUED FOR 66% DESIGN REVIEW	15/11/25
2	ISSUED FOR 33% DESIGN REVIEW	15/10/28
1	ISSUED FOR DESIGN DEVELOPMENT	15/09/11
0		

Client/client

**ESQUIMALT GRAVING DOCK**

825 ADMIRALS ROAD  
VICTORIA, BC, V9A 2P1

Project title/Titre du projet  
**825 ADMIRALS ROAD VICTORIA BC  
ESQUIMALT GRAVING DOCK  
ELECTRICAL SAFETY UPGRADE**

**SOUTH SUBSTATION SWITCHGEAR REPLACEMENT (SSSR)**

Consultant Signature Box Only

Designed by/Concept par  
**I. BARNES**

Drawn by/Dessiné par  
**J. BIELING / S. SEYMOUR**

PWCSG Project Manager/Administrateur de Projets TPSGC  
**Jamie LeBlanc**

PWCSG Regional Manager, Architectural and Engineering Services/  
Gestionnaire régionale, Services d'architectural et de génie, TPSGC  
**Preetipal Paul**

Drawing title/Titre du dessin

**SOUTH SIDE SUBSTATION REPLACEMENT HIGH MAST LIGHTING CONTROLLER WIRING DIAGRAM**

Project No./No. du projet	Sheet/Feuille	Revision no./La Révision no.
<b>R.062548.2</b>	<b>5123</b>	<b>5</b>




**GENERAL NOTES**

1. ALL LV LOADS HAVE BEEN TRANSITIONED TO THE SSSR AT WHICH TIME THE TEMPORARY FEED TO THE SSSR WILL BE DISCONNECTED AND REMOVED. ALL EXISTING ELECTRICAL DISTRIBUTION EQUIPMENT, ASIDE FROM THE SMALL POWER PANELS AND FIRE ALARM EQUIPMENT, TO BE REMOVED FROM THE SSS AND COMPRESSOR ROOM.

**KEY NOTES:**


- 1 EXISTING PANEL 2SL1 TO BE REFEED FROM NEW ELECTRICAL DISTRIBUTION 2SSSR-SP-1, REFER TO SHEET 5108 FOR ADDITIONAL DETAILS.
- 2 EXISTING CABLES TO BE DISCONNECTED FROM SOUTH SIDE SUBSTATION SERVICES AND REMOVED, EXISTING CABLE TRAY TO BE DISMOUNTED AND REMOVED. REFER TO SHEET 5108 FOR ADDITIONAL DETAILS. DURING CONSTRUCTION PROVIDE TEMPORARY CONNECTION BETWEEN EXISTING STANDBY POWER PANEL AND EXISTING TRANSFER SWITCH TO ALLOW FOR UNINTERRUPTED OPERATION.
- 3 EXISTING WALL MOUNTED SPLITTER BOX AND INTERNAL ELECTRICAL DISCONNECT AND CONNECTION BOX TO BE REMOVED.
- 4 EXISTING WALL MOUNTED OUTDOOR LIGHT TO BE REMOVED
- 5 EXISTING WALL MOUNTED SIREN TO BE REMOVED.
- 6 EXISTING CCTV CAMERA CONTROL BOX AND FIBRE PATCH PANELS TO BE REMOVED AFTER TRANSFER AND COMMISSIONING OF COMMUNICATION SYSTEM IN NEW SSSR IS COMPLETE.
- 7 NOT USED
- 8 SCADA CONTROL AND SIGNALING DUCT WORK TO BE REMOVED AFTER TRANSFER AND COMMISSIONING OF NEW SSSR SCADA SYSTEM IS COMPLETE.
- 9 EXISTING SCADA CONTROL PANELS TO BE REMOVED AFTER TRANSFER AND COMMISSIONING OF NEW SSSR SCADA SYSTEM IS COMPLETE. ANY SERVICES CONNECTED TO MEASUREMENT INSTRUMENTS OUTSIDE EXISTING SOUTH SIDE SUBSTATION TO BE TRANSFERRED TO NEW METERS LOCATED IN NEW SSSR SCADA PANEL.
- 10 SOUTH SIDE OVERHEAD TECK CABLES AND CABLE TRAYS
  - REMOVE ALL CONDUITS, CABLES, RACKS AND HARDWARE RELATED AFTER EXISTING CONDUCTORS ARE DISCONNECTED.
  - PATCH ALL WALL ANCHOR POINTS AND PAINT TO MATCH EXISTING WALL COLOUR.
  - SEAL ALL WALL PENETRATIONS, REMOVE ALL WALL PENETRATION SLEEVES, CONDUITS, AND JOINTS AND SEAL WITH WATERPROOF GROUT. SMOOTH AND PAINT TO MATCH EXISTING.
- 11 SOUTH SIDE SUBSTATION 347/600V SWITCHBOARD 6SB DISTRIBUTION:
  - TRANSFER ALL REMAINING LOADS IN THIS SWITCHBOARD TO NEW PANEL 6SSSR-SP.
  - INSTALL CONTINUOUS NEW HOME RUNS WHERE SPECIFIED.
  - DISCONNECT THE CELL AND REMOVE ENTIRELY WHEN ALL CIRCUITS HAVE BEEN TRANSFERRED.
  - REPAIR AND PATCH ALL FLOOR/WALL PENETRATION AT EACH SWITCHGEAR CELL.
  - REMOVE ALL REDUNDANT CONDUITS, CABLES, RACKS AND HARDWARE RELATED TO THE DISTRIBUTION.
- 12 SOUTH SIDE SUBSTATION 2.4KV SWITCHBOARD 2.4SS DISTRIBUTION:
  - TRANSFER ALL TRAVELING CRANE LOAD IN THIS PANEL TO 2.4KV DISTRIBUTION IN NEW SSSR SECOND FLOOR
  - INSTALL CONTINUOUS NEW HOME RUNS WHERE SPECIFIED.
  - DISCONNECT THE CELLS AND REMOVE THEM ENTIRELY WHEN ALL CIRCUITS HAVE BEEN TRANSFERRED.
  - REPAIR AND PATCH ALL FLOOR/WALL PENETRATION AT EACH SWITCHGEAR CELL.
  - REMOVE ALL REDUNDANT CONDUITS, CABLES, RACKS AND HARDWARE RELATED TO THE DISTRIBUTION.
- 13 SOUTH SIDE SUBSTATION 480V SWITCHBOARD 4SS2 DISTRIBUTION:
  - TRANSFER ALL REMAINING LOADS IN THIS PANEL TO NEW 4SSSR-2 SWITCHBOARD.
  - INSTALL CONTINUOUS NEW HOME RUNS WHERE SPECIFIED.
  - DISCONNECT THE CELLS AND REMOVE THEM ENTIRELY WHEN ALL CIRCUITS HAVE BEEN TRANSFERRED.
  - REPAIR AND PATCH ALL FLOOR/WALL PENETRATION AT EACH SWITCHGEAR CELL.
  - REMOVE ALL REDUNDANT CONDUITS, CABLES, RACKS AND HARDWARE RELATED TO THE DISTRIBUTION.
- 14 SOUTH SIDE SUBSTATION 120/208V SWITCHBOARD 2SS2 DISTRIBUTION:
  - TRANSFER ALL REMAINING LOADS IN THIS PANEL TO NEW 2SSSR-1 SWITCHBOARD.
  - INSTALL CONTINUOUS NEW HOME RUNS WHERE SPECIFIED.
  - DISCONNECT THE CELLS AND REMOVE THEM ENTIRELY WHEN ALL CIRCUITS HAVE BEEN TRANSFERRED.
  - REPAIR AND PATCH ALL FLOOR/WALL PENETRATION AT EACH SWITCHGEAR CELL.
  - REMOVE ALL REDUNDANT CONDUITS, CABLES, RACKS AND HARDWARE RELATED TO THE DISTRIBUTION.
- 15 NOT USED
- 16 EXISTING OVERHEAD FEEDER BUS DUCTS TO BE DISCONNECTED AND REMOVED AFTER ALL LOADS ARE TRANSFERRED AND CONNECTED PANELS/DEVICES ARE DECOMMISSIONED.
- 17 EXISTING 480V 1000KVAR HARMONIC FILTER BANK TO BE RELOCATED INTO NEW SSSR SUBSTATION AND RECOMMISSIONED. REFER TO SHEET 5101 AND SHEET 5031 FOR EQUIPMENT LOCATION INFORMATION AND SHEET XXXX FOR EQUIPMENT RECOMMISSIONING INFORMATION.
- 18 SOUTH SIDE SUBSTATION 480V SWITCHBOARD 4SS1 DISTRIBUTION:
  - EXISTING 480V, 3000A MAIN BREAKER AND BUS DUCT CONNECTION CELLS TO BE DISCONNECTED AND REMOVED
  - EXISTING 480V, 400A MAIN BREAKER, 225/12.5kVA 480-120/208V STEP DOWN TRANSFORMER AND 800A 120/208V SECONDARY BREAKER AND BUS DUCT CONNECTION CELLS TO BE REMOVED.
- 19 SOUTH SIDE SUBSTATION T12-SSS-1 12.5kV/480V 2000kVA STEP DOWN TRANSFORMER
  - DISCONNECT THE CELL AND REMOVE ENTIRELY WHEN ALL CIRCUITS HAVE BEEN TRANSFERRED.
  - REPAIR AND PATCH ALL FLOOR/WALL PENETRATION AT EACH SWITCHGEAR CELL.
  - REMOVE ALL REDUNDANT CONDUITS, CABLES, RACKS AND HARDWARE RELATED TO THE DISTRIBUTION.
- 20 SOUTH SIDE SUBSTATION 12.5kV MAIN BREAKER AND DISCONNECT SWITCH CELLS
  - DISCONNECT THE CELL AND REMOVE ENTIRELY WHEN ALL CIRCUITS HAVE BEEN TRANSFERRED.
  - REPAIR AND PATCH ALL FLOOR/WALL PENETRATION AT EACH SWITCHGEAR CELL.
  - REMOVE ALL REDUNDANT CONDUITS, CABLES, RACKS AND HARDWARE RELATED TO THE DISTRIBUTION.
  - DISCONNECT AND REMOVE TEMPORARY FEED FROM SSSR. REFER TO SHEET 5101 FOR TEMPORARY FEED DETAILS.
- 21 SOUTH SIDE SUBSTATION 480-600V TRANSFORMER T4SS2
  - DISCONNECT THE TRANSFORMER AND REMOVE ENTIRELY WHEN ALL LOADS HAVE BEEN TRANSFERRED.
  - REPAIR AND PATCH ALL FLOOR/WALL PENETRATION AT EACH SWITCHGEAR CELL.
  - REMOVE ALL REDUNDANT CONDUITS, CABLES, RACKS AND HARDWARE RELATED TO THE INSTALLATION.
- 22 SOUTH SIDE SUBSTATION 600V-120 TRANSFORMER T6SB-2
  - DISCONNECT THE TRANSFORMER AND REMOVE ENTIRELY WHEN ALL LOADS HAVE BEEN TRANSFERRED.
  - REPAIR AND PATCH ALL FLOOR/WALL PENETRATION AT EACH SWITCHGEAR CELL.
  - REMOVE ALL REDUNDANT CONDUITS, CABLES, RACKS AND HARDWARE RELATED TO THE INSTALLATION.
- 23 SOUTH SIDE SUBSTATION 600V-480 TRANSFORMER T4SB-2
  - DISCONNECT THE TRANSFORMER AND REMOVE ENTIRELY WHEN ALL LOADS HAVE BEEN TRANSFERRED.
  - REPAIR AND PATCH ALL FLOOR/WALL PENETRATION AT EACH SWITCHGEAR CELL.
  - REMOVE ALL REDUNDANT CONDUITS, CABLES, RACKS AND HARDWARE RELATED TO THE INSTALLATION.

- 24 SOUTH SIDE SUBSTATION 208V PANEL 2SK DISTRIBUTION:
  - EXISTING NON BUILDING LOADS TO BE TRANSFERRED TO NEW 208V PANEL IN SSSR 2SSSR-1
  - REPAIR AND PATCH ALL FLOOR/WALL PENETRATIONS AT PANEL.
  - REMOVE ALL REDUNDANT CONDUITS, CABLES, RACKS AND HARDWARE RELATED TO THE DISTRIBUTION.
  - EXISTING PANEL AND BREAKERS TO BE RETAINED. MARK ALL UNUSED BREAKERS AS SPARES.
- 25 SOUTH SIDE SUBSTATION 480V PANEL 1SA DISTRIBUTION:
  - EXISTING LOADS TO BE TRANSFERRED TO NEW 480V STANDBY PANEL IN SSSR 4SSSR-SP
  - REPAIR AND PATCH ALL FLOOR/WALL PENETRATIONS AT PANEL.
  - REMOVE ALL REDUNDANT CONDUITS, CABLES, RACKS AND HARDWARE RELATED TO THE DISTRIBUTION.
  - PANEL TO BE DISMOUNTED AND DISPOSED OF.
- 26 EXISTING 480V, 200A DISCONNECT TO BE REMOVED AND ALL WALL PENETRATIONS AND ANCHOR POINTS PATCHED, SEALED AND REPAIRED.
- 27 EXISTING 480V POWER FEED FROM SOUTH SIDE SUBSTATION TO VICTORIA SHIPYARDS BARKER BUILDING. AFTER TRANSFER OF BARKER BUILDING FEEDS TO NEW 4SSSR-2 SWITCHBOARD AND RECONNECTION OF BARKER BUILDING VIA EXISTING DUCT BANK EXISTING TECK FEEDERS ARE TO BE REMOVED, WALL PENETRATIONS TO BE SEALED AND PAINTED TO MATCH EXISTING WALL COLOUR. CONDUIT STUBS TO BE CAPPED FOR FUTURE USE.
- 28 EXISTING COMMUNICATIONS AND FIRE ALARM SERVICES FROM SOUTH SIDE SUBSTATION TO VICTORIA SHIPYARDS BARKER BUILDING. AFTER TRANSFER OF BARKER BUILDING SERVICES TO NEW SOUTH SIDE SUBSTATION TELECOM VIA EXISTING DUCT BANK, EXISTING CONDUCTORS, LPS AND PULL BOXES ARE TO BE REMOVED. WALL PENETRATIONS TO BE SEALED AND PAINTED TO MATCH EXISTING WALL COLOUR. CONDUIT STUBS TO BE CUT DOWN TO 100mm ABOVE CONCRETE PLASTER AND CAPPED FOR FUTURE USE.
- 29 EXISTING COMMUNICATIONS, SCADA, FIRE ALARM AND POWER CONNECTIONS FROM SOUTH SIDE SUBSTATION TO EXISTING PULL BOXES NEAR HIGH MAST LIGHTING. EXISTING SERVICES TO BE RECONNECTED VIA EXISTING DUCT BANK TO NEW SSSR, AND ALL CONDUITS CUT BACK TO 100mm ABOVE PLASTER AND CAPPED AS SPARE. WALL PENETRATIONS TO BE SEALED AND PAINTED TO MATCH EXISTING WALL COLOUR.
- 30 EXISTING JETTY MOUNT SERVICE TO BE REMOVED. EXISTING TECK CABLES TO BE REMOVED FROM CONDUITS AND DISPOSED OF. EXISTING COMMUNICATIONS CABLES TO BE REMOVED FROM CONDUITS AND DISPOSED OF. ALL DIRECT BURIED CABLES TO BE DISCONNECTED AND MADE SAFE. ALL CONDUITS TO BE CUT DOWN TO 100mm ABOVE PLASTER AND CAPPED AS SPARE. WALL PENETRATIONS TO BE SEALED AND PAINTED TO MATCH EXISTING WALL COLOUR. EXISTING EXTERIOR AND INTERIOR WALL MOUNTED CABLE TRAY TO BE REMOVED.
- 31 EXISTING SOUTH SIDE SUBSTATION INTERIM HIGH VOLTAGE, LOW VOLTAGE AND COMMUNICATIONS SERVICE. AFTER TRANSFER TO LOADS THESE SERVICES ARE TO BE DISCONNECTED. HIGH VOLTAGE FEED FROM SSSR TO BE PULLED OUT OF DUCT BANK AND DISPOSED OF. LOW VOLTAGE TO BE TRANSFERRED TO APPROPRIATE SSSR SWITCHBOARDS. ALL CONDUITS TO BE CUT DOWN TO 100mm ABOVE PLASTER AND CAPPED AS SPARE. WALL PENETRATIONS TO BE SEALED AND PAINTED TO MATCH EXISTING WALL COLOUR. EXISTING EXTERIOR AND INTERIOR WALL MOUNTED CABLE TRAY TO BE REMOVED.
- 32 EXISTING SOUTH SIDE SUBSTATION ACCESS STAIRWAY TO BE REMOVED DURING SSSR CONSTRUCTION PHASE AND REINSTATED BEFORE FINAL HAND OVER TO PUBLIC WORKS. REFER TO ARCHITECTURAL AND CIVIL SHEETS FOR ADDITIONAL INFORMATION.
- 33 EXISTING WALL MOUNTED TUNNEL LIGHTS TO BE REMOVED AND RELOCATED TO OPPOSITE SIDE OF TUNNEL WALL AFTER NEW SSSR SPLICE BOXES AND LOAD TRANSFER IS COMPLETE.
- 34 EXISTING JUNCTION BOX TO BE REMOVED
- 35 EXISTING SERVICE METER TO BE REMOVED.
- 36 EXISTING ROPE LIGHTS SPLICE BOX TO BE REMOVED AFTER RECONNECTION OF ROPE LIGHTS VIA TUNNEL SPLICES.
- 37 EXISTING DISCONNECT SWITCH TO BE REMOVED. SERVICE TO BE RECONNECTED FROM NEW SSSR 480V SWITCHBOARD
- 38 COMPRESSOR ROOM 600V SWITCHBOARD 6SC
  - DISCONNECT THE TRANSFORMER AND REMOVE ENTIRELY WHEN ALL LOADS HAVE BEEN TRANSFERRED.
  - REPAIR AND PATCH ALL FLOOR/WALL PENETRATION AT EACH SWITCHGEAR CELL.
  - REMOVE ALL REDUNDANT CONDUITS, CABLES, RACKS AND HARDWARE RELATED TO THE INSTALLATION. PANEL TO BE DISMOUNTED AND DISPOSED OF.
- 39 COMPRESSOR ROOM T2-4-SC 2.4kV/600V 1000kVA STEP DOWN TRANSFORMER
  - DISCONNECT THE CELL AND REMOVE ENTIRELY WHEN ALL CIRCUITS HAVE BEEN TRANSFERRED.
  - REPAIR AND PATCH ALL FLOOR/WALL PENETRATION AT EACH SWITCHGEAR CELL.
  - REMOVE ALL REDUNDANT CONDUITS, CABLES, RACKS AND HARDWARE RELATED TO THE DISTRIBUTION.
- 40 COMPRESSOR ROOM 2.4KV MAIN BREAKER AND DISCONNECT SWITCH CELLS
  - DISCONNECT THE CELL AND REMOVE ENTIRELY WHEN ALL CIRCUITS HAVE BEEN TRANSFERRED.
  - REPAIR AND PATCH ALL FLOOR/WALL PENETRATION AT EACH SWITCHGEAR CELL.
  - REMOVE ALL REDUNDANT CONDUITS, CABLES, RACKS AND HARDWARE RELATED TO THE DISTRIBUTION.
- 41 COMPRESSOR ROOM SCADA PANEL COMMUNICATION FEEDS TO BE TRANSFERRED TO NEW SSSR SCADA PANEL
- 42 EXISTING COMPRESSOR ROOM 10kVA 600-120/240V TRANSFORMER TO BE REMOVED
- 43 EXISTING 120/240V COMPRESSOR ROOM CONTROL POWER PANEL TO BE REFEED FROM 2SSSR-SP-1
- 44 NEW SERVICE TUNNEL COVER PLATES TO BE SUPPLIED TO REPLACE EXISTING. REFER TO ARCHITECTURAL DETAILS FOR ADDITIONAL INFORMATION.
- 45 EXISTING COMPRESSOR ROOM 120/208V 3Ø 4W 100A PANEL 2T TO REMAIN.



1 SOUTH SIDE SUBSTATION MAIN FLOOR  
SCALE 1:50

2 SOUTH SIDE SUBSTATION CABLE PIT  
SCALE 1:50



Revision/Revisions	Description/Description	Date/Date
5	ISSUED FOR TENDER	15/01/28
4	ISSUED FOR 90% DESIGN REVIEW	16/01/06
3	ISSUED FOR 60% DESIGN REVIEW	15/11/25
2	ISSUED FOR 33% DESIGN REVIEW	15/10/28
1	ISSUED FOR DESIGN DEVELOPMENT	15/09/11
0		

**ESQUIMALT GRAVING DOCK**  
825 ADMIRALS ROAD VICTORIA, BC, V9A 2P1


Project title/Titre du projet  
**825 ADMIRALS ROAD VICTORIA BC ESQUIMALT GRAVING DOCK ELECTRICAL SAFETY UPGRADE**  
**SOUTH SUBSTATION SWITCHGEAR REPLACEMENT (SSSR)**

Consultant Signature Box Only  
Designed by/Concept par I. BARNES  
Drawn by/Dessiné par J. BIELING / S. SEYMOUR  
PWGSC Project Manager/Administrateur de Projets TPSGC Jamie LeBlanc  
PWGSC, Regional Manager, Architectural and Engineering Services/ Gestionnaire régionale, Services d'architecture et de génie, TPSGC Preetipal Paul

Drawing title/Titre du dessin  
**EXISTING SOUTH SIDE SUBSTATION DEMOLITION AND REMEDIATION WORK**

Project No./No. du projet	Sheet/Feuille	Revision no./no. de révision
R.062548.2	5130	5





5	ISSUED FOR TENDER	15/01/28
4	ISSUED FOR 99% DESIGN REVIEW	16/01/06
3	ISSUED FOR 66% DESIGN REVIEW	15/11/25
2	ISSUED FOR 33% DESIGN REVIEW	15/10/28
1	ISSUED FOR DESIGN DEVELOPMENT	15/09/11
0		

Revision/ Révision	Description/Description	Date/Date
--------------------	-------------------------	-----------

Client/client

**ESQUIMALT GRAVING DOCK**

**825 ADMIRALS ROAD VICTORIA, BC, V9A 2P1**

Project title/Titre du projet  
**825 ADMIRALS ROAD VICTORIA BC ESQUIMALT GRAVING DOCK ELECTRICAL SAFETY UPGRADE**

**SOUTH SUBSTATION SWITCHGEAR REPLACEMENT (SSSR)**

Consultant Signature Box Only

Designed by/Concept par  
**I. BARNES**

Drawn by/Dessiné par  
**J. BIELING / S. SEYMOUR**

PWSC Project Manager/Administrateur de Projets TPSGC  
**Jamie LeBlanc**

PWSC Regional Manager, Architectural and Engineering Services/ Gestionnaire régionale, Services d'architecture et de génie, TPSGC  
**Preetpal Paul**

Drawing title/Titre du dessin



**SECOND FLOOR GROUNDING LAYOUT**


Project No./No. du projet <b>R.062548.2</b>	Sheet/Feuille <b>5400</b>	Revision no./La Révision no. <b>5</b>
--	------------------------------	--



LEGEND	
	GROUND ROD WITH ACCESS
	GROUND ROD WITHOUT ACCESS
	GROUND ROD CONDUCTOR RISER TO 2ND FLOOR
	COMPRESSION CONNECTOR
	#40 GROUND CONDUCTOR
	#20 GROUND CONDUCTOR


- GENERAL NOTES:**
- GROUNDING SYSTEM SHALL BE INSTALLED PER CANADIAN ELECTRICAL CODE.
  - BUILDING UFER GROUND CONDUCTOR CONNECTED TO GROUND GRID.
  - STEP AND TOUCH GRID SHOWN IS ON UPPER FLOOR LEVEL.
  - FLOOR SHOWN IS SECOND FLOOR. GROUND CONDUCTORS TO RUN DOWN TO FIRST FLOOR GROUND LEVEL IN RISERS BEFORE ENTERING GROUND GRID AT INDICATED LOCATIONS.






LEGEND	
	INTERCEPTING CONDUCTOR WITH DOWN CONDUCTOR CONNECTION
	DOWN CONDUCTOR CONNECTION TO GROUND ROD, THERMIT TYPE CONNECTION
	AIR TERMINAL
	INTERCEPTING CONDUCTOR CONNECTION TO METALLIC DEVICE ON ROOF

- GENERAL NOTES:**
- LIGHTNING PROTECTION SYSTEM SHALL COMPLY WITH OR EXCEED REQUIREMENTS OF CAN/CSA-B72-M87 INSTALLATION CODE FOR LIGHTNING PROTECTION SYSTEMS FOR CLASS 1 INSTALLATION.
  - ALL LIGHTNING PROTECTION EQUIPMENT SHALL BE RATED MINIMUM CLASS 1 MATERIAL.
  - AS PER CAN/CSA-B72-M87 REQUIREMENT, CONTRACTOR SHALL TEST THAT LIGHTNING PROTECTION SYSTEM PROVIDES A RESISTANCE TO GROUND OF LESS THAN 50 OHMS WHEN MEASURED AT ANY POINT BETWEEN INTERCEPTING SYSTEM AND THE GROUND SYSTEM. IF NECESSARY, AUXILIARY GROUND ELECTRODES SHALL BE ADDED TO OBTAIN THIS VALUE.
  - INTERCEPTING CONDUCTORS AND DOWN CONDUCTORS SHALL BE BARE STRANDED COPPER MINIMUM #2 AWG.
  - GROUND ROD, COPPER OR COPPER-CLAD STEEL TYPE MINIMUM 19mm DIAMETER x 3048mm LONG. CONNECTION TO DOWN CONDUCTORS SHALL BE MINIMUM 150mm BELOW GRADE. GROUND RODS TO BE INSTALLED IN GROUND ROD INSPECTION WELL BOX MINIMUM 300x300x450mm SIZE.
  - EACH GROUND ROD OF LIGHTNING PROTECTION SYSTEM SHALL BE CONNECTED TO THE GROUND GRID SYSTEM VIA THERMIT TYPE CONNECTION.
  - ALL CONDUCTIVE MATERIALS ON ROOF SHALL BE CONNECTED TO INTERCEPTING CONDUCTOR.
  - ALL PARAPET PENETRATIONS SHALL BE SEALED WITH SUITABLE CAULKING.
  - AIR TERMINALS SHALL BE SOLID ROD 9.5MM IN DIAMETER COPPER AND SHALL EXTEND NOT LESS THAN 50MM ABOVE HIGHEST PART OF ROOF. COORDINATE AIR TERMINAL INSTALLATION ON MECHANICAL UNIT WITH DIV 25 CONTRACTOR AND EQUIPMENT SUPPLIER.
  - DOWN CONDUCTORS SHALL BE ROUTED SUCH THAT THEY ARE NOT DIRECTLY BEHIND ANY ELECTRICAL EQUIPMENT MOUNTED ON THE INTERIOR WALL. A MINIMUM HORIZONTAL DISTANCE OF 300mm MUST BE MAINTAINED FROM ANY INTERIOR WALL MOUNTED ELECTRICAL EQUIPMENT.
  - CO-ORDINATE ANY REQUIRED SUPPORT OR GYE WIRES WITH ARCHITECTURAL AND STRUCTURAL DISCIPLINES.
- KEYNOTES:**
- INTERCEPTING CONDUCTORS AND DOWN CONDUCTORS SHALL BE BARE STRANDED COPPER MINIMUM No.2 AWG.
  - LIGHTNING GROUND RODS REQUIRED IN ADDITION TO GROUND GRID RODS. SEE SHEET 5400 FOR GROUND GRID DETAILS.



1 SERVICE ENTRANCE SUBSTATION ROOF – PLAN VIEW  
SCALE 1:50



2 SERVICE ENTRANCE SUBSTATION ELEVATION – SOUTH VIEW  
SCALE 1:100

Revision/ Révision	Description/ Description	Date/ Date
5	ISSUED FOR TENDER	15/01/28
4	ISSUED FOR 99% DESIGN REVIEW	16/01/06
3	ISSUED FOR 66% DESIGN REVIEW	15/11/25
2	ISSUED FOR 33% DESIGN REVIEW	15/10/28
1	ISSUED FOR DESIGN DEVELOPMENT	15/09/11
0		

Client/client

**ESQUIMALT GRAVING DOCK**

825 ADMIRALS ROAD  
VICTORIA, BC, V9A 2P1

Project title/Titre du projet  
825 ADMIRALS ROAD VICTORIA BC  
ESQUIMALT GRAVING DOCK  
ELECTRICAL SAFETY UPGRADE

**SOUTH SUBSTATION SWITCHGEAR REPLACEMENT (SSSR)**

Consultant Signature Box Only

Designed by/Concept par  
**I. BARNES**

Drawn by/Dessiné par  
**J. BIELING / S. SEYMOUR**


PWCSG Project Manager/Administrateur de Projets TPSGC  
**Jamie LeBlanc**


PWCSG Regional Manager, Architectural and Engineering Services/  
Gestionnaire régionale, Services d'architectural et de génie, TPSGC  
**Preetpal Paul**

Drawing title/Titre du dessin

**LIGHTNING PROTECTION**

Project No./No. du projet	Sheet/Feuille	Revision no./ La Révision no.
R.062548.2	5401	5






EGD DUCTBANK CONDUIT NAMING CONVENTION


1. CONDUIT CUT SECTIONS ARE TAKEN LOOKING WEST DOWN THE SITE AND LOOKING OUT FROM EACH MANHOLE FACE OR BUILDING.
2. CONDUITS ARE NAMED ACCORDING TO THE VERTICAL AND HORIZONTAL ROW AT WHICH THEY LEAVE A MANHOLE OR BUILDING.

3-1	3-2	3-3
2-1	2-2	2-3
1-1	1-2	1-3

3. CONDUITS ARE NAMED FROM MANHOLE OR BUILDING IT IS COMING FROM TO THE MANHOLE OR BUILDING IT IS GOING TO. CONDUITS ARE NAMED FOR THE LOWEST NUMBERED MANHOLE TO THE NEXT BOX. SO A CONDUIT RUNNING FROM 102LV TO 105LV WOULD BE NAMED IN MANHOLE 102LV NOT 105 LV. IF CONDUIT 2-3 FROM ABOVE IS GOING FROM MANHOLES 102LV TO 105LV THEN THIS CONDUIT WOULD BE NAMED 102LV-105LV:1-1.
4. IF A SPACE EXISTS IN ONE OF THE CONDUIT ROWS OR COLUMNS IT IS SKIPPED AND ITS IDENTIFIER IS NOT USED. FOR EXAMPLE THE FOLLOWING CONDUITS ARE IDENTIFIED AS SHOWN:



5. CONDUITS ENTERING A MANHOLE VIA THE SAME FACE AS CONDUITS EXITING A MANHOLE OR BUILDING ARE IGNORED FOR THE PURPOSES OF CREATING THE EXITING CONDUIT'S MATRIX.



5	ISSUED FOR TENDER	15/01/28
4	ISSUED FOR 99% DESIGN REVIEW	16/01/06
3	ISSUED FOR 66% DESIGN REVIEW	15/11/25
2	ISSUED FOR 33% DESIGN REVIEW	15/10/28
1	ISSUED FOR DESIGN DEVELOPMENT	15/09/11
0		

Revision/ Révision	Description/Description	Date/Date
--------------------	-------------------------	-----------

Client/client

**ESQUIMALT GRAVING DOCK**

**825 ADMIRALS ROAD VICTORIA, BC, V9A 2P1**

Project title/Titre du projet  
**825 ADMIRALS ROAD VICTORIA BC ESQUIMALT GRAVING DOCK ELECTRICAL SAFETY UPGRADE**

**SOUTH SUBSTATION SWITCHGEAR REPLACEMENT (SSSR)**

Consultant Signature Box Only

Designed by/Concept par  
**I. BARNES**

Drawn by/Dessiné par  
**J. BIELING / S. SEYMOUR**

PWGSC Project Manager/Administrateur de Projets TPSGC  
**Jamie LeBlanc**


PWGSC Regional Manager, Architectural and Engineering Services/ Gestionnaire régionale, Services d'architecture et de génie, TPSGC  
**Preetpal Paul**

Drawing title/Titre du dessin


**EGD DUCT BANK CONDUIT NAMING CONVENTION**

Project No./No. du projet <b>R.062548.2</b>	Sheet/Feuille <b>5410</b>	Revision no./La Révision no. <b>5</b>
--	------------------------------	--






KEYPLAN




**KEYNOTES:**  
 ① CONTRACTOR TO SUPPLY 3 SETS OF 2 RACKS PER HV MANHOLE.  
 CONTRACTOR TO INSTALL SUPPORT CANTRUSS IN LV AND COMM MANHOLES TO ALLOW INSTALLATION OF RACKS IN FUTURE.

1 TYPICAL 27kV CABLE SUPPORT IN HV MANHOLES  
 SCALE 1:5  
 5411



**KEYNOTES:**  
 ① INSTALL ONE GROUND ROD IN EACH MANHOLE AT SUMP END OF BASE. CONNECT TO #4/0 GROUND.  
 ② COMPRESSION TAP CONNECTOR  
 ③ #2/0 BONDING CONDUCTOR FOR EACH SUPPORT STRUT LOCATION ON MANHOLE WALLS.  
 ④ GALVANIZED CABLE STRAP  
 ⑤ #4/0 AWG GREEN INSULATED GROUND FOR EACH BRANCH DUCT BANK.  
 ⑥ #4/0 AWG GREEN INSULATED GROUND TO MAIN SUBSTATION.  
 ⑦ FOR LID FRAME GROUNDING SEE REFERENCE 1.  
 ⑧ TO NEXT MANHOLE WHERE APPLICABLE.

2 HV MANHOLE GROUNDING DETAILS  
 N.T.S.  
 5411



3 DUCT INSTALLATION WITH PLASTIC SPACERS  
 N.T.S.  
 5411

5	ISSUED FOR TENDER	15/01/28
4	ISSUED FOR 99% DESIGN REVIEW	16/01/06
3	ISSUED FOR 66% DESIGN REVIEW	15/11/25
2	ISSUED FOR 33% DESIGN REVIEW	15/10/28
1	ISSUED FOR DESIGN DEVELOPMENT	15/09/11
0		
Revision/Revisión	Description/Description	Date/Date

Client/Client

**ESQUIMALT GRAVING DOCK**

825 ADMIRALS ROAD  
 VICTORIA, BC, V9A 2P1

Project title/Titre du projet  
**825 ADMIRALS ROAD VICTORIA BC  
 ESQUIMALT GRAVING DOCK  
 ELECTRICAL SAFETY UPGRADE**

**SOUTH SUBSTATION SWITCHGEAR REPLACEMENT (SSSR)**



Consultant Signature Box Only

Designed by/Concept par  
**I. BARNES**  
 Drawn by/Dessiné par  
**J. BIELING / S. SEYMOUR**  
 PWGSC Project Manager/Administrateur de Projets TPSGC  
**Jamie LeBlanc**  
 PWGSC Regional Manager, Architectural and Engineering Services/  
 Gestionnaire régional, Services d'architectural et de génie, TPSGC  
**Preetipal Paul**

Drawing title/Titre du dessin


**MINI MANHOLE DETAILS, GROUNDING AND MISCELLANEOUS DETAILS**

Project No./No. du projet	Sheet/Feuille	Revision no./La Révision no.
R.062548.2	5411	5




4 CONDUIT PILASTER STUB UP DETAILS  
 N.T.S.  
 5411






- GENERAL NOTES:
- SEE SHEET 5411 FOR MANHOLE DIMENSIONS AND CONSTRUCTION DETAILS.
  - SEE SHEET 5411 FOR CONDUIT SPACER DETAILS.
  - SEE SHEET 5411 FOR HIGH VOLTAGE MANHOLE GROUNDING DETAILS.
  - IDENTIFY ALL FEEDER CABLES WITH COLOURED TAGS HAVING 4 SLOTTED TIE HOLES AND SECURED WITH TWO PLASTIC TAG TIES.
  - ALL MANHOLES SHALL BE EQUIPPED WITH CONDUIT DIRECTORIES. EACH WALL OF THE MANHOLE WITH CONDUIT ENTRY SHALL HAVE A DIRECTORY. SEE SPECIFICATION FOR DIRECTORY DETAILS.
  - ALL MANHOLE COVERS SHALL HAVE ASSIGNED MANHOLE NUMBER WELDED ONTO EXTERIOR OF LID.



1 MINI-MANHOLE (143HV)  
SCALE 1:25



2 MINI-MANHOLE (140HV)  
SCALE 1:25

5	ISSUED FOR TENDER	15/01/28
4	ISSUED FOR 99% DESIGN REVIEW	16/01/06
3	ISSUED FOR 66% DESIGN REVIEW	15/11/25
2	ISSUED FOR 33% DESIGN REVIEW	15/10/28
1	ISSUED FOR DESIGN DEVELOPMENT	15/09/11
0		

Revision/Revisions	Description/Description	Date/Date
--------------------	-------------------------	-----------

Client/client

**ESQUIMALT GRAVING DOCK**

**825 ADMIRALS ROAD VICTORIA, BC, V9A 2P1**

Project title/Titre du projet  
**825 ADMIRALS ROAD VICTORIA BC  
ESQUIMALT GRAVING DOCK  
ELECTRICAL SAFETY UPGRADE**

**SOUTH SUBSTATION SWITCHGEAR REPLACEMENT (SSSR)**

Consultant Signature Box Only

Designed by/Concept par  
**I. BARNES**

Drawn by/Dessine par  
**J. BIELING / S. SEYMOUR**


PWCSC Project Manager/Administrateur de Projets TPSGC  
**Jamie LeBlanc**



PWCSC Regional Manager, Architectural and Engineering Services/  
Gestionnaire régionale, Services d'architectural et de génie, TPSGC  
**Prestipal Paul**

Drawing title/Titre du dessin


**EXISTING HIGH VOLTAGE MANHOLE DETAILS**

Project No./No. du projet	Sheet/Feuille	Revision no./La Révision no.
<b>R.062548.2</b>	<b>5412</b>	<b>5</b>







1 MINI-MANHOLE (144LV)  
5413 SCALE 1:25




2 MINI-MANHOLE (144LV)  
5413 SCALE 1:25



3 MINI-MANHOLE (144LV)  
5413 SCALE 1:25



4 MINI-MANHOLE (144LV)  
5413 SCALE 1:25



KEYNOTES:

- ① 1000mm LONG, CABLE SUPPORT HOOKS MOUNTED TO STEEL SUPPORT CHANNELS TO BE HOT DIP GALVANIZED CONSTRUCTION AND SUITABLE FOR MOUNTING INSULATED PORCELAIN SUPPORT PADS. HOOKS TO BE MOUNTED SUCH THAT THE 3c AND 4c 350KCM CABLES PASS THROUGH THE MANHOLE IN A STRAIGHT RUN AND CAN BE SPLICED ON THE SUPPORTS.
- ② PORCELAIN CABLE RACK INSULATOR PADS, SIZED TO SUPPORT 4c#350KCM TECK CABLE SPLICES.
- ③ NOT USED
- ④ NOT USED
- ⑤ CONDUITS FROM MANHOLE TO NEW SSSR BASEMENT.
- ⑥ SUMP PIT
- ⑦ CONDUIT PENETRATIONS IN MANHOLE WALL. REFER TO SECTION SSSR/5416 FOR ADDITIONAL DETAILS.
- ⑧ CONDUIT PENETRATIONS IN MANHOLE WALL. REFER TO SECTION SJ/5416 FOR ADDITIONAL DETAILS.
- ⑨ CONDUITS FROM EXISTING DUCT. REFER TO SECTION SS5415 FOR ADDITIONAL DETAILS.

GENERAL NOTES:

1. SEE SHEET 5411 FOR MANHOLE DIMENSIONS AND CONSTRUCTION DETAILS.
2. SEE SHEET 5411 FOR CONDUIT SPACER DETAILS.
3. SEE SHEET 5411 FOR HIGH VOLTAGE MANHOLE GROUNDING DETAILS.
4. IDENTIFY ALL FEEDER CABLES WITH COLOURED TAGS HAVING 4 SLOTTED HOLES AND SECURED WITH TWO PLASTIC TAG TIES.
5. ALL MANHOLES SHALL BE EQUIPPED WITH CONDUIT DIRECTORIES. EACH WALL OF THE MANHOLE WITH CONDUIT ENTRY SHALL HAVE A DIRECTORY. SEE SPECIFICATION FOR DIRECTORY DETAILS.
6. ALL MANHOLE COVERS SHALL HAVE ASSIGNED MANHOLE NUMBER WELDED ONTO EXTERIOR OF LID.



Revision/Revisions	Description/Description	Date/Date
5	ISSUED FOR TENDER	15/01/28
4	ISSUED FOR 99% DESIGN REVIEW	16/01/06
3	ISSUED FOR 66% DESIGN REVIEW	15/11/25
2	ISSUED FOR 33% DESIGN REVIEW	15/10/28
1	ISSUED FOR DESIGN DEVELOPMENT	15/09/11
0		

Client/client

**ESQUIMALT GRAVING DOCK**

**825 ADMIRALS ROAD VICTORIA, BC, V9A 2P1**

Project title/Titre du projet  
**825 ADMIRALS ROAD VICTORIA BC  
ESQUIMALT GRAVING DOCK  
ELECTRICAL SAFETY UPGRADE**

**SOUTH SUBSTATION SWITCHGEAR REPLACEMENT (SSSR)**

Consultant Signature Box Only

Designed by/Concept par  
**I. BARNES**

Drawn by/Dessiné par  
**J. BIELING / S. SEYMOUR**


PWCS Project Manager/Administrateur de Projets TPSGC  
**Jamie LeBlanc**

PWCS Regional Manager, Architectural and Engineering Services/  
Gestionnaire régionale, Services d'architecture et de génie, TPSGC  
**Preetpal Paul**


Drawing title/Titre du dessin

**EXISTING LOW VOLTAGE MANHOLE DETAILS**


Project No./No. du projet	Sheet/Feuille	Revision no./La Révision no.
<b>R.062548.2</b>	<b>5413</b>	<b>5</b>



- GENERAL NOTES:**
- SEE SHEET 5411 FOR MANHOLE DIMENSIONS AND CONSTRUCTION DETAILS.
  - SEE SHEET 5411 FOR CONDUIT SPACER DETAILS.
  - SEE SHEET 5411 FOR HIGH VOLTAGE MANHOLE GROUNDING DETAILS.
  - IDENTIFY ALL FEEDER CABLES WITH COLOURED TAGS HAVING 4 SLOTTED TIE HOLES AND SECURED WITH TWO PLASTIC TAG TIES.
  - ALL MANHOLES SHALL BE EQUIPPED WITH CONDUIT DIRECTORIES. EACH WALL OF THE MANHOLE WITH CONDUIT ENTRY SHALL HAVE A DIRECTORY. SEE SPECIFICATION FOR DIRECTORY DETAILS.
  - ALL MANHOLE COVERS SHALL HAVE ASSIGNED MANHOLE NUMBER WELDED ONTO EXTERIOR OF LID.



1 MINI-MANHOLE (145C)  
SCALE 1:25  
5414



2 MINI-MANHOLE (142C)  
SCALE 1:25  
5414

5	ISSUED FOR TENDER	15/01/28
4	ISSUED FOR 99% DESIGN REVIEW	16/01/06
3	ISSUED FOR 66% DESIGN REVIEW	15/11/25
2	ISSUED FOR 33% DESIGN REVIEW	15/10/28
1	ISSUED FOR DESIGN DEVELOPMENT	15/09/11
0		

Revision/Revision	Description/Description	Date/Date
-------------------	-------------------------	-----------

Client/client

**ESQUIMALT GRAVING DOCK**

825 ADMIRALS ROAD  
VICTORIA, BC, V9A 2P1

Project title/Titre du projet  
**825 ADMIRALS ROAD VICTORIA BC  
ESQUIMALT GRAVING DOCK  
ELECTRICAL SAFETY UPGRADE**

**SOUTH SUBSTATION  
SWITCHGEAR  
REPLACEMENT  
(SSSR)**

Consultant Signature Box Only

Designed by/Concept par  
**I. BARNES**

Drawn by/Dessiné par  
**J. BIELING / S. SEYMOUR**


PWCS Project Manager/Administrateur de Projets TPSGC  
**Jamie LeBlanc**

PWCS Regional Manager, Architectural and Engineering Services/  
Gestionnaire régionale, Services d'architecture et de génie, TPSGC  
**Preetpal Paul**

Drawing title/Titre du dessin

**EXISTING COMMUNICATIONS  
MANHOLE DETAILS**


Project No./No. du projet <b>R.062548.2</b>	Sheet/Feuille <b>5414</b>	Revision no./ La Révision no. <b>5</b>
--	------------------------------	--





GENERAL NOTES:

- ALL HV CONDUITS ON THIS SHEET ARE 129mm. ALL OTHER CONDUITS ON THIS SHEET ARE 103mm UNLESS NOTED OTHERWISE.
- ALL CONCRETE ENCASED CONDUITS ARE SCHEDULE 40 RIGID PVC CONDUITS.
- REINFORCE DUCT BANKS WITH 15M BARS RUN CONTINUOUSLY IN ALL 4 CORNERS OF THE DUCT BANK.
- INSTALL ONE CONTINUOUS 4/0 INSULATED COPPER GROUND CONDUCTORS IN THE BOTTOM OF EVERY DUCT BANK. TIE IN GROUNDS AT EVERY MANHOLE AND DISTRIBUTION CENTER TO PROVIDE ELECTRICAL CONTINUITY SITE WIDE.
- PROVIDE ADDITIONAL GROUNDS WHERE DUCT BANKS FAN OUT INTO SEPARATE MANHOLES.
- BOND ALL METAL RACKING LOCATIONS IN EVERY MANHOLE.
- USE UNDERGROUND DUCT SPACERS WITH 190mmx190mm DUCT CENTER TO CENTER MEASUREMENT EXCEPT WHERE NOTED.
- ALL CONDUITS MUST BE ENCASED IN A MINIMUM OF 50mm OF CONCRETE.
- MAINTAIN 300mm SEPARATION BETWEEN COMMUNICATIONS CONDUITS AND POWER CONDUITS. FIBRE OPTIC CONDUITS MAY BE INSTALLED WITHIN THE 300mm SEPARATION.
- ALL DUCTBANKS SHALL BE INSTALLED IN ACCORDANCE WITH CANADIAN ELECTRICAL CODE.
- REFER TO SITE PLANS FOR SPACING BETWEEN DUCTBANKS.



SS 5415 DUCT SECTION DETAIL  
SCALE 1:10

CONDUIT AND CABLE SCHEDULE								
CUT SECTION	CONDUIT ROUTE	CONDUIT ID	SIZE (mm)	TYPE	SYSTEM NOMINAL VOLTAGE	CONDUCTORS	COMMENTS	
SS	140HV - 143HV	1-1	129	HV	12.5/25/12.5kV	EMPTY	FUTURE	
		1-2	129	HV	12.5/25/12.5kV	3x1c#250KCM	FEEDER TO EXISTING SOUTH SUBSTATION	
		2-1	129	HV	12.5/25/12.5kV	EMPTY	FUTURE	
		2-2	129	HV	12.5/25/12.5kV	EMPTY	FUTURE	
	141LV - 144LV	1-1	103	LV	600V	4c#350KCM RW90		B-1 FEEDER
		1-2	103	LV	600V	4c#350KCM RW90		B-1 FEEDER
		1-3	103	LV	600V	EMPTY		FUTURE DOCK RECEPTACLES #1, FUTURE DOCK RECEPTACLES #2
		1-4	103	LV	600V	4c#6, 3x#2 TECK, 2x(3c#10 TECK)		HIGH MAST LIGHTING #2, LIFT STATION #11 POWER, SUMP #1 PANEL, SUMP #2 PANEL
		2-1	103	LV	600V	4c#350KCM RW90		B-1 FEEDER
		2-2	103	LV	600V	4c#350KCM RW90		B-1 FEEDER
		2-3	103	LV	600V	EMPTY		FUTURE DOCK RECEPTACLES #3, FUTURE DOCK RECEPTACLES #4
		2-4	103	LV	600V	EMPTY		FUTURE
		3-1	103	LV	600V	EMPTY		FUTURE
		3-2	103	LV	600V	EMPTY		FUTURE
		3-3	103	LV	600V	EMPTY		FUTURE
		3-4	103	LV	600V	EMPTY		FUTURE
	142C- 145C	1-1	103	COMM	EMPTY	2xCoax		SHAW CABLE
		1-2	103	COMM	N/A	4c#12TECK, 8c#12 TECK		LIFT STATION #11 SCADA ALARM, SUMP #1 & SUMP #2 WATER SCADA ALARM
		1-3	103	COMM	EMPTY	1x48 50/125um SSM, 2x48 9/125um SSM		FIBRE LINK - SES TO SSSR INTERCONNECT
		1-4	103	COMM	EMPTY	2x12 9/125um SSM		FIBRE - F/A AND G/A SYSTEMS
		2-1	103	COMM	EMPTY	100PR#24 GEL FILLED		TELEPHONE CABLE - SES TO SSSR INTERCONNECT
		2-2	103	COMM	EMPTY	EMPTY		FUTURE
		2-3	103	COMM	EMPTY	EMPTY		FUTURE
		2-4	103	COMM	EMPTY	1x12 9/125um SSM		FIBRE - CCTV SYSTEM
		3-1	103	COMM	EMPTY	EMPTY		FUTURE FIRE & EMERGENCY ALARM
		3-2	103	COMM	EMPTY	EMPTY		FUTURE
		3-3	103	COMM	EMPTY	EMPTY		FUTURE
		3-4	103	COMM	EMPTY	EMPTY		FUTURE - FIBRE ONLY



Revision/Revisions	Description/Description	Date/Date
5	ISSUED FOR TENDER	15/01/28
4	ISSUED FOR 99% DESIGN REVIEW	16/01/06
3	ISSUED FOR 66% DESIGN REVIEW	15/11/25
2	ISSUED FOR 33% DESIGN REVIEW	15/10/28
1	ISSUED FOR DESIGN DEVELOPMENT	15/09/11
0		

Client/client

ESQUIMALT  
GRAVING DOCK

825 ADMIRALS ROAD  
VICTORIA, BC, V9A 2P1

Project title/Titre du projet  
**825 ADMIRALS ROAD VICTORIA BC  
ESQUIMALT GRAVING DOCK  
ELECTRICAL SAFETY UPGRADE**

**SOUTH SUBSTATION  
SWITCHGEAR  
REPLACEMENT  
(SSSR)**

Consultant Signature Box Only

Designed by/Concept par  
**I. BARNES**

Drawn by/Dessiné par  
**J. BIELING / S. SEYMOUR**

PWCSG Project Manager/Administrateur de Projets TPSGC  
**Jamie LeBlanc**





PWCSG Regional Manager, Architectural and Engineering Services/  
Gestionnaire régionale, Services d'architecture et de génie, TPSGC  
**Prestipal Paul**

Drawing title/Titre du dessin

**NEW DUCT BANK  
CROSS SECTION DETAILS 1 OF 4**

Project No./No. du projet	Sheet/Feuille	Revision no./ La Révision no.
<b>R.062548.2</b>	<b>5415</b>	<b>5</b>





2 HV, LV AND COMM. MANHOLE PENETRATION ELEVATION  
SCALE 1:20



3 LV AND COMM. MANHOLE PENETRATION ELEVATION  
SCALE 1:20

- GENERAL NOTES:**
- ALL CONCRETE ENCASED CONDUITS ARE SCHEDULE 40 RIGID PVC CONDUITS.
  - REINFORCE DUCT BANKS WITH 15M BARS RUN CONTINUOUSLY IN ALL 4 CORNERS OF THE DUCT BANK.
  - INSTALL ONE CONTINUOUS 40 INSULATED COPPER GROUND CONDUCTORS IN THE BOTTOM OF EVERY DUCT BANK. TIE IN GROUNDS AT EVERY MANHOLE AND DISTRIBUTION CENTER TO PROVIDE ELECTRICAL CONTINUITY SITE WIDE.
  - PROVIDE ADDITIONAL GROUNDS WHERE DUCT BANKS FAN OUT INTO SEPARATE MANHOLES.
  - BOND ALL METAL RACKING LOCATIONS IN EVERY MANHOLE.
  - USE UNDERGROUND DUCT SPACERS WITH 190mmx190mm DUCT CENTER TO CENTER MEASUREMENT EXCEPT WHERE NOTED.
  - ALL CONDUITS MUST BE ENCASED IN A MINIMUM OF 50mm OF CONCRETE.
  - MAINTAIN 300mm SEPARATION BETWEEN COMMUNICATIONS CONDUITS AND POWER CONDUITS. FIBRE OPTIC CONDUITS MAY BE INSTALLED WITHIN THE 300mm SEPARATION.
  - ALL DUCTBANKS SHALL BE INSTALLED IN ACCORDANCE WITH CANADIAN ELECTRICAL CODE.
  - REFER TO SITE PLANS FOR SPACING BETWEEN DUCTBANKS.

1 HV, LV AND COMM. MANHOLE PLAN VIEW  
SCALE 1:20

- KEY NOTES:**
- INTERCEPT EXISTING CONDUIT STUBS AND EXTEND INTO NEW SSSR BUILDING. MANHOLE AND CONDUIT STUB ARE EXISTING FROM PREVIOUS SOUTH SIDE SUBSTATION DUCT BANK EXTENSION PROJECT. NO NEW MANHOLE ARE REQUIRED.

CONDUIT AND CABLE SCHEDULE							
CUT SECTION	CONDUIT ROUTE	CONDUIT ID	SIZE (mm)	TYPE	SYSTEM NOMINAL VOLTAGE	CONDUCTORS	COMMENTS
EXISTING SERVICES - 144LV	3/5416	1-1	27	LV	120/208V	3c#10	TUG WHARF CABLES (EXISTING)
		1-2	27	LV	120/208V	3c#10	TUG WHARF CABLES (EXISTING)
		1-3	27	LV	120/208V	3c#12	TUG WHARF CABLES (EXISTING)
		1-4	27	LV	120/208V	3c#12	TUG WHARF CABLES (EXISTING)
		1-5	27	LV	120/208V	3c#12	TUG WHARF CABLES (EXISTING)
		2-1	27	LV	120/208V	3c#12	TUG WHARF CABLES (EXISTING)
		2-2	27	LV	120/208V	3c#12	TUG WHARF CABLES (EXISTING)
		2-3	27	LV	120/208V	2c#12	TUG WHARF CABLES (EXISTING)
		2-4	53	LV	120/208V	3c#2	120/208V OUTDOOR PANEL (EXISTING)
		2-5	53	LV	480V	EMPTY	KCB CONDUIT #77 (FUTURE)
		3-1	27	LV	120/208V	EMPTY	JM#5 120V (FUTURE)
		3-2	53	LV	120/208V	EMPTY	JM#5 120V (FUTURE)
		3-3	53	LV	120/208V	EMPTY	KCB CONDUIT #70 (FUTURE)
		3-4	53	LV	120/208V	EMPTY	KCB CONDUIT #71 (FUTURE)
		3-5	53	LV	120/208V	EMPTY	KCB CONDUIT #72 (FUTURE)
		4-1	27	LV	120/208V	EMPTY	JM#5 120V (FUTURE)
		4-2	53	LV	480V	EMPTY	KCB CONDUIT #123 (FUTURE)
		4-3	53	LV	480V	EMPTY	KCB CONDUIT #126 (FUTURE)
		4-4	129	LV	480V	EMPTY	JM#3 480V (FUTURE)
		4-5	129	LV	480V	EMPTY	JM#3 480V (FUTURE)
		5-1	27	LV	120/208V	EMPTY	JM#5 120V (FUTURE)
		5-2	129	LV	480V	EMPTY	JM#4 480V (FUTURE)
		5-3	129	LV	480V	EMPTY	JM#4 480V (FUTURE)
		5-4	129	LV	120/208V	EMPTY	JM#3 120/208V (FUTURE)
		5-5	129	LV	120/208V	EMPTY	JM#3 120/208V (FUTURE)
		6-1	27	LV	120/208V	2c#12	NAV. LIGHTS (EXISTING)
		6-2	129	LV	480V	EMPTY	JM#5 480V (FUTURE)
		6-3	129	LV	480V	EMPTY	JM#5 480V (FUTURE)
		6-4	129	LV	120/208V	EMPTY	JM#4 120/208V (FUTURE)
		6-5	129	LV	120/208V	EMPTY	JM#5 120/208V (FUTURE)
		1-1	27	COMM	N/A	2c#12	TUG WHARF F/A HORN (EXISTING)
		1-2	27	COMM	N/A	2c#12	TUG WHARF F/A HORN (EXISTING)
		1-3	27	COMM	N/A	2c#14	TUG WHARF F/A (EXISTING)
		1-4	27	COMM	N/A	N/A	JETTY MOUNTS F/A (FUTURE)
		1-5	27	COMM	N/A	EMPTY	JM#5 TEL (FUTURE)
2-1	27	COMM	N/A	EMPTY	JM#5 SCADA (FUTURE)		
2-2	27	COMM	N/A	EMPTY	JETTY TEL (FUTURE)		
2-3	27	COMM	N/A	EMPTY	JETTY TEL (FUTURE)		
2-4	27	COMM	N/A	EMPTY	JETTY TEL (FUTURE)		
2-5	27	COMM	N/A	EMPTY	JETTY TEL (FUTURE)		
3-1	27	COMM	N/A	EMPTY	JETTY CCTV (FUTURE)		
3-2	27	COMM	N/A	EMPTY	JETTY CCTV (FUTURE)		
3-3	27	COMM	N/A	EMPTY	JETTY F/A HORN (FUTURE)		
3-4	27	COMM	N/A	EMPTY	JETTY F/A HORN (FUTURE)		
3-5	27	COMM	N/A	EMPTY	JETTY F/A (FUTURE)		



SSSR DUCT SECTION DETAILS  
SCALE 1:20

CONDUIT AND CABLE SCHEDULE							
CUT SECTION	CONDUIT ROUTE	CONDUIT ID	SIZE (mm)	TYPE	SYSTEM NOMINAL VOLTAGE	CONDUCTORS	COMMENTS
143HV - SSSR HV SECTION	HV SECTION	1-1	129	HV	12.5/25/12.5KV	EMPTY	FUTURE
		1-2	129	HV	12.5/25/12.5KV	3x1C#250KCM	FEEDER TO SSSR FROM SES
		2-1	129	HV	12.5/25/12.5KV	EMPTY	FUTURE
		2-2	129	HV	12.5/25/12.5KV	EMPTY	FUTURE
		1-1	103	LV	480V	4c#350KCM RW90	B-1 FEEDER
		1-2	103	LV	480V	4c#350KCM RW90	B-1 FEEDER
		1-3	103	LV	600V	EMPTY	FUTURE DOCK RECEPTACLES #1, FUTURE DOCK RECEPTACLES #2
		1-4	103	LV	600V	4c#6, 3x#2 TECK, 2x(3c#10 TECK)	HIGH MAST LIGHTING #2, LIFT STATION #11 POWER, SUMP #1 PANEL, SUMP #2 PANEL
		2-1	103	LV	480V	4c#350KCM RW90	B-1 FEEDER
		2-2	103	LV	480V	4c#350KCM RW90	B-1 FEEDER
		2-3	103	LV	600V	EMPTY	FUTURE DOCK RECEPTACLES #3, FUTURE DOCK RECEPTACLES #4
		2-4	103	LV	600V	EMPTY	FUTURE TUG WHARF POWER
		3-1	103	LV	600V	EMPTY	FUTURE
		3-2	103	LV	600V	EMPTY	FUTURE
		3-3	103	LV	600V	EMPTY	FUTURE
3-4	103	LV	600V	EMPTY	FUTURE		
4-1	103	LV	600V	EMPTY	FUTURE		
4-2	103	LV	120/208V	EMPTY	JM#5 120V (FUTURE)		
4-3	103	LV	120/208V	2x3c#10, 3x3c#12	TUG WHARF CABLES (EXISTING)		
4-4	103	LV	600V	EMPTY	FUTURE		
5-1	103	LV	600V	EMPTY	FUTURE		
5-2	103	LV	120/208V	3c#2, 2c#12	120/208V OUTDOOR PANEL, NAV. LIGHTS (EXISTING)		
5-3	103	LV	120/208V	2x3c#12, 2c#12	TUG WHARF CABLES (EXISTING)		
5-4	103	LV	600V	EMPTY	FUTURE		
6-1	103	LV	120/208V	EMPTY	KCB CONDUIT #70,71,72 (FUTURE)		
6-2	103	LV	480V	EMPTY	KCB CONDUIT #77, 123, 126 (FUTURE)		
6-3	129	LV	480V	EMPTY	JM#4 480V (FUTURE)		
6-4	129	LV	480V	EMPTY	JM#4 480V (FUTURE)		
7-1	129	LV	480V	EMPTY	JM#3 480V (FUTURE)		
7-2	129	LV	480V	EMPTY	JM#3 480V (FUTURE)		
7-3	129	LV	480V	EMPTY	JM#4 120/208V (FUTURE)		
7-4	129	LV	480V	EMPTY	JM#5 120/208V (FUTURE)		
8-1	129	LV	480V	EMPTY	JM#3 120/208V (FUTURE)		
8-2	129	LV	480V	EMPTY	JM#3 120/208V (FUTURE)		
8-3	129	LV	480V	EMPTY	JM#5 480V (FUTURE)		
8-4	129	LV	480V	EMPTY	JM#5 480V (FUTURE)		
1-1	103	COMM	N/A	2xCoax	SHAW CABLE		
1-2	103	COMM	N/A	4c#12TECK, 8c#12 TECK	LIFT STATION #11 SCADA ALARM, SUMP #1 & SUMP #2 WATER SCADA ALARM		
1-3	103	COMM	N/A	1x48 50/125um SSM, 2x48 9/125um SSM	FIBRE LINK - SES TO SSSR INTERCONNECT		
2-1	103	COMM	N/A	100PR#24 GEL FILLED	TELEPHONE CABLE - SES TO SSSR INTERCONNECT		
2-2	103	COMM	N/A	EMPTY	JM#5 TEL & JETTY TEL (FUTURE)		
2-3	103	COMM	N/A	2x12 9/125um SSM	FIBRE - F/A AND G/A SYSTEMS		
3-1	103	COMM	N/A	4x2c#12, 6x2c#12	TUG WHARF & JETTY F/A HORN (EXISTING)		
3-2	103	COMM	N/A	EMPTY	TUG WHARF & JETTY F/A (EXISTING+FUTURE)		
3-3	103	COMM	N/A	1x12 9/125um SSM	JM#5 SCADA (FUTURE)		
4-1	103	COMM	N/A	TBD	FIBRE - CCTV SYSTEM		
4-2	103	COMM	N/A	TBD	TBD		
4-3	103	COMM	N/A	EMPTY	FUTURE - FIBRE ONLY		
5-1	103	COMM	N/A	EMPTY	JETTY CCTV (FUTURE)		
5-2	103	COMM	N/A	EMPTY	FUTURE		
6-1	103	COMM	N/A	EMPTY	FUTURE		
6-2	103	COMM	N/A	EMPTY	FUTURE		



Revision/Revisions	Description/Description	Date/Date
5	ISSUED FOR TENDER	15/01/28
4	ISSUED FOR 99% DESIGN REVIEW	16/01/06
3	ISSUED FOR 66% DESIGN REVIEW	15/11/25
2	ISSUED FOR 33% DESIGN REVIEW	15/10/28
1	ISSUED FOR DESIGN DEVELOPMENT	15/09/11
0		

**ESQUIMALT GRAVING DOCK**

825 ADMIRALS ROAD  
VICTORIA, BC, V9A 2P1

Project Title/Titre du projet  
**825 ADMIRALS ROAD VICTORIA BC  
ESQUIMALT GRAVING DOCK  
ELECTRICAL SAFETY UPGRADE**

**SOUTH SUBSTATION  
SWITCHGEAR  
REPLACEMENT  
(SSSR)**

Consultant Signature Box Only

Designed by/Concept par  
**I. BARNES**


Drawing by/Dessiné par  
**J. BIELING / S. SEYMOUR**

PWSSC Project Manager/Administrateur de Projets TPSGC  
**Jamie LeBlanc**

PWSSC Regional Manager, Architectural and Engineering Services/  
Gestionnaire régionale, Services d'architecture et de génie, TPSGC  
**Preotipal Paul**


Drawing Title/Titre du dessin

**NEW DUCT BANK  
CROSS SECTION DETAILS  
2 OF 4**



GENERAL NOTES:

- ALL CONCRETE ENCASED CONDUITS ARE SCHEDULE 40 RIGID PVC CONDUITS.
- REINFORCE DUCT BANKS WITH 15M BARS RUN CONTINUOUSLY IN ALL 4 CORNERS OF THE DUCT BANK.
- INSTALL ONE CONTINUOUS 4/0 INSULATED COPPER GROUND CONDUCTORS IN THE BOTTOM OF EVERY DUCT BANK. TIE IN GROUNDS AT EVERY MANHOLE AND DISTRIBUTION CENTER TO PROVIDE ELECTRICAL CONTINUITY SITE WIDE.
- PROVIDE ADDITIONAL GROUNDS WHERE DUCT BANKS FAN OUT INTO SEPARATE MANHOLES.
- BOND ALL METAL RACKING LOCATIONS IN EVERY MANHOLE.
- USE UNDERGROUND DUCT SPACERS WITH 190mmx190mm DUCT CENTER TO CENTER MEASUREMENT EXCEPT WHERE NOTED.
- ALL CONDUITS MUST BE ENCASED IN A MINIMUM OF 50mm OF CONCRETE.
- MAINTAIN 300mm SEPARATION BETWEEN COMMUNICATIONS CONDUITS AND POWER CONDUITS. FIBRE OPTIC CONDUITS MAY BE INSTALLED WITHIN THE 300mm SEPARATION.
- ALL DUCTBANKS SHALL BE INSTALLED IN ACCORDANCE WITH CANADIAN ELECTRICAL CODE.
- REFER TO SITE PLANS FOR SPACING BETWEEN DUCTBANKS.



STA 5417 DUCT SECTION DETAILS SCALE 1:10

CONDUIT AND CABLE SCHEDULE								
CUT SECTION	CONDUIT ROUTE	CONDUIT ID	SIZE (mm)	TYPE	SYSTEM NOMINAL VOLTAGE	NEW CONDUCTORS	EXISTING CONDUCTORS	COMMENTS
STA	SSSR-SERVICE TUNNEL LV	1-1	129	LV	208V	REUSE EXISTING	4c#350kCM TECK	JM1 - 120/208V CIRCUIT
		1-2	129	LV	208V	REUSE EXISTING	4c#350kCM TECK	JM1 - 120/208V CIRCUIT
		1-3	103	LV	208V	3c#2/0 TECK	3c#1 MI CABLE	EXISTING DOCK SERVICES #1 CENTER
		1-4	103	LV	208V	3c#8 TECK	3c#10 MI CABLE	SOUTH WEST DOCK STAIR ROPELIGHT
		1-5	103	LV	120/208V	4c#350kCM	NEW SERVICE	120/208V, 400A DS2-W
		1-6	103	LV	480V	3c#4/0 TECK	3c#250kCM MI CABLE	EXISTING DOCK SERVICES #1 SOUTH WEST 1 OF 2
		1-7	103	LV	480V	3c#4/0 TECK	3c#250kCM MI CABLE	EXISTING DOCK SERVICES #1 CENTER 1 OF 2
		1-8	103	LV	480V	3c#4/0 TECK	3c#250kCM MI CABLE	EXISTING DOCK SERVICES #1 SOUTH EAST 1 OF 2
		1-9	103	LV	480V	3c#3/0	NEW SERVICE	480V, 400A DS2-W
		1-10	103	LV	480V	3c#3/0	NEW SERVICE	480V, 400A DS2-C
		1-11	103	LV	480V	3c#3/0	NEW SERVICE	480V, 400A DS2-C
		2-1	129	LV	208V	REUSE EXISTING	4c#350kCM TECK	JM2 - 120/208V CIRCUIT
		2-2	129	LV	208V	REUSE EXISTING	4c#350kCM TECK	JM2 - 120/208V CIRCUIT
		2-3	103	LV	208V	3c#2/0 TECK	3c#1 MI CABLE	EXISTING DOCK SERVICES #1 SOUTH EAST
		2-4	103	LV	208V	3c#3/0 TECK	3c#1/0 MI CABLE	EXISTING DOCK SERVICES #1 SOUTH WEST
		2-5	103	LV	120/208V	4c#350kCM	NEW SERVICE	120/208V, 400A DS2-C
		2-6	103	LV	480V	3c#4/0 TECK	3c#250kCM MI CABLE	EXISTING DOCK SERVICES #1 SOUTH WEST 2 OF 2
		2-7	103	LV	480V	3c#4/0 TECK	3c#250kCM MI CABLE	EXISTING DOCK SERVICES #1 CENTER 2 OF 2
		2-8	103	LV	480V	3c#4/0 TECK	3c#250kCM MI CABLE	EXISTING DOCK SERVICES #1 SOUTH EAST 2 OF 2
		2-9	129	LV	480V	3c#3/0	NEW SERVICE	480V, 400A DS2-W
		2-10	103	LV	480V	3c#3/0	NEW SERVICE	480V, 400A DS2-W
		2-11	129	LV	480V	3c#3/0	NEW SERVICE	480V, 400A DS2-C
		3-1	129	LV	430-630V	3c#500kCM TECK	NEW SERVICE	2000A REGULATED DOCK SERVICE, DS2-C
		3-2	129	LV	430-630V	3c#500kCM TECK	NEW SERVICE	2000A REGULATED DOCK SERVICE, DS2-C
		3-3	129	LV	430-630V	3c#500kCM TECK	NEW SERVICE	2000A REGULATED DOCK SERVICE, DS2-C
		3-4	129	LV	430-630V	3c#500kCM TECK	NEW SERVICE	2000A REGULATED DOCK SERVICE, DS2-C
		3-5	129	LV	408V	REUSE EXISTING	3c#350kCM TECK	JM1 - 480V CIRCUIT
		3-6	129	LV	408V	REUSE EXISTING	3c#350kCM TECK	JM1 - 480V CIRCUIT
		3-7	103	LV	600V	REUSE EXISTING	3c#2/0 TECK	600V CAISSON CONNECTION
		3-8	103	LV	600V	3c#4/0	NEW SERVICE	600V, 400A DS2-W
		3-9	103	LV	600V	3c#4/0	NEW SERVICE	600V, 400A DS2-W
		3-10	103	LV	600V	FUTURE	NEW SERVICE	FUTURE HIGH MAST #1
		3-11	103	LV	N/A	FUTURE	NEW SERVICE	SPARE
		4-1	129	LV	430-630V	3c#500kCM TECK	NEW SERVICE	2000A REGULATED DOCK SERVICE, DS2-C
		4-2	129	LV	430-630V	3c#500kCM TECK	NEW SERVICE	2000A REGULATED DOCK SERVICE, DS2-C
		4-3	129	LV	430-630V	3c#500kCM TECK	NEW SERVICE	2000A REGULATED DOCK SERVICE, DS2-C
		4-4	129	LV	430-630V	3c#500kCM TECK	NEW SERVICE	2000A REGULATED DOCK SERVICE, DS2-C
		4-5	129	LV	408V	REUSE EXISTING	3c#350kCM TECK	JM2 - 480V CIRCUIT
		4-6	129	LV	408V	REUSE EXISTING	3c#350kCM TECK	JM2 - 480V CIRCUIT
		4-7	103	LV	N/A	FUTURE	NEW SERVICE	SPARE
		4-8	103	LV	N/A	FUTURE	NEW SERVICE	SPARE
4-9	103	LV	N/A	FUTURE	NEW SERVICE	SPARE		
4-10	103	LV	N/A	FUTURE	NEW SERVICE	SPARE		
4-11	103	LV	N/A	FUTURE	NEW SERVICE	SPARE		
1-1	103	COMM	N/A	4xCAT5e	NEW SERVICE	DS2-W DATA SERVICES		
1-2	103	COMM	N/A	16PR#22	NEW SERVICE	DS2-W COMM SERVICES		
1-3	103	COMM	N/A	FUTURE	NEW SERVICE	DS2-W FIBRE SERVICES		
2-1	103	COMM	N/A	4xCAT5e	NEW SERVICE	DS2-C DATA SERVICES		
2-2	103	COMM	N/A	16PR#22	NEW SERVICE	DS2-C COMM SERVICES		
2-3	103	COMM	N/A	FUTURE	NEW SERVICE	DS2-C FIBRE SERVICES		
3-1	27	COMM	N/A	2x2c#12	NEW SERVICE	DS2-W F/A SERVICES		
3-2	27	COMM	N/A	2x2c#12	NEW SERVICE	DS2-W EMERGENCY SERVICES		
3-3	103	COMM	N/A	SPARE	NEW SERVICE	FUTURE (FIBRE ONLY)		
4-1	27	COMM	N/A	2x2c#12	NEW SERVICE	DS2-C F/A SERVICES		
4-2	27	COMM	N/A	2x2c#12	NEW SERVICE	DS2-C EMERGENCY SERVICES		
4-3	103	COMM	N/A	SPARE	NEW SERVICE	FUTURE (FIBRE ONLY)		

Revision/Revisions	Description/Description	Date/Date
5	ISSUED FOR TENDER	15/01/28
4	ISSUED FOR 99% DESIGN REVIEW	16/01/06
3	ISSUED FOR 66% DESIGN REVIEW	15/11/25
2	ISSUED FOR 33% DESIGN REVIEW	15/10/28
1	ISSUED FOR DESIGN DEVELOPMENT	15/09/11
0		

Client/client

ESQUIMALT GRAVING DOCK

825 ADMIRALS ROAD VICTORIA, BC, V9A 2P1

Project title/Titre du projet  
825 ADMIRALS ROAD VICTORIA BC  
ESQUIMALT GRAVING DOCK  
ELECTRICAL SAFETY UPGRADE

SOUTH SUBSTATION SWITCHGEAR REPLACEMENT (SSSR)

Consultant Signature Box Only

Designed by/Concept par

I. BARNES

Drawn by/Dessiné par

J. BIELING / S. SEYMOUR

PW/CSC Project Manager/Administrateur de Projets TPSGC

Jamie LeBlanc

PW/CSC Regional Manager, Architectural and Engineering Services/ Gestionnaire régionale, Services d'architecture et de génie, TPSGC

Preetipal Paul

Drawing title/Titre du dessin

NEW DUCT BANK CROSS SECTION DETAILS 3 OF 4

Project No./No. du projet

R.062548.2



Sheet/Feuille

5417


Revision no./La Révision no.

5





STB DUCT SECTION DETAILS  
5418 SCALE 1:25




STC EXISTING DUCT SECTION DETAILS  
5418 SCALE 1:25

CONDUIT AND CABLE SCHEDULE							
CUT SECTION	CONDUIT ROUTE	CONDUIT ID	SIZE (mm)	TYPE	SYSTEM NOMINAL VOLTAGE	CONDUCTORS	COMMENTS
STB	EXISTING DUCT BANK LV - SSSR SERVICE PIT	1-1	103	LV	480V	3c#500(KCM) TECK + 1#2 GR	480V, KIOSK #1
		1-2	103	LV	600V	EMPTY	SPARE
		1-3	53	LV	208V	3c#1 TECK + 1#8 GR	120/208V, KIOSK #1
		1-4	53	LV	600V	EMPTY	SPARE
		2-1	103	LV	480V	2x(3c#250(KCM) TECK + 1#2 GR	480V, KIOSK #2
		2-2	103	LV	600V	EMPTY	SPARE
		2-3	53	LV	208V	3c#1 TECK + 1#8 GR	120/208V, KIOSK #2
		2-4	53	LV	600V	EMPTY	SPARE
		3-1	103	LV	480V	2x(3c#250(KCM) TECK + 2#12 GR	480V, VSY MACHINE SHIP
		3-2	103	LV	600V	EMPTY	SPARE
		3-3	53	LV	120/208V	6c#10 + 1#10 GND	CATHODIC PROTECTION
		3-4	53	LV	600V	EMPTY	SPARE
		1-5	53	LV	120/208V	7c#12	UNKNOW SERVICE
		1-6	103	LV	480V	2x(3c#250(KCM) TECK + 1#2 GR	480V, KIOSK #3
		2-5	53	LV	208V	3c#1 TECK + 1#8 GR	120/208V, KIOSK #3
		2-6	103	LV	600V	EMPTY	SPARE
	EXISTING DUCT BANK COMM - SSSR SERVICE PIT	1-1	53	COMM	N/A	EMPTY	SPARE
		1-2	53	COMM	N/A	9c#12	VICTORIA SHIPYARDS FIRE ALARM SYSTEM
		2-1	103	COMM	N/A	50PR#22	TELECOMM
		2-2	103	COMM	N/A	12PR#22M 1 FIBRE, 1 F/A	TELECOMM

CONDUIT AND CABLE SCHEDULE							
CUT SECTION	CONDUIT ROUTE	CONDUIT ID	SIZE (mm)	TYPE	SYSTEM NOMINAL VOLTAGE	CONDUCTORS	COMMENTS
STB	EXISTING DUCT BANK LV - SSSR SERVICE PIT	1-1	103	LV	480V	3c#500(KCM) TECK + 1#2 GR	480V, KIOSK #1
		1-2	103	LV	600V	EMPTY	SPARE
		1-3	53	LV	208V	3c#1 TECK + 1#8 GR	120/208V, KIOSK #1
		1-4	53	LV	600V	EMPTY	SPARE
		2-1	103	LV	480V	2x(3c#250(KCM) TECK + 1#2 GR	480V, KIOSK #2
		2-2	103	LV	600V	EMPTY	SPARE
		2-3	53	LV	208V	3c#1 TECK + 1#8 GR	120/208V, KIOSK #2
		2-4	53	LV	600V	EMPTY	SPARE
		3-1	103	LV	480V	2x(3c#250(KCM) TECK + 2#12 GR	480V, VSY MACHINE SHIP
		3-2	103	LV	600V	EMPTY	SPARE
		3-3	53	LV	120/208V	6c#10 + 1#10 GND	CATHODIC PROTECTION
		3-4	53	LV	600V	EMPTY	SPARE
		1-5	53	LV	120/208V	7c#12	UNKNOW SERVICE
		1-6	103	LV	480V	2x(3c#250(KCM) TECK + 1#2 GR	480V, KIOSK #3
		2-5	53	LV	208V	3c#1 TECK + 1#8 GR	120/208V, KIOSK #3
		2-6	103	LV	600V	EMPTY	SPARE
	EXISTING DUCT BANK COMM - SSSR SERVICE PIT	1-1	53	COMM	N/A	EMPTY	SPARE
		1-2	53	COMM	N/A	9c#12	VICTORIA SHIPYARDS FIRE ALARM SYSTEM
		2-1	103	COMM	N/A	50PR#22	TELECOMM
		2-2	103	COMM	N/A	12PR#22M 1 FIBRE, 1 F/A	TELECOMM

GENERAL NOTES:

- ALL CONCRETE ENCASED CONDUITS ARE SCHEDULE 40 RIGID PVC CONDUITS.
- REINFORCE DUCT BANKS WITH 15M BARS RUN CONTINUOUSLY IN ALL 4 CORNERS OF THE DUCT BANK.
- INSTALL ONE CONTINUOUS 40 INSULATED COPPER GROUND CONDUCTORS IN THE BOTTOM OF EVERY DUCT BANK. TIE IN GROUNDS AT EVERY MANHOLE AND DISTRIBUTION CENTER TO PROVIDE ELECTRICAL CONTINUITY SITE WIDE.
- PROVIDE ADDITIONAL GROUNDS WHERE DUCT BANKS FAN OUT INTO SEPARATE MANHOLES.
- BOND ALL METAL RACKING LOCATIONS IN EVERY MANHOLE.
- USE UNDERGROUND DUCT SPACERS WITH 190mmx190mm DUCT CENTER TO CENTER MEASUREMENT EXCEPT WHERE NOTED.
- ALL CONDUITS MUST BE ENCASED IN A MINIMUM OF 50mm OF CONCRETE.
- MAINTAIN 300mm SEPARATION BETWEEN COMMUNICATIONS CONDUITS AND POWER CONDUITS. FIBRE OPTIC CONDUITS MAY BE INSTALLED WITHIN THE 300mm SEPARATION.
- ALL DUCTBANKS SHALL BE INSTALLED IN ACCORDANCE WITH CANADIAN ELECTRICAL CODE.
- REFER TO SITE PLANS FOR SPACING BETWEEN DUCTBANKS.



1 EXISTING CENTRAL JETTY DUCT BANK TEMPORARY SERVICE SOLUTION  
5418 SCALE 1:20

KEYNOTES:

- INTERCEPT, SPLICE AND EXTEND EXISTING COMMUNICATION, FIRE ALARM AND CCTV CIRCUITS FROM EXISTING COMMUNICATIONS MANHOLE AND EXTEND TO EXISTING SSS BUILDING ALONG ROUTE SHOWN. REFER TO STC5418 FOR EXISTING COMMUNICATIONS CONDUCTORS.
- INTERCEPT, SPLICE AND EXTEND EXISTING POWER CIRCUITS FROM EXISTING LV MANHOLE AND EXTEND TO EXISTING SSS SWITCHBOARDS. RECONNECT TO EXISTING FEEDER BREAKERS. REFER TO STC5418 FOR EXISTING LV CONDUCTORS.
- INTERCEPT, SPLICE AND EXTEND EXISTING POWER CIRCUITS FROM EXISTING LV DUCT BANK AND EXTEND TO EXISTING SSS SWITCHBOARDS. RECONNECT TO EXISTING FEEDER BREAKERS. REFER TO STC5418 FOR EXISTING LV CONDUCTORS.
- CONDUCTORS WILL BE REQUIRED TO CROSS ACTIVE ROAD. ENSURE SUITABLE CROSSING COVERING IS PROVIDED TO PREVENT DAMAGE TO CABLES DURING CONSTRUCTION.
- MOUNT TEMPORARY CONDUCTORS TO EXISTING SOUTH JETTY RETAINING WALL. ENSURE THEY ARE MOUNTED ABOVE MAXIMUM HIGH TIDE LEVELS. ENSURE PASS THROUGHS FROM ABOVE JETTY DECK PLANE TO BELOW JETTY ARE SEALED TO PREVENT LIQUIDS FROM BYPASSING EGD WATER TREATMENT SYSTEMS.
- RUN TEMPORARY CONDUCTORS ALONG EXISTING SOUTH JETTY RETAINING WALL, ENSURING ADEQUATE SUPPORT SPACING.
- SHADED AREA INDICATES EXTENT OF EXISTING STEEL PILING. THIS ZONE BUTTS UP TO RETAINING WALL AND IS OPEN TO THE OCEAN BELOW. ALLOWING ACCESS TO RETAINING WALL FOR CONDUCTOR MOUNTINGS. THIS IS A CONFINED SPACE AND WILL REQUIRE CO-ORDINATION WITH TIDAL LEVELS TO ACCESS WORK AREAS.
- REUSE EXISTING JETTY MOUNT SERVICE DUCT BANK. PULL NEW TEMPORARY CONDUCTORS IN DUCT BANK TO EXISTING SSS BUILDING.
- EXISTING JETTY MOUNT SERVICE DUCT BANK ROUTE.
- ENTRE SSS BUILDING USING EXISTING WALL MOUNTED CABLE TRAY AND WALL PENETRATIONS AND SEAL EDGES OF PENETRATIONS WITH WATERPROOF POLYURETHANE CAULKING.
- RUN CONDUCTORS TO REQUIRED TERMINATION POINTS USING EXISTING OVERHEAD CABLE TRAY.
- TERMINATE COMMUNICATIONS CONDUCTORS IN SSS COMMUNICATION PANELS. TEST AND CONFIRM SYSTEM OPERATION.
- TERMINAL LV CONDUCTORS IN SSS LV SWITCHBOARD. TEST AND CONFIRM SYSTEM OPERATION.

Revision/	Description/Description	Date/Date
5	ISSUED FOR TENDER	15/01/28
4	ISSUED FOR 99% DESIGN REVIEW	16/01/06
3	ISSUED FOR 66% DESIGN REVIEW	15/11/25
2	ISSUED FOR 33% DESIGN REVIEW	15/10/28
1	ISSUED FOR DESIGN DEVELOPMENT	15/09/11
0		

Client/client  
**ESQUIMALT GRAVING DOCK**  
825 ADMIRALS ROAD  
VICTORIA, BC, V9A 2P1

Project title/Titre du projet  
**825 ADMIRALS ROAD - VICTORIA BC  
ESQUIMALT GRAVING DOCK  
ELECTRICAL SAFETY UPGRADE**

**SOUTH SUBSTATION  
SWITCHGEAR  
REPLACEMENT  
(SSSR)**

Consultant Signature Box Only  
Designed by/Concept par  
**I. BARNES**  
Drawn by/Dessiné par  
**J. BIELING / S. SEYMOUR**  
PWGSC Project Manager/Administrateur de Projets TPSGC  
**Jamie LeBlanc**  
PWGSC, Regional Manager, Architectural and Engineering Services/  
Gestionnaire régionale, Services d'architectural et de génie, TPSGC  
**Preetpal Paul**

Drawing title/Titre du dessin  
**NEW DUCT BANK  
CROSS SECTION DETAILS  
4 OF 4  
AND TEMPORARY SERVICE**

Project No./No. du projet	Sheet/Fauille	Revision no./ La Révision no.
R.062548.2	5418	5