
Robertson Martin Architects

216 Pretoria Avenue
Ottawa, ON K1S 1X2
Phone:613.567.1361
<http://www.robertsonmartin.com>

ADDENDUM NO. A02

Project: **CFIA Fallowfield Lab Retrofit
3851 Fallowfield Road,
Ottawa, ON
K2H 8P9**

Project No.: **H0541 (RMA)15181**

Date: **02/11/2016**

ADDENDUM

The following information supplements and/or supersedes the bid documents dated 2015/11/24

This Addendum forms part of the contract documents and is to be read, interpreted, and co-ordinated with all other parts. The cost of all contained herein is to be included in the contract sum. The following revisions supersede the information contained in the original drawings and specifications issued for the above-named project to the extent referenced and shall become part thereof. Acknowledge receipt of this Addendum by inserting its number and date on the Tender Form. Failure to do so may subject the Bidder to disqualification.

CLARIFICATIONS

1. GENERAL

1.1. **Question:**

"Could you please clarify if replacement of the metal covers on perimeter heating units will be part of General Contractor or Mechanical Contractor scope of work? This item mentioned on both Architectural and Mechanical drawings."

Response:

General Contractor is to determine who they wish to engage for provision of replacement perimeter heating unit covers.

1.2. **Question:**

"You included section 08 41 13 in your specification but on the door schedule aluminium is not mentioned, please clarify?"

Response:

Door schedule indicates the finish for the replacement entrance door systems is to be pre-finished.

Refer to 2.7 Aluminum Finishes / Specifications Section 084113 – Aluminum-Framed Entrances and Storefronts.

2. SPECIFICATIONS

2.1. **DELETE** from specifications Section 09 51 99:

2.2 Components / .1 Standard Suspended Acoustical Ceiling System / .14 Basis of Design: *Cirrus High-NRC, **556** by Armstrong World Industries.*

2.2. **ADD** to specifications Section 09 51 99:

2.2 Components / .1 Standard Suspended Acoustical Ceiling System / .14 Basis of Design: *Cirrus High-NRC, **565** by Armstrong World Industries (24" x 48").*

Clarification:

CGC Eclipse High-NRC Panels SLT 76523 (24" X 48") has been reviewed as an acceptable alternate product.

Alternate products may be accepted if the Contractor can demonstrate compliance with specifications.

1. Attachments

1.1. *n/a*

END of Addendum No. A02