



RETURN BIDS TO:
RETOURNER LES SOUMISSIONS À:
Public Works Government Services Canada- Bid
Receiving / Réception des soumissions
189 Prince William Street
Room 405
Saint John
New Brunswick
E2L 2B9

SOLICITATION AMENDMENT
MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution
Public Works Government Services Canada- Bid
Receiving / Réception des soumissions
189 Prince William Street
Room 405
Saint John
New Bruns
E2L 2B9

Title - Sujet Fuel Tank Replacement-Springhill,NS	
Solicitation No. - N° de l'invitation EC016-162189/A	Amendment No. - N° modif. 005
Client Reference No. - N° de référence du client R.061879.001	Date 2016-02-23
GETS Reference No. - N° de référence de SEAG PW-\$PWB-020-3801	
File No. - N° de dossier PWB-5-38196 (020)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2016-03-01	
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Donovan, Janine PWB	Buyer Id - Id de l'acheteur pwb020
Telephone No. - N° de téléphone (506) 636-5347 ()	FAX No. - N° de FAX (506) 636-4376
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction:	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

This Solicitation Amendment No. Five (5) is raised to include the following addendum no. 5.

The following addendum to the tender documents is effective immediately. This addendum shall form part of the contract documents.

All other terms and conditions remain the same.

Addendum 5.

1. **QUESTIONS AND ANSWERS**

- Q1: The specification indicates that the successful contractor will have to pay for costs for relocating underground services that are in the way of new infrastructure. See section 31 14 11 Part 1.1.4.2. Unless PWGS can quantify this and inform us exactly what services have to be moved, this would be impossible to include. If encountered, these situations are always dealt with on a Time and Material basis.
- A1: Items found on-site during construction that are not indicated on drawings and specifications will be time and materials.
- Q2: The drawings indicate an Impermeable Poly layer underneath the concrete slab. This is not industry standard and there is no specification on this indicated. Can you please advise as to what type of material this is?
- A2: This layer consists of a 6 mil poly.
- Q3: There is a requirement for a temporary Furnace Oil Tank, however, no indication for a temporary Diesel Tank for the Generator. Will this be required?
- A3: The temporary fuel tank only serves the heating plant. The generators have day tanks, which will supply diesel.
- Q4: During the site meeting there was a discussion on contaminated soils. There is no mention on the drawings or specification on areas to be excavated or quantities. Will this be time and material?
- A4: Contaminated soils are to be removed, and will be time and material.
- Q5: The drawings indicate Monitoring Wells to be decommissioned. Only MW2 and MW3 are visible on the drawings. Are there more to be decommissioned?
- A5: All monitoring wells (5) to be removed are indicated on drawing C-101. They are listed in the coordinate table below the legend. The 5 monitoring wells are TH-1, th-2, th-4, bh-2 and bh-3. They are also shown on the site plan, and are all to be decommissioned.
- Q6: Please confirm if permits are by Owner or by the General Contractors.
- A6: The General Contractor is required to obtain and maintain all permits.

2. **SPECIFICATIONS**

.1 **Section 26 05 23 – Splitters, Junction, Pull Boxes and Cabinets**

Part 2.2: Standard of acceptance is Crouse-Hinds WJBF series for Steel, Pencil for HDPE.

Solicitation No. - N° de l'invitation

Amd. No. - N° de la modif.

Buyer ID - Id de l'acheteur

EC016-162189/A

005

pwb020

Client Ref. No. - N° de réf. du client

File No. - N° du dossier

CCC No./N° CCC - FMS No./N° VME

R.061879.001

PWB-5-38196

.2 Section 33 56 13 – Aboveground Fuel Tanks

Part 2.1: Products manufactured by Industries Desjardins meeting the specifications are considered acceptable alternates.

Part 2.2: Products manufactured by Industries Desjardins meeting the specifications are considered acceptable alternates.

Part 2.1.1.2.8 Ktech models FS401-1, VS9253-XP and AL201-1 are considered acceptable alternates.

Part 2.9: Containment Solutions CSI-10 double wall oil/water separator is considered an acceptable alternate to the standard of acceptance.

Part 2.16: Diesel Fuel Filtration System shall be performance based. Delete line item 2.16.7

3. DRAWINGS

.1 Drawing C-102 – Finished Site Plan

REVISE storm collection pipe sizing between Stations 0+000 and 0+073 to 100 mm diameter.

.2 Drawing C-105 – Storm Main Profile

REVISE storm collection pipe sizing between Stations 0+000 and 0+073 to 100 mm diameter.