



POWER FLOOR PLAN - PENTHOUSE LEVEL

KEYNOTES	
①	OVERHEAD DOOR CONTROL DEVICES SUPPLIED AND INSTALLED BY DIVISION 8. WIRE AND CONDUIT PER MANUFACTURER'S REQUIREMENTS BY DIVISION 28.
②	PROVIDE 120V, 15A CIRCUIT FOR SECURITY PANEL. COORDINATE FINAL LOCATION ON SITE.
③	PROVIDE 120V, 15A CIRCUIT FOR BMS. COORDINATE FINAL LOCATION ON SITE WITH DIVISION 25.




DRY STORAGE BUILDING POWER PLAN



KEY PLAN

SCALE - NTS



0	RELEASED FOR CONSTRUCTION	01/29/2016
revisions		date

project
NEW G.O.C.B. SAINT-LÉONARD NEW BRUNSWICK
project

drawing
PENTHOUSE AND DRY STORAGE PLANS ELECTRICAL AND DETAILS
dessin

designed SRP
date JANUARY 29, 2016
drawn CAM
date JANUARY 29, 2016
approved DAG
date FEBRUARY 17, 2016
Tender
PWCSO Project Manager
no. du projet
R.069499.001
no. du dessin

2601-3

drawing no. no. du dessin