

PART 1 - GENERAL

- 1.1 General .1 This Section covers items common to Sections of Division 26. This section supplements requirements of Division 01.
- 1.2 Codes and Standards .1 Do complete installation in accordance with CSA C22.1-15 Canadian Electrical Code, Part 1, Safety Standard for Electrical Installations, Update No. 1, except where specified otherwise.
- .2 Abbreviations for electrical terms: to CSA Z85-1983.
- .3 Comply with CSA Certification Standards and Electrical Bulletins in force at time of Tender submission.
- .4 Where requirements of this specification exceed those of the above mentioned standards, this specification shall govern.
- 1.3 Care, Operation and Start-up .1 Instruct the Departmental Representative and operating personnel in the operation, care and maintenance of equipment.
- .2 Arrange and pay for services of manufacturer's factory service engineer to supervise start-up of installation, check, and adjust.
- .3 Provide these services for such period, and for as many visits as necessary to put equipment in operation, and ensure that operating personnel are conversant with all aspects of its care and operation.
- 1.4 Voltage Ratings .1 Operating voltages: to CAN3-C235-83 (R2015).
- .2 Motors, electric heating, control and distribution devices and equipment to operate satisfactorily at 60

Hz within normal operating limits established by above standard. Equipment to operate in extreme operating conditions established in above standard without damage to equipment.

1.5 Permits, Fees
and Inspection

- .1 Submit to Electrical Inspection Department and Supply Authority necessary number of drawings and specifications for examination and approval prior to commencement of work.
- .2 Pay associated fees.
- .3 The Departmental Representative will provide drawings and specifications required by Electrical Inspection Department and Supply Authority at no cost.
- .4 Notify the Departmental Representative of changes required by Electrical Inspection Department prior to making changes.

1.6 Materials and
Equipment

- .1 Equipment and material to be CSA certified. Where there is no alternative to supplying equipment which is not CSA certified, obtain special approval from Electrical Inspection Department.
- .2 Factory assemble control panels and component assemblies.

1.7 Electric
Motors, Equipment
and Controls

- .1 Related mechanical responsibility is indicated in Division 23.
- .2 Control wiring and conduit is specified in Division 26 except for conduit, wiring and connections below 50 V which are related to control systems specified and shown on mechanical drawings.

1.8 Finishes

- .1 Shop finish metal enclosure surfaces by application of

rust resistant primer inside and outside, and at least two coats of finish enamel.

- .2 Clean and touch up surfaces of shop-painted equipment scratched or marred during shipment or installation, to match original paint.
- .3 Clean and prime exposed non-galvanized hangers, racks and fastenings to prevent rusting.

1.9 Equipment Identification

- .1 Identify electrical equipment with nameplates and labels as follows:
 - .2 Nameplates:
 - .1 Lamicaid 3 mm thick plastic engraving sheet, black face, white core, mechanically attached with self-tapping screws.

NAMEPLATE SIZES

Size 1	10 x 50 mm	1 line	3 mm high letters
Size 2	12 x 70 mm	1 line	5 mm high letters
Size 3	12 x 70 mm	2 lines	3 mm high letters
Size 4	20 x 90 mm	1 line	8 mm high letters
Size 5	20 x 90 mm	2 lines	5 mm high letters
Size 6	25 x 100 mm	1 line	12 mm high letters
Size 7	25 x 100 mm	2 lines	6 mm high letters

- .3 Labels:
 - .1 Embossed plastic labels with 6 mm high letters unless specified otherwise.
- .4 Wording on nameplates and labels to be approved by the Departmental Representative prior to manufacture.
- .5 Allow for average of twenty-five (25) letters per nameplate and label.
- .6 Nameplates for terminal cabinets and junction boxes to indicate system and/or voltage characteristics.
- .7 Disconnects, starters and contactors: indicate equipment being controlled and voltage.

- .8 Transformers indicate capacity, primary and secondary voltages.

1.10 Wiring
Identification

- .1 Identify wiring with permanent indelible identifying markings, either numbered or coloured plastic tapes, on both ends of phase conductors of feeders and branch circuit wiring.
- .2 Maintain phase sequence and colour coding throughout.
- .3 Colour code: to CSA C22.1-09.
- .4 Use colour coded wires in communication cables, matched throughout system.

1.11 Conduit and
Cable
Identification

- .1 Colour code conduits, boxes and metallic sheathed cables.
- .2 Code with plastic tape or paint at points where conduit or cable enters wall, ceiling, or floor, and at 15 m intervals.
- .3 Colours: 25 mm wide prime colour and 20 mm wide auxiliary colour.

	<u>Prime</u>	<u>Auxiliary</u>
up to 250 V	yellow	
up to 600 V	yellow	green
up to 500 V	yellow	blue
Telephone	green	
Other communication Systems	green	blue
Fire alarm	red	
Emergency voice	red	blue
Other security Systems	red	yellow

<u>1.12 Wiring Terminations</u>	.1	Lugs, terminals, screws used for termination of wiring to be suitable for either copper or aluminum conductors.
<u>1.13 Manufacturers and CSA Labels</u>	.1	Visible and legible after equipment is installed.
<u>1.14 Warning Signs</u>	.1	As specified and to meet requirements of Electrical Inspection Department and the Departmental Representative.
<u>1.15 Single Line Electrical Diagrams</u>	.1	Provide updated modified single line electrical diagrams to Departmental Representative.
<u>1.16 Location of Outlets</u>	.1	Locate outlets in accordance with architectural and electrical drawings.
	.2	Do not install outlets back-to-back in wall; allow minimum 150 mm horizontal clearance between boxes.
	.3	Change location of outlets at no extra cost or credit, providing distance does not exceed 6000 mm, and information is given before installation.
<u>1.17 Mounting Heights</u>	.1	Mounting height of equipment is from finished floor to centre line of equipment unless specified or indicated otherwise.
	.2	If mounting height of equipment is not specified or indicated, verify before proceeding with installation.
	.3	Install electrical equipment at following heights unless indicated otherwise. .1 Local switches: 1200 mm. .2 Wall receptacles: .1 General: 400 mm.

- .2 Above top of continuous baseboard heater: 200 mm.
- .3 In mechanical rooms: 1200 mm.
- .3 Panelboards: as required by Code or as indicated.
- .4 Telephone outlets: 400 mm.
- .5 Wall mounted telephone: 1200 mm.
- .6 Doorbell push buttons: 1200 mm.

1.18 Conduit and
Cable Installation

- .1 Install cables, conduits and fittings to be embedded or plastered over, neatly and close to building structure so furring can be kept to minimum.
- .2 Holes for conduits passing through exterior wall and roof shall be properly flashed and made watertight.

1.19 Field Quality
Control

- .1 Conduct and pay for following commissioning tests:
 - .1 Power distribution system including phasing, voltage, grounding and load balancing.
 - .2 Circuits originating from branch distribution panels.
 - .3 Motors, heaters and associated control equipment including sequenced operation of systems where applicable.
- .2 Carry out tests in presence of Departmental Representative.
- .3 Provide instruments, meters, equipment and personnel required to conduct tests during and at conclusion of project.
- .4 Submit test results for Departmental Representative's review.

1.20 Work
Involvements

- .1 Provide modifications to the following systems as shown on drawings and as described in these specifications:
 - .1 120/208 volt distribution system.
 - .2 Wiring and connection of mechanical motors and controls.
 - .3 Telephone raceway system as required for installation of refrigeration system controls.
 - .4 Data raceway system as required for

installation of refrigeration system controls.

1.21 As Built
Record

- .1 Departmental Representative will provide two (2) sets of drawings at the start of construction to allow the contractor to keep and maintain accurate as built drawings. Co-ordinate requirements with Section 01 78 00 - Closeout Submittals.
- .2 One set shall be keep on site to record the information reflecting changes and installation on a daily basis during construction. At the end of the project all information from the construction set shall be transferred onto the clean set and sent to the Departmental Representative for the final review.

PART 2 - PRODUCTS

2.1 Not Used

- .1 Not used.

PART 3 - EXECUTION

3.1 Not Used

- .1 Not used.

END OF SECTION

PART 1 - GENERAL

- 1.1 References .1 CSA C22.2-No.65-2003(R2008) Wire Connectors.

PART 2 - PRODUCTS

- 2.1 Materials .1 Pressure type wire connectors: with current carrying parts of copper sized to fit copper conductors as required.
- .2 Fixture type splicing connectors: with current carrying parts of copper sized to fit copper conductors 10 AWG or less.
- .3 Clamps or connectors for flexible conduit as required.

PART 3 - EXECUTION

- 3.1 Installation .1 Remove insulation carefully from ends of conductors and:
- .1 Install mechanical pressure type connectors and tighten screws with appropriate compression tool recommended by manufacturer. Installation shall meet secureness tests in accordance with CSA C22.2-No.65-2003(R2008)
- .2 Install fixture type connectors and tighten. Replace insulating cap.
- .3 Apply coat of zinc joint compound on aluminum conductors prior to installation of connectors.
- .4 Install box connectors to CSA E222.2 No. 18.

PART 1 - GENERAL

- 1.1 References .1 CSA C22.2-No.0.3-09(R2014), Test Methods for Electrical Wires and Cables.
- 1.2 Product Data .1 Submit product data in accordance with Section 01 33 00 - Submittal Procedures.

PART 2 - PRODUCTS

- 2.1 Building Wires .1 Conductors: stranded for 10 AWG and larger. Minimum size: 12 AWG.
- .2 Phase neutral and ground conductors: Copper size as indicated, with 1000 V insulation of chemically cross-linked thermosetting polyethylene material rated RW90.
- 2.2 Control Wiring .1 600 V type: copper stranded annealed copper conductors, sizes as indicated with polyethylene insulation RW90 (x-link).

PART 3 - EXECUTION

- 3.1 Installation of Building Wires .1 Install wiring conduit in accordance with Section 26 05 34.
- 3.2 Installation of Control Wiring .1 Install control wiring in conduit.

END OF SECTION

PART 1 - GENERAL

- 1.1 References .1 ANSI/IEEE 837-2002, Qualifying Permanent Connections Used in Substation Grounding.

PART 2 - PRODUCTS

- 2.1 Equipment .1 Clamps for grounding of conductor: size as required to electrically conductive underground water pipe.
- .2 Copper conductor: minimum 6 m long for each concrete encased electrode, bare, stranded, tinned, soft annealed, size as indicated.
- .3 Rod electrodes: copper clad steel, 19 mm diameter by 3 m long.
- .4 Plate electrodes: copper, surface area 0.2 m², 1.6 mm thick.
- .5 Grounding conductors: bare stranded copper, soft annealed, size as indicated.
- .6 Insulated grounding conductors: green, type. XLPE.
- .7 Ground bus: copper, size as indicated, complete with insulated supports, fastenings, connectors.
- .8 Non-corroding accessories necessary for grounding system, type, size, material as indicated, including but not necessarily limited to:
- .1 Grounding and bonding bushings.
 - .2 Protective type clamps.
 - .3 Bolted type conductor connectors.
 - .4 Thermit welded type conductor connectors.
 - .5 Bonding jumpers, straps.
 - .6 Pressure wire connectors.
-

PART 3 - EXECUTION

- 3.1 Installation General
- .1 Install complete permanent, continuous grounding system including, electrodes, conductors, connectors, accessories. Where EMT is used, run ground wire in conduit.
 - .2 Install connectors in accordance with manufacturer's instructions.
 - .3 Protect exposed grounding conductors from mechanical injury.
 - .4 Make buried connections, and connections to conductive water main, electrodes, using permanent mechanical connectors or inspectable wrought copper compression connectors to ANSI/IEEE 837-2002.
 - .5 Use mechanical connectors for grounding connections to equipment provided with lugs.
 - .6 Soldered joints not permitted.
 - .7 Install bonding wire for flexible conduit, connected at both ends to grounding bushing, solderless lug, clamp or cup washer and screw. Neatly cleat bonding wire to exterior of flexible conduit.
 - .8 Install separate ground conductor to outdoor lighting standards.
 - .9 Make grounding connections in radial configuration only, with connections terminating at street side of water pipe. Avoid loop connections.
- 3.2 System and Circuit Grounding
- .1 Install system and circuit grounding connections to neutral of secondary 208 V system.
- 3.3 Equipment Grounding
- .1 Install grounding connections to typical equipment included in, but not necessarily limited to following list. Service equipment, transformers, switchgear, frames of motors, starters, control panels, elevators and escalators, distribution panels, outdoor lighting.
-

-
- 3.4 Grounding Bus .1 Install copper grounding bus mounted on insulated supports on wall of electrical rooms.
- .2 Ground items of electrical equipment in electrical room to ground bus with individual bare stranded copper connections size 3/0 AWG.
- 3.5 Communication Systems .1 Install grounding connections for voice/image/data, fire alarm, intercommunication systems as follows:
- .1 Voice/image/data systems: make grounding system in accordance with the IT & Telecommunication standards and requirements.
- .2 Fire alarm, intercommunication systems as indicated.
- 3.6 Field Quality Control .1 Perform tests in accordance with Section 26 05 00 - Common Work Results - Electrical.
- .2 Perform ground continuity and resistance tests using method appropriate to site conditions and to approval of the Departmental Representative and local authority having jurisdiction over installation.
- .3 Perform tests before energizing electrical system.

PART 1 - GENERAL

1.1 Related Sections .1 Section 01 00 10 - General Instructions.

1.2 General .1 Fastenings and supports: No electrical equipment to be fastened directly to drywall only drywall supports.

PART 2 - PRODUCT

2.1 Support Channels .1 U shape, size 41 x 41 mm, 2.5 mm thick, surface mounted, suspended and ceilings.

2.2 Manufacturer .1 Acceptable manufacturers: Cantruss, Electrovert or equivalent.

PART 3 - EXECUTION

3.1 Installation .1 Secure equipment to masonry, tile and plaster surfaces with lead anchors.

.2 Secure equipment to poured concrete with expandable inserts.

.3 Secure surface mounted equipment with twist clip fasteners to inverted T bar ceilings. Ensure that T bars are adequately supported to carry weight of equipment specified before installation.

.4 Support equipment, conduit or cables using clips, spring loaded bolts, cable clamps designed as accessories to basic channel members.

.5 Fasten exposed conduit or cables to building construction or support system using straps.

.1 One-hole malleable steel straps to secure surface conduits and cables 50 mm and smaller.

- 3.1 Installation
(Cont'd)
- .5 (Cont'd)
 - .2 Two-hole steel straps for conduits and cables larger than 50 mm.
 - .3 Beam clamps to secure conduit to exposed steel work.
 - .6 Suspended support systems.
 - .1 Support individual cable or conduit runs with 6 mm dia threaded rods and spring clips.
 - .2 Support 2 or more cables or conduits on channels supported by 6 mm dia threaded rod hangers where direct fastening to building construction is impractical.
 - .7 Provide metal brackets, frames, hangers, clamps and related types of support structures where indicated or as required to support conduit and cable runs.
 - .8 Ensure adequate support for raceways and cables dropped vertically to equipment where there is no wall support.
 - .9 Do not use wire lashing or perforated strap to support or secure raceways or cables.
 - .10 Do not use supports or equipment installed for other trades for conduit or cable support except with permission of other trade and approval of the Departmental Representative.
 - .11 Install fastenings and supports as required for each type of equipment cables and conduits, and in accordance with manufacturer's installation recommendations.
 - .12 Electrical panels, switches or other electrical equipment shall be complete with suitable bases or mounting brackets. Install angle or channel iron supports to bear the equipment where it is shown in or on structural tile walls, or walls that are inadequate to bear the equipment.
 - .13 Provide channel iron or other metal supports where necessary to adequately support lighting fixtures. Do not use wood. Lighting fixtures shall be supported totally independent of ceiling and supported from structure above.
 - .14 Support hangers, in general, from inserts in concrete construction or from building structural steel beams, using beam clamps. Provide Additional angle or channel steel members required between beams for supporting conduits.

PART 1 - GENERAL

1.1 Shop Drawings and Product Data .1 Submit shop drawings and product data for cabinets in accordance with Section 01 33 00 - Submittal Procedures.

1.2 Reference .1 CAN/CSA C22.2 NO. 76 (R2014) - Splitters.

.2 CSA C22.2 NO. 40-M1989 (R2014) - Cutout, Junction and Pull Boxes.

PART 2 - PRODUCTS

2.1 Junction and Pull Boxes .1 Welded steel construction with screw-on flat covers for surface mounting.

.2 Covers with 25 mm minimum extension all around, for flush-mounted pull and junction boxes.

2.2 Cabinets .1 Type E: sheet steel, hinged door and return flange overlapping sides, handle, lock and catch, for surface mounting.

2.3 Splitters .1 Sheet metal enclosure, welded corners and formed hinged cover suitable for locking in closed position.

.2 Main and branch lugs to match required size and number of incoming and outgoing conductors as indicated.

.3 At least three spare terminals on each set of lugs in splitters less than 400 A.

PART 3 - EXECUTION

- 3.1 Junction, Pull Boxes and Cabinets Installation
- .1 Install pull boxes in inconspicuous but accessible locations.
 - .2 Install terminal block as indicated in Type T cabinets.
 - .3 Only main junction and pull boxes are indicated. Install pull boxes so as not to exceed 30 m of conduit run between pull boxes.
- 3.2 Splitter Installation
- .1 Install splitters as indicated and mount plumb, true and square to the building lines.
 - .2 Extend splitters full length of equipment arrangement except where indicated otherwise.
- 3.3 Identification
- .1 Provide equipment identification in accordance with Section 26 05 00 - Common Work Results - Electrical.
 - .2 Install size 2 identification labels indicating system name, voltage and phase.

PART 1 - GENERAL

- 1.1 References .1 CSA C22.1-15 Canadian Electrical Code, Part 1.
- .2 CAN/CSA C22.2 No.18.1-13 Metallic Outlet Boxes (Tri-National Standard, with ANCE NMX-J-023/01 and UL 514A).

PART 2 - PRODUCTS

- 2.1 Outlet and Conduit Boxes General .1 Size boxes in accordance with CSA C22.1.
- .2 102 mm square or larger outlet boxes as required for special devices.
- .3 Gang boxes where wiring devices are grouped.
- .4 Blank cover plates for boxes without wiring devices.
- .5 Combination boxes with barriers where outlets for more than one system are grouped.
- .6 347 V outlet boxes for 347 V switching devices.
- 2.2 Sheet Steel Outlet Boxes .1 Electro-galvanized steel single and multi gang flush device boxes for flush installation, minimum size 76 x 50 x 38 mm or as indicated. 102 mm square outlet boxes when more than one conduit enters one side with extension and plaster rings as required.
- .2 102 mm square or octagonal outlet boxes for lighting fixture outlets.
- .3 102 mm square outlet boxes with extension and plaster rings for flush mounting devices in finished plaster or tile walls.
- 2.3 Masonry Boxes .1 Electro-galvanized steel masonry single and multi gang boxes for devices flush mounted in exposed block walls.
-

2.4 Concrete Boxes .1 Electro-galvanized sheet steel concrete type boxes for flush mount in concrete with matching extension and plaster rings as required.

2.5 Conduit Boxes .1 Cast FS boxes with factory-threaded hubs and mounting feet for surface wiring of switches and receptacle.

2.6 Fittings- General .1 Bushing and connectors with nylon insulated throats.
.2 Knock-out fillers to prevent entry of debris.
.3 Conduit outlet bodies for conduit up to 32 mm and pull boxes for larger conduits.
.4 Double locknuts and insulated bushings on sheet metal boxes.

PART 3 - EXECUTION

3.1 Installation .1 Support boxes independently of connecting conduits.
.2 Fill boxes with paper, sponges or foam or similar approved material to prevent entry of debris during construction. Remove upon completion of work.
.3 For flush installations mount outlets flush with finished wall using plaster rings to permit wall finish to come within 6 mm of opening.
.4 Provide correct size of openings in boxes for conduit. Reducing washers are not allowed.
.5 Provide a suitable outlet box for each light switch, receptacle or other outlet, approved for the particular area in which it is to be installed.
.6 Locate outlet boxes, mounted in hung ceiling space, so they do not obstruct or interfere with the removal of lay-in ceiling tiles.

3.1 Installation
(Cont'd)

- .7 Offset outlet boxes, shown back to back in partitions, horizontally to minimize noise transmission between adjacent rooms.
- .8 Use gang boxes at locations where more than one device is to be mounted. Use combination boxes with suitable barriers where outlets for more than one system are shown.

PART 1 - GENERAL

- 1.1 Location of Conduit .1 Drawings do not indicate all conduit runs. Those indicated are in diagrammatic form only.

PART 2 - PRODUCTS

- 2.1 Conduits .1 Rigid galvanized steel threaded conduit.
.2 Electrical metallic tubing (EMT): with couplings.
.3 Flexible steel conduit and liquid-tight flexible metal conduit.
- 2.2 Conduit Fastenings .1 One hole malleable iron straps to secure surface conduits 50 mm and smaller. Two hole steel straps for conduits larger than 50 mm.
.2 Beam clamps to secure conduits to exposed steel work.
.3 Channel type supports for two or more conduits at 2 m oc.
.4 Six mm dia threaded rods to support suspended channels.
- 2.3 Conduit Fittings .1 Fittings: manufactured for use with conduit specified. Coating: same as conduit.
.2 Factory "ells" where 90° bends are required for 25 mm and larger conduits.
.3 Raintight connectors and couplings for EMT. Set-screws are not acceptable.
- 2.4 Expansion Fittings for Rigid Conduit .1 Weatherproof expansion fittings with internal bonding assembly suitable for 100 mm linear expansion.
-

<u>2.4 Expansion Fittings for Rigid Conduit (Cont'd)</u>	.2	Watertight expansion fittings with integral bonding jumper suitable for linear expansion and 19 mm deflection in all directions.
	.3	Weatherproof expansion fittings for linear expansion at entry to panel.
<u>2.5 Fish Cord</u>	.1	Polypropylene.

PART 3 - EXECUTION

<u>3.1 Installation</u>	.1	Install conduits to conserve headroom in exposed locations and cause minimum interference in spaces through which they pass.
	.2	Conceal conduits except in mechanical and electrical service rooms and in unfinished areas.
	.3	Use electrical metallic tubing (EMT) for runs exposed, concealed in walls or suspended ceiling.
	.4	Use flexible metal conduit for connection to recessed incandescent fixtures without a prewired outlet box connection to recessed fluorescent fixtures.
	.5	Use liquid tight flexible metal conduit for connection to motors or vibrating equipment.
	.6	Minimum conduit size for lighting and power circuits: 19 mm.
	.7	Bend conduit cold. Replace conduit if kinked or flattened more than 1/10th of its original diameter.
	.8	Mechanically bend steel conduit over 19 mm dia.
	.9	Install fish cord in empty conduits.
	.10	Run 2- 27 mm spare conduits up to ceiling space from each flush panel. Terminate these conduits in 152 x 152 x 102 mm junction boxes in ceiling space or in case of an exposed concrete slab.

- 3.1 Installation (Cont'd)
- .11 Where conduits become blocked, remove and replace blocked section. Do not use liquids to clean out conduits.
 - .12 Dry conduits out before installing wire.
- 3.2 Surface Conduits
- .1 Run parallel or perpendicular to building lines.
 - .2 Locate conduits behind infrared or gas fired heaters with 1.5 m clearance.
 - .3 Run conduits in flanged portion of structural steel.
 - .4 Group conduits wherever possible on channels.
 - .5 Do not pass conduits through structural members except as indicated.
 - .6 Do not locate conduits less than 75 mm parallel to steam or hot water lines with minimum of 25 mm at crossovers.
- 3.3 Concealed Conduits
- .1 Run parallel or perpendicular to building lines.
 - .2 Do not install horizontal runs in masonry walls.
 - .3 Do not install conduits in terrazzo or concrete toppings.

PART 1 - GENERAL

<u>1.1 RELATED REQUIREMENTS</u>	.1	Section 01 33 00 - Submittal Procedures.
	.2	Section 26 05 00 - Common Work Results - Electrical.
	.3	Section 26 28 16.02 - Moulded Case Circuit Breakers.
<u>1.2 REFERENCES</u>	.1	Canadian Standards Association (CSA International) .1 CSA C22.2 No.29-2015, Panelboards and Enclosed Panelboards.
<u>1.3 ACTION AND INFORMATIONAL SUBMITTALS</u>	.1	Submit in accordance with Section 01 33 00 Submittal Procedures.
	.2	Product Data: .1 Submit manufacturer's instructions, printed product literature and data sheets for panelboards and include product characteristics, performance criteria, physical size, finish and limitations.
	.3	Shop Drawings: .1 Submit drawings stamped and signed by professional engineer registered or licensed in Province of Ontario, Canada. .2 Include on drawings: .1 Electrical detail of panel, branch breaker type, quantity, ampacity and enclosure dimension.
	.4	Sustainable Design Submittals: .1 Construction Waste Management: .1 Submit project Waste Management Plan highlighting recycling and salvage requirements. .2 Submit calculations on end-of-project recycling rates, salvage rates, and landfill rates demonstrating that 75% of construction wastes were recycled or salvaged.
<u>1.4 CLOSEOUT SUBMITTALS</u>	.1	Submit in accordance with Section 01 78 00 Closeout Submittals.

1.4 CLOSEOUT
SUBMITTALS
(Cont'd)

- .2 Operation and Maintenance Data: submit operation and maintenance data for panelboards for incorporation into manual.

1.5 DELIVERY,
STORAGE AND
HANDLING

- .1 Deliver, store and handle materials in accordance with Section 01 00 10 - General Instructions and with manufacturer's written instructions.
- .2 Delivery and Acceptance Requirements: deliver materials to site in original factory packaging, labelled with manufacturer's name and address.
- .3 Storage and Handling Requirements:
 - .1 Store materials off ground in dry location and in accordance with manufacturer's recommendations in clean, dry, well-ventilated area.
 - .2 Store and protect panelboards from nicks, scratches, and blemishes.
 - .3 Replace defective or damaged materials with new.
- .4 Develop Construction Waste Management Plan related to Work of this Section.
- .5 Packaging Waste Management: remove for reuse of pallets, crates, padding, and packaging materials as specified in Construction Waste Management Plan in accordance with Section 01 74 21 - Construction/Demolition Waste Management and Disposal.

PART 2 - PRODUCTS

2.1 PANELBOARDS

- .1 Panelboards: to CSA C22.2 No.29 and product of one manufacturer.
 - .1 Install circuit breakers in panelboards before shipment.
 - .2 In addition to CSA requirements manufacturer's nameplate must show fault current that panel including breakers has been built to withstand.
 - .2 250 V panelboards: bus and breakers rated for 22 kA (symmetrical) interrupting capacity or as indicated.
-

2.1 PANELBOARDS
(Cont'd)

- .3 Sequence phase bussing with odd numbered breakers on left and even on right, with each breaker identified by permanent number identification as to circuit number and phase.
- .4 Panelboards: mains, number of circuits, and number and size of branch circuit breakers as indicated.
- .5 Minimum of 2 flush locks for each panel board.
- .6 Two keys for each panelboard and key panelboards alike.
- .7 Copper bus with neutral of same ampere rating of mains.
- .8 Mains: suitable for bolt-on breakers.
- .9 Trim with concealed front bolts and hinges.
- .10 Trim and door finish: baked enamel as per colour schedule.
- .11 Isolated ground bus.
- .12 Include grounding busbar with 3 of terminals for bonding conductor similar to breaker capacity of the panel board.
- .13 Drip Shield for sprinkler protection.

2.2 BREAKERS

- .1 Breakers: to Section 26 28 16.02 - Moulded Case Circuit Breakers.
- .2 Breakers with thermal and magnetic tripping in panelboards except as indicated otherwise.
- .3 Main breaker: separately mounted on top or bottom of panel to suit cable entry. When mounted vertically, down position should open breaker.
- .4 Lock-on devices for 10% of 15 to 30 A breakers installed as indicated. Turn over unused lock-on devices to Departmental Representative.
- .5 Lock-on devices for receptacles, fire alarm, clock outlet, emergency, door supervisory, intercom, stairway, exit and night light circuits.

- 2.3 EQUIPMENT IDENTIFICATION
- .1 Provide equipment identification in accordance with Section 26 05 00 - Common Work Results for Electrical.
 - .2 Nameplate for each panelboard size 4 engraved as indicated.
 - .3 Nameplate for each circuit in distribution panelboards size 2 engraved as indicated.
 - .4 Complete circuit directory with typewritten legend showing location and load of each circuit, mounted in plastic envelope at inside of panel door.
 - .5 Circuits supplying Patient Care Areas must be entered in circuit directory with Bold Font.

PART 3 - EXECUTION

- 3.1 EXAMINATION
- .1 Verification of Conditions: verify that conditions of substrate previously installed under other Sections or Contracts are acceptable for panelboards installation in accordance with manufacturer's written instructions.
 - .1 Visually inspect substrate in presence of Departmental Representative.
 - .2 Inform Departmental Representative of unacceptable conditions immediately upon discovery.
 - .3 Proceed with installation only after unacceptable conditions have been remedied and after receipt of written approval to proceed from Departmental Representative.

- 3.2 INSTALLATION
- .1 Locate panelboards as indicated and mount securely, plumb, true and square, to adjoining surfaces.
 - .2 Install surface mounted panelboards on plywood backboards. Where practical, group panelboards on common backboard.
 - .3 Mount panelboards to height specified in Section 26 05 00 - Common Work Results for Electrical or as indicated.
 - .4 Connect loads to circuits.
 - .5 Connect neutral conductors to common neutral bus with respective neutral identified.
-

3.2 INSTALLATION

(Cont'd)

- .6 Where panels of different systems (i.e. Standard and Vital Power) supply a common patient care area, ground busses in panels to be interconnect with a minimum #6 AWG ground conductor.

3.3 CLEANING

- .1 Progress Cleaning: clean in accordance with Section 01 74 11 - Cleaning.
.1 Leave Work area clean at end of each day.
- .2 Final Cleaning: upon completion remove surplus materials, rubbish, tools and equipment in accordance with Section 01 74 11 - Cleaning.
- .3 Waste Management: separate waste materials for reuse and recycling in accordance with Section 01 74 21 - Construction/Demolition Waste Management and Disposal.
.1 Remove recycling containers and bins from site and dispose of materials at appropriate facility.

3.4 PROTECTION

- .1 Protect installed products and components from damage during construction.
- .2 Repair damage to adjacent materials caused by panelboards installation.

PART 1 - GENERAL

1.1 RELATED
REQUIREMENTS

- .1 Section 01 33 00 - Submittal Procedures.
- .2 Section 01 74 21 - Construction/Demolition Waste Management and Disposal.

1.2 REFERENCES

- .1 Canadian Standards Association (CSA International).
 - .1 CSA C22.2 No. 5-13, Molded-Case Circuit Breakers, Molded-Case Switches and Circuit-Breaker Enclosures (Tri-national standard with UL 489, and NMX-J-266-ANCE-2013), Update No. 1(2014).

1.3 ACTION AND
INFORMATIONAL
SUBMITTALS

- .1 Submit in accordance with Section 01 33 00 - Submittal Procedures.
 - .2 Product Data:
 - .1 Submit manufacturer's instructions, printed product literature and data sheets for circuit breakers and include product characteristics, performance criteria, physical size, finish and limitations.
 - .3 Certificates:
 - .1 Prior to installation of circuit breakers in either new or existing installation, Contractor must submit 3 copies of a production certificate of origin from the manufacturer. Production certificate of origin must be duly signed by factory and local manufacturer's representative certifying that circuit breakers come from this manufacturer and are new and meet standards and regulations.
 - .1 Production certificate of origin must be submitted to Departmental Representative for approval.
 - .2 Delay in submitting production of certificate of origin will not justify any extension of contract and additional compensation.
-

- 1.4 DELIVERY,
STORAGE AND
HANDLING
(Cont'd)
- .2 Delivery and Acceptance Requirements: deliver materials to site in original factory packaging, labelled with manufacturer's name and address.
 - .3 Storage and Handling Requirements:
 - .1 Store circuit breakers off ground in dry location and in accordance with manufacturer's recommendations in clean, dry, well-ventilated area.
 - .2 Store and protect circuit breakers from nicks, scratches, and blemishes.
 - .3 Replace defective or damaged materials with new.
 - .4 Develop Construction Waste Management Plan related to Work of this Section.
 - .5 Packaging Waste Management: remove for reuse of pallets, crates, padding, and packaging materials as specified in Construction Waste Management Plan in accordance with Section 01 74 21 - Construction/Demolition Waste Management and Disposal.

PART 2 - PRODUCTS

- 2.1 BREAKERS
GENERAL
- .1 Moulded-case circuit breakers, Circuit breakers, and ground-fault circuit-interrupters, fused circuit breakers, and accessory high-fault protectors: to CSA C22.2 No. 5.
 - .2 Bolt-on moulded case circuit breaker: quick-make, quick-break type, for manual and automatic operation with temperature compensation for 40 degrees C ambient.
 - .3 Common-trip breakers: with single handle for multi-pole applications.
 - .4 Magnetic instantaneous trip elements in circuit breakers to operate only when value of current reaches setting.
 - .1 Trip settings on breakers with adjustable trips to range from 3-8 times current rating.
 - .5 Circuit breakers with interchangeable trips as indicated.
-

- 2.2 THERMAL
MAGNETIC BREAKERS
DESIGN A .1 Moulded case circuit breaker to operate automatically by means of thermal and magnetic tripping devices to provide inverse time current tripping and instantaneous tripping for short circuit protection.
- 2.3 MAGNETIC
BREAKERS DESIGN B .1 Moulded case circuit breaker to operate automatically by means of magnetic tripping devices to provide instantaneous tripping for short circuit protection.
- 2.4 CURRENT
LIMITING AND SERIES
RATED THERMAL
MAGNETIC BREAKERS
DESIGN C .1 Thermal magnetic breakers with current limiters.
.1 Time current limiting characteristics of fuses limiters coordinated with time current tripping characteristics of circuit breaker.
.2 Co-ordination to result in interruption by breaker of fault-level currents up to interrupting capacity of breaker.
.2 Series rated breakers to be manufacturer tested and listed. Breakers to be applied following manufacturer's guidelines and accepted best practice.
.1 Breakers applied following manufacturer's guidelines and accepted best practice.
- 2.5 OPTIONAL
FEATURES .1 Include:
.1 Shunt trip.
.2 Auxiliary switch.
.3 Motor-operated mechanism c/w time delay unit.
.4 Under-voltage release.
.5 On-off locking device.
.6 Handle mechanism.

PART 3 - EXECUTION

- 3.1 INSTALLATION .1 Install circuit breakers as indicated.
- 3.2 CLEANING .1 Progress Cleaning: clean in accordance with Section 01 74 11 - Cleaning.
.1 Leave Work area clean at end of each day.
-

3.2 CLEANING

(Cont'd)

- .2 Final Cleaning: upon completion remove surplus materials, rubbish, tools and equipment in accordance with Section 01 74 11 - Cleaning.
- .3 Waste Management: separate waste materials for reuse and recycling in accordance with Section 01 74 21 - Construction/Demolition Waste Management and Disposal.
 - .1 Remove recycling containers and bins from site and dispose of materials at appropriate facility.

PART 1 - GENERAL

- 1.1 RELATED REQUIREMENTS
- .1 Section 01 33 00 - Submittal Procedures.
 - .2 Section 01 35 29.06 - Health and Safety Requirements.
 - .3 Section 01 74 21 - Construction/Demolition Waste Management and Disposal.
 - .4 Section 26 05 00 - Common Work Results For Electrical.
- 1.2 REFERENCES
- .1 Canadian Standards Association (CSA International).
 - .1 CAN/CSA-C22.2 No.4-04 (2014), Enclosed and Dead-Front Switches (Tri-National Standard, with ANCE NMX-J-162-2004 and UL 98).
 - .2 CSA C22.2 No.39-13, Fuseholder Assemblies.
- 1.3 ACTION AND INFORMATIONAL SUBMITTALS
- .1 Submit in accordance with Section 01 33 00 Submittal Procedures.
 - .2 Product Data:
 - .1 Submit manufacturer's instructions, printed product literature and data sheets for disconnect switches - fused and non-fused and include product characteristics, performance criteria, physical size, finish and limitations.
 - .3 Sustainable Design Submittals:
 - .1 Construction Waste Management:
 - .1 Submit project Waste Management Plan highlighting recycling and salvage requirements.
 - .2 Submit calculations on end-of-project recycling rates, salvage rates, and landfill rates demonstrating that 75% of construction wastes were recycled or salvaged.
 - .2 Recycled Content:
 - .1 Submit listing of recycled content products used, including details of required percentages or recycled content materials and products, showing their costs and percentages of post-consumer and post-industrial content, and total cost of materials for project.
-

1.3 ACTION AND
INFORMATIONAL
SUBMITTALS
(Cont'd)

- .3 (Cont'd)
- .2 (Cont'd)
- .3 Regional Materials: submit evidence that project incorporates required percentage of regional materials and products, showing their cost, distance from project to furthest site of extraction or manufacture, and total cost of materials for project.

1.4 DELIVERY,
STORAGE AND
HANDLING

- .1 Deliver, store and handle materials in accordance with Section 01 00 10 - General Instructions and with manufacturer's written instructions.
- .2 Delivery and Acceptance Requirements: deliver materials to site in original factory packaging, labelled with manufacturer's name and address.
- .3 Storage and Handling Requirements:
 - .1 Store materials off ground in dry location and in accordance with manufacturer's recommendations in clean, dry, well-ventilated area.
 - .2 Store and protect disconnect switches - fused and non-fused from nicks, scratches, and blemishes.
 - .3 Replace defective or damaged materials with new.
- .4 Develop Construction Waste Management Plan related to Work of this Section.
- .5 Packaging Waste Management: remove for reuse of pallets, crates, padding, and packaging materials as specified in Construction Waste Management Plan in accordance with Section 01 74 21 - Construction/Demolition Waste Management and Disposal.

PART 2 - PRODUCTS

2.1 DISCONNECT
SWITCHES

- .1 Fusible, Non-fusible, Horsepower rated disconnect switch in CSA enclosure, to CAN/CSA-C22.2 No.4, size as indicated.
 - .2 Provision for padlocking in off switch position by 2 locks.
 - .3 Mechanically interlocked door to prevent opening when handle in ON position.
-

- 2.1 DISCONNECT SWITCHES (Cont'd)
- .4 Fuses: size as indicated.
 - .5 Fuseholders: to CSA C22.2 No.39 relocatable and suitable without adaptors, for type and size of fuse indicated.
 - .6 Quick-make, quick-break action.
 - .7 ON-OFF switch position indication on switch enclosure cover.
 - .8 Sprinkler proof drip shield.
 - .9 Provide weatherproof (suitable for outdoor installations) disconnect switches where noted on the drawings.

- 2.2 EQUIPMENT IDENTIFICATION
- .1 Provide equipment identification in accordance with Section 26 05 00 - Common Work Results - Electrical.
 - .2 Indicate name of load controlled on size 4 nameplate.

PART 3 - EXECUTION

- 3.1 INSTALLATION
- .1 Install disconnect switches complete with fuses if applicable.

- 3.2 CLEANING
- .1 Progress Cleaning: clean in accordance with Section 01 74 11 - Cleaning.
 - .1 Leave Work area clean at end of each day.
 - .2 Final Cleaning: upon completion remove surplus materials, rubbish, tools and equipment in accordance with Section 01 74 11 - Cleaning.
 - .3 Waste Management: separate waste materials for reuse and recycling in accordance with Section 01 74 21 - Construction/Demolition Waste Management and Disposal.
 - .1 Remove recycling containers and bins from site and dispose of materials at appropriate facility.

PART 1 - GENERAL

- 1.1 Product Data .1 Submit product data in accordance with Section 01 33 00 - Submittal Procedures.

PART 2 - PRODUCTS

- 2.1 Contactors .1 Contactors: to EEMAC No.1CS-1970.
- .2 Electrically held controlled by pilot devices as indicated and rated for type of load controlled.
- .3 Complete with 2 normally open and 2 normally closed auxiliary contacts unless indicated otherwise.
- .4 Mount in CSA Enclosure 2, (sprinklerproof) unless otherwise indicated.
- .5 Include following options in cover:
.1 Red indicating lamp.
.2 Hand-off-auto selector switch.
- .6 Coil and contact electrical characteristics as indicated on drawings.
- .7 Acceptable manufacturers: Square D, Westinghouse, FPE or Siemens Cutler Hammer.
- 2.2 Equipment Identification .1 Provide equipment identification in accordance with Section 26 05 00 - Common Work Results - Electrical.
- .2 Label size 25 mm high indicating name of load controlled as indicated.
- 2.3 Industrial Relays .1 Industrial relays c/w 120 volt control coil, quantity of contacts as indicated.
- .2 Contacts rated for 16 amperes at 125 volts A/C.
-

-
- 2.3 Industrial Relays
(Cont'd)
- .3 Relays to be mounted in CSA enclosure 1, surface mounted.
Siemens #869-2G1 or equivalent.
 - .4 Acceptable Materials: Siemens or equivalent.
 - .1 4 contacts N.O. - #3TK20 40-OAK6.
 - .2 3 contacts N.O. - #3TK20 31-AOK6.
 - .3 2 contacts N.O. - #3TK20 22-OAK6.

PART 3 - EXECUTION

- 3.1 Installation
- .1 Install contactors and connect auxiliary control devices as indicated.
 - .2 Install relays and connect auxiliary control devices as indicated.

PART 1 - GENERAL

- 1.1 Shop Drawings and Product Data
- .1 Submit shop drawings in accordance with Section 01 33 00 - Submittal Procedures.
 - .2 To indicate:
 - .1 Mounting method and dimensions.
 - .2 Starter size and type.
 - .3 Layout of identified internal and front panel components.
 - .4 Enclosure types.
 - .5 Wiring diagram for each type of starter.
 - .6 Interconnection diagrams.
- 1.2 Operation and Maintenance Data
- .1 Provide operation and maintenance data for motor starters for incorporation into manual specified in Section 01 78 00 - Closeout Submittals.
 - .2 Include operation and maintenance data for each type and style of starter.

PART 2 - PRODUCTS

- 2.1 Materials
- .1 Starters: EEMAC E14-1.
 - .1 Half size starters are acceptable.
- 2.2 Manual Motor Starters
- .1 Three phase and single phase manual motor starters of size, type, rating, and enclosure type as indicated, with components as follows:
 - .1 Switching mechanism, quick make and break.
 - .2 Three overload heaters, manual reset, trip indicating handle.
 - .2 Accessories:
 - .1 Switch pushbutton: heavy duty labelled as indicated.
 - .2 Indicating light: heavy duty type and colour as indicated.
 - .3 Locking tab to permit padlocking in "ON" or "OFF" position.
-

-
- 2.3 Full Voltage Magnetic Starters
- .1 Combination magnetic starters of size, type, rating and enclosure type as indicated with components as follows:
 - .1 Contactor solenoid operated, rapid action type.
 - .2 Motor overload protective device in each phase, manually reset from outside enclosure.
 - .3 Power and control terminals.
 - .4 Wiring and schematic diagram inside starter enclosure in visible location.
 - .5 Identify each wire and terminal for external connections, within starter, with permanent number marking identical to diagram.
 - .2 Combination type starters to include disconnect switch with operating lever on outside of enclosure to control disconnect and provision for:
 - .1 Locking in "OFF" position with up to 3 padlocks.
 - .2 Locking in "ON" position.
 - .3 Independent locking of enclosure door.
 - .3 Accessories:
 - .1 Selector switches: heavy duty labelled as indicated.
 - .2 Indicating lights: heavy duty type and color as indicated.
 - .3 1-N/O and 1-N/C spare auxiliary contacts unless otherwise indicated.
- 2.4 Control Transformer
- .1 Single phase, dry type, control transformer with primary voltage as indicated and 120V secondary, complete with secondary fuse, installed in with starter as indicated.
 - .2 Size control transformer for control circuit load plus 20% spare capacity.
- 2.5 Finishes
- .1 Apply finishes to enclosure in accordance with Section 26 05 00 - Common Work Results - Electrical.
- 2.6 Equipment Identification
- .1 Provide equipment identification in accordance with Section 16010 - Common Work Results - Electrical.
 - .2 Manual starter designation label, white plate, black letters, size 1, engraved as indicated.
-

2.6 Equipment Identification (Cont'd) .3 Magnetic starter designation label, white plate, black letters, size 2 engraved as indicated.

PART 3 - EXECUTION

3.1 Installation .1 Install starters, connect power and control as indicated.
.2 Ensure correct fuses and overload devices elements installed.

3.2 Tests .1 Perform tests in accordance with Section 26 05 00 - Common Work Results - Electrical and manufacturer's instructions.
.2 Operate switches, contactors to verify correct functioning.
.3 Perform starting and stopping sequences of contactors and relays.
.4 Check that sequence controls, interlocking with other separate related starters, equipment, control devices, operate as indicated.