



RETURN BIDS TO:
RETOURNER LES SOUMISSIONS À:
Bid Receiving Public Works and Government
Services Canada/Réception des soumissions
Travaux publics et Services gouvernementaux
Canada
800 Burrard Street, Room 219
800, rue Burrard, pièce 219
Vancouver
British Columbia
V6Z 0B9
Bid Fax: (604) 775-9381

SOLICITATION AMENDMENT

MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution
Public Works and Government Services Canada -
Pacific Region
800 Burrard Street, Room 219
800, rue Burrard, pièce 219
Vancouver
British C
V6Z 0B9

Title - Sujet Stair Replacement	
Solicitation No. - N° de l'invitation EZ899-162132/A	Amendment No. - N° modif. 001
Client Reference No. - N° de référence du client	Date 2016-02-29
GETS Reference No. - N° de référence de SEAG PW-\$PWY-025-7748	
File No. - N° de dossier PWY-5-38375 (025)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2016-03-07	Time Zone Fuseau horaire Pacific Standard Time PST
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Fung, Donna(PWY)	Buyer Id - Id de l'acheteur pwy025
Telephone No. - N° de téléphone (604) 666-9835 ()	FAX No. - N° de FAX (604) 775-6633
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction: Parks Canada - Gitwangak Battle Hill National Historic Site - Kitwanga, BC	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

Solicitation No. - N° de l'invitation
EZ899-162132/A

Amd. No. - N° de la modif.
001

Buyer ID - Id de l'acheteur
pwy025

Client Ref. No. - N° de réf. du client

File No. - N° du dossier

CCC No./N° CCC - FMS No/ N° VME

This Amendment No. 001 is raised to incorporate Addendum No. 001

ALL OTHER TERMS AND CONDITIONS REMAIN UNCHANGED.

ADDENDUM

Project: West Coast Trail Bridges Repair

Addendum No.: 001

Gitwangak Battle Hill Stair Replacement, Kitwanga, BC

Project No.: R.076123.001

Requisition No.: EZ899-162132/A

March 1, 2016

GENERAL

This Addendum forms part of the Contract Documents for **Project No. R.076123.001** and amends the original drawings and Specifications. The following revisions supersede the information contained in the original drawings and Specifications issued to the extent referenced and shall become part thereof. No adjustment to the Contract Price will be considered or allowed due to the Contractor or to any sub-contractor or supplier not being familiar with this Addendum.

Questions and Answers:

Question No1: Bid documents indicate all excavations must be monitored, who is covering costs for archeologist? Parks Canada or General contractor?

Answer no1: Contractor is not responsible for hiring the Archaeologist for monitoring during construction. Golder Associates is the Archaeologist that will monitor the site during construction and is retained by the consultant - WSP.

Question No2: In the plans there is an item named "B1" referring to wood beams under the platforms and landings, but I can find no description for these beams

Answer no2: See the notes at the bottom left corner of the drawing S-2 that show B1=50x300 (note 10.). Note 5 Shows that the all the stringers are to be No1 Cedar, which is the case of the beam B1.

End of Addendum