

ADDENDUM NUMBER: THREE

ISSUED BY: SEPW Architecture Inc.
109 – 3725 Pasqua St., Regina, SK. S4S 6W8
PH. (306) 569-2255

**PROJECT: 25B RANGE RENOVATION
REGINA, SK.**

This addendum forms part of the Contract documents and amends the original Drawings and Specifications dated 2016-01-12, previous Addenda if applicable and as noted below. This Addendum consists of 2 pages.

Ensure that all parties are aware of all items included in this Addendum

A-3-1 REF. SECTION 13 54 00, FIRING RANGE BAFFLES

.1 A question was asked by one of the Bidders regarding the responsibility of the baffle supplier for the suspension system. We note the following is contained in the Specifications:

Clause 1.3.3 Note requirement for engineer signed and stamped shop drawings.

Further to this we note the manufacturer must meet the following requirement.

Clause 1.4.3 states:

“Range baffle manufacturer must have a minimum of ten (10) years’ experience in the manufacturing of range baffles and who are regularly engaged in the design and manufacturing of the type of range baffles specified. If requested, provide five (5) actual installations of compatible design, construction, and size with proven durability.”

Further to this Clause 2.1.7.1 states:

“Baffle supplier shall be responsible for design of the adjustable suspension system for the baffle assembly.”

A-3-2 REF. ADDENDUM 2 (SEPW)

.1 Reference Addendum TWO item A-2-1, CLARIFICATION: The Specification Section number should have read 13 54 00 Firing Range Baffles not 12 54 00.

A-3-3 REF. AMENDMENT 3 –Q5 AND ADDENDUM 1 (SEPW)

Q5 In Amendment #2 it states that the RCMP staff maintain the system. Will they be removing and reinstalling the system or are we to carry the cost?

A5. **CHANGE TO READ:** This work is to be included in the contract and SHALL be completed by a Mancom representative or personnel authorized to install Mancom target carrier system.

A-3-4 REF. ELECTRICAL

.1 CLARIFICATION: The contractor is responsible to carry all associated costs for programming changes to the existing Mancom target retrieval system required in order to meet electrical specifications section 26 09 25 – HMI and Controls Narrative. A contact number was provided in an earlier addendum and is repeated below.
1-905-304-6141.

END OF ADDENDUM NO. 3