



- ### KEYNOTES
- ① COORDINATE FINAL LOCATION WITH MECHANICAL EQUIPMENT INSTALLATIONS.
  - ② ELECTRICAL BOXES SHALL NOT BE INSTALLED WITHIN OR OVER THIS ROOM UNLESS SPECIFICALLY SERVICING EQUIPMENT OR DEVICES LOCATED WITHIN.
  - ③ THREE POSITION - TWO CIRCUIT SWITCH, UP POSITION MAIN LIGHTS, DOWN POSITION NIGHT LIGHTS, CENTER OFF.
  - ④ LIGHT SWITCHES IN ROOMS 159, 164, 171 SHALL BE COMPLETE WITH PLASTER RINGS.
  - ⑤ INSTALL IN SINGLE CONTINUOUS RUN WITH LINEAR SUSPENDED LUMINAIRE TOTAL LENGTHS AS INDICATED.
  - ⑥ WIRE ALL PENDANT LIGHTS (TYPE I) TO SAME DIMMER SWITCH BEHIND ENTRY COUNTER AND TO CIRCUIT PC-4.
  - ⑦ SUSPEND LIGHT FIXTURES AT 2600mm ABOVE FINISHED FLOOR.
  - ⑧ COORDINATE WITH MECHANICAL AND ARCHITECTURAL TRADES PRIOR TO INSTALLATION OF BOXES FOR WALL SCONCE TYPE H FIXTURES. SEE ELEVATION ON DRAWING 606-11.
  - ⑨ SUSPEND LIGHT FIXTURE TO MATCH HEIGHT OF SURFACE MOUNTED FIXTURES IN ROOM 163.
  - ⑩ FLUSH MOUNT DEVICES IN ROOMS WITH ACCOUSTIC WALL PANELS. SUPPLY ALL EXTENSION RINGS AND TAMPERPROOF HARDWARE AS REQUIRED.
  - ⑪ FIELD SET TIME DELAY TO 30 MINUTES.

- ### NOTES:
1. LIGHT SWITCHES DENOTED WITH 'a,b' TO CONTROL LIGHT FIXTURES DENOTED WITH 'a,b' RESPECTIVELY.
  2. EXIT LIGHTS IN NORTH-EAST SECTION TO BE ON CIRCUIT PE-1.
  3. EXIT LIGHTS IN SOUTH-WEST SECTION TO BE ON CIRCUIT PC-1.
  4. CIRCUIT EMERGENCY BATTERY BACKUP LIGHTS INTO NEARBY LIGHTING CIRCUIT.

### LIGHTING SCHEDULE

SYMBOL	DESCRIPTION	LAMP	VOLTAGE	MOUNTING
A2	610 x 1220mm RECESSED MOUNTED LED FIXTURE	LED 4300L	120V	RECESSED IN T-BAR CEILING
AD	610 x 1220mm RECESSED MOUNTED LED FIXTURE C/W DRYWALL KIT	LED 4300L	120V	RECESSED IN DRYWALL CEILING
B	50x2440mm RECESSED LINEAR LED	LED 560L/FT	120V	RECESSED IN T-BAR CEILING. CONTINUOUS RUN
B1	50mm SUSPENDED LINEAR LED	LED 560L/FT	120V	SUSPENDED AT 4500mm A.F.F. CONTINUOUS RUN
C	1220mm SURFACE MOUNTED FIXTURE SECURE TYPE, VANDAL PROOF	LED 3500L	120V	SURFACE MOUNTED. COORDINATE INSTALLATION WITH CEILING TYPE PER DRAWING 601-4.
D	RECESSED LED POT LIGHT FIXTURE	LED 1000L	120V	RECESSED IN T-BAR / DRYWALL CEILING
D1	RECESSED LED POT LIGHT FIXTURE	LED 2500L	120V	RECESSED IN T-BAR/ DRYWALL CEILING
E	RECESSED LED POT LIGHT 75mm	LED 400L	120V	RECESSED DRYWALL CEILING. COORDINATE WITH ANTIVULT INSTALLATION.
F	1220mm LED STRIP LIGHT	LED 4000L	120V	SURFACE MOUNTED/ SUSPENDED FROM CHAIN. COORDINATE WITH MECHANICAL EQUIPMENT INSTALLATIONS.
G	1220mm SURFACE MOUNTED WRAP LED FIXTURE	LED 4000L	120V	SURFACE MOUNTED/ SUSPENDED FROM CHAIN. COORDINATE WITH MECHANICAL EQUIPMENT INSTALLATIONS.
H	SURFACE MOUNTED LED WALL SCONCE	LED 900L 28W	120V	WALL MOUNTED AT 3050mm A.F.F. SEE KEYNOTE 8 AND ELEVATION ON DRAWING 606-11.
I	DECORATIVE PENDANT LIGHT FIXTURE	LED 2300L	120V 30W	PENDANT SUSPENDED AT 3657mm (BOTTOM OF FIXTURE) A.F.F. COMPLETE WITH ALL MOUNTING HARDWARE AS REQUIRED
J	1220mm SECURE TYPE FIXTURE WITH NIGHT LIGHT	2-32W T8 9W-NL	120V	COORDINATE EXACT LOCATION WITH DEPARTMENTAL REPRESENTATIVE
K/K1	LED WALL PACK/ WITH BUILT IN PHOTOCCELL	LED 2500L	120V	WALL MOUNTED AT 3300mm OR AS INDICATED
M	500mm LED TASK LIGHT LOW PROFILE C/W ROCKER SWITCH	LED	120V 6W	MOUNTED UNDER CABINET. COORDINATE WITH CASEWORK INSTALLATION.
N	1220mm SURFACE MOUNTED LED VANITY	LED 1530L	120V 15W	MOUNTED ABOVE VANITY MIRROR/ ABOVE LOCKERS. SEE ARCHITECTURAL CASEWORK AND INTERIOR ELEVATION DRAWING 606-2.
Q	SURFACE MOUNTED LOW PROFILE LED FIXTURE	LED 740L	120V	SURFACE MOUNTED
R	1220mm SURFACE MOUNTED LED LINEAR STRIP COVE LIGHT	LED 4000L	120V	MOUNTED APPROX. 2875mm A.F.F. IN ALCOVE. SEE ARCHITECTURAL CASEWORK AND INTERIOR ELEVATION DRAWING 606-3 AND 606-6.
S	RECESSED LED SHOWER POT LIGHT	LED 900L	120V	RECESSED IN SHOWER CEILING
S1	SURFACE MOUNTED SHOWER LIGHT-BEHAVIORAL TYPE	18W QUAD CFL	120V 18W	SURFACE MOUNTED ON SHOWER CEILING. COMPLETE WITH TAMPER PROOF HARDWARE.
V	RECESSED LED POT LIGHT FIXTURE	LED 650L	120V 9W	RECESSED MOUNTED IN CANOPY. COORDINATE WITH ARCHITECTURAL
W	LED SUSPENDED LIGHT FIXTURE	LED 6400L	120V	SUSPENDED WITH AIRCRAFT CABLE AT 3550 A.F.F.
Y	LED BOLLARD - SUPPLIED BY DIVISION 10 AND INSTALLED BY DIVISION 26.	LED 270L	120V	COMPLETE WITH BASE. SEE DRAWINGS 2600-1 AND 2600-2.
Z/Z2	EXTERIOR POLE MOUNTED LED FIXTURE. TYPE 4 DISTRIBUTION/ TYPE 5 DISTRIBUTION.	LED 8000L	120V	MOUNTED ON 7650mm POLE C/W POLE BASE AND MOUNTING HARDWARE. SEE DRAWINGS 2600-1 AND 2600-2.
X	LED EMERGENCY LIGHTS BATTERY PACK	LED 5W 12V	120V	WALL MOUNTED AT 2440mm A.F.F.
X2	CEILING MOUNT/ WALL MOUNT LED EXIT LIGHT COMPLETE WITH BATTERY	LED	120V	SURFACE MOUNTED TO CEILING/ WALL AS SHOWN. C/W DIRECTIONAL ARROWS AS REQUIRED. *X2 INDICATES VANDAL RESISTANT

LIGHTING FLOOR PLAN - MAIN LEVEL  
SCALE : 1:100

PWGS B1 (2004)



KEY PLAN  
SCALE - NTS



0	RELEASED FOR CONSTRUCTION	01/29/2016
revisions		date
project		project

NEW  
G.O.C.B  
SAINT-LÉONARD  
NEW BRUNSWICK

MAIN FLOOR PLAN  
LIGHTING

designed SRP	conçu
date JANUARY 29, 2016	
drawn CAM	dessiné
date JANUARY 29, 2016	
approved DAG	approuvé
date FEBRUARY 17, 2016	
Tender	Submission

PWGS Project Manager / Administrateur de projets TPSCG  
project number / no. du projet  
**R.069499.001**

drawing no. / no. du dessin  
**2602-1**