



RETURN BIDS TO:
RETOURNER LES SOUMISSIONS À:
Bid Receiving Public Works and Government
Services Canada/Réception des soumissions
Travaux publics et Services gouvernementaux
Canada
800 Burrard Street, Room 219
800, rue Burrard, pièce 219
Vancouver
British Columbia
V6Z 0B9
Bid Fax: (604) 775-9381

SOLICITATION AMENDMENT
MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution
Public Works and Government Services Canada -
Pacific Region
800 Burrard Street, Room 219
800, rue Burrard, pièce 219
Vancouver
British C
V6Z 0B9

Title - Sujet CFIA Boiler Replacement	
Solicitation No. - N° de l'invitation 39903-150594/A	Amendment No. - N° modif. 002
Client Reference No. - N° de référence du client	Date 2016-03-07
GETS Reference No. - N° de référence de SEAG PW-\$PWY-028-7749	
File No. - N° de dossier PWY-5-38374 (028)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2016-03-15	Time Zone Fuseau horaire Pacific Standard Time PST
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Lam (PWY), Tian	Buyer Id - Id de l'acheteur pwy028
Telephone No. - N° de téléphone (604) 775-9382 ()	FAX No. - N° de FAX (604) 775-6633
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction: CFIA - Burnaby Lab - Burnaby, BC	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

Solicitation No. - N° de l'invitation
39903-150594/A

Amd. No. - N° de la modif.
002

Buyer ID - Id de l'acheteur
pwy028

Client Ref. No. - N° de réf. du client

File No. - N° du dossier CCC No./N°
PWY-5-38374

CCC - FMS No./N° VME

Les documents français seront disponibles sur demande.
Vous trouverez l'addenda n° 1 ci-joint.
Les autres conditions ne changent pas.

This amendment is raised to include Annex D in the solicitation documents and to issue Addendum #001.

Please find attached herein:

- 1) Annex D (form to be submitted by the Bidder with his/her Bid)
- 2) Addendum #001

All other terms and conditions remain unchanged.

Solicitation No. - N° de l'invitation
39903-150594/A

Amd. No. - N° de la modif.
002

Buyer ID - Id de l'acheteur
pwy028

Client Ref. No. - N° de réf. du client

File No. - N° du dossier CCC No./N°
PWY-5-38374

CCC - FMS No./N° VME

ANNEXE D - LISTE DES SOUS-TRAITANTS

- 1) Conformément à la clause IG07 – Liste des sous-traitants et fournisseurs des Instructions générales - Services de construction - Exigences relatives à la garantie de soumission R2710T, le soumissionnaire devrait accompagner sa soumission d'une liste de sous-traitants.
- 2) Le soumissionnaire devrait soumettre la liste des sous-traitants pour toute partie des travaux dont la valeur équivaut à au moins 20 % du prix soumissionné.

	Sous-traitant	Division	Valeur estimative des travaux
1			
2			
3			
4			
5			
6			
7			
8			
9			
10			
11			
12			
13			
14			
15			

**CFIA Burnaby Boiler Replacement
3155 Willingdon Green, Burnaby, BC
Addendum #1**

The following changes / clarifications in the tender documents are effective immediately. This Addendum will form part of the Contract Documents.

Response to Bidders' Inquiries:

Please find below a response to bidder's inquiries received to date.

1. **Add clause 2.1.12.7 in Section 23 52 00 – Heating Boilers as follow:**
.7 Boiler shall be suitable for and rated for operation with the existing heating system, which operates with water at pH over 9.
2. **The sequence calls for a flow sensor in the common line but on the mechanical drawings they're showing 5 flow meters. Can you clarify this for me?**
Provide flow measuring stations per schematic drawing. Note: sequence of control quoted clarifies operation for one of them.
3. **There is no valve symbol for the symbol below on hot water schematic drawing – M4.01. Please advise us what kind of valve is.**



This is flow measuring balance valve ("circuit setter"). Note, that all balance valves on the project are flow measuring balance valve type ("circuit setters"). Add the valve symbol to the legend.

4. **I do not see a list of supplied materials? On drawing M3.02 detail 8 indicated to install new check valve for AHU coil, but there is no any size provided either this detail or schematic. Please advise.**
The detail 8 on drawing M3.02 is information only, refer to hot water system schematic drawing M4.01 for scope of work related to existing control valve stations at air handling units.
5. **On drawing M4.01 showing the 65ø new bypass line to be installed. Can you provide the plan drawing for the layout of the existing piping?**
Exact location of bypass line in the boiler room is to be determined and coordinated on site.
6. **On drawing M3.02 detail 7, what is the stacked pumps' branch line size (typ. 3)?**
Pipe size (on the branches) is pump size.

END OF ADDENDUM