



**RETURN BIDS TO:**  
**RETOURNER LES SOUMISSIONS À:**  
Bid Receiving Public Works and Government  
Services Canada/Réception des soumissions  
Travaux publics et Services gouvernementaux  
Canada  
Pacific Region  
401 - 1230 Government Street  
Victoria, B.C.  
V8W 3X4  
Bid Fax: (250) 363-3344

## SOLICITATION AMENDMENT MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address  
Raison sociale et adresse du  
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution  
Public Works and Government Services Canada -  
Pacific Region  
401 - 1230 Government Street  
Victoria, B. C.  
V8W 3X4

<b>Title - Sujet</b> Steel Piling Pipe	
<b>Solicitation No. - N° de l'invitation</b> F1700-150942/A	<b>Amendment No. - N° modif.</b> 003
<b>Client Reference No. - N° de référence du client</b> F1700-150942	<b>Date</b> 2016-03-08
<b>GETS Reference No. - N° de référence de SEAG</b> PW-\$XLV-166-6912	
<b>File No. - N° de dossier</b> XLV-5-38221 (166)	<b>CCC No./N° CCC - FMS No./N° VME</b>
<b>Solicitation Closes - L'invitation prend fin</b> <b>at - à 02:00 PM</b> <b>on - le 2016-03-14</b>	
<b>Time Zone</b> Fuseau horaire Pacific Standard Time PST	
<b>F.O.B. - F.A.B.</b> <b>Plant-Usine:</b> <input type="checkbox"/> <b>Destination:</b> <input type="checkbox"/> <b>Other-Autre:</b> <input type="checkbox"/>	
<b>Address Enquiries to: - Adresser toutes questions à:</b> Castle, David G.	<b>Buyer Id - Id de l'acheteur</b> xlv166
<b>Telephone No. - N° de téléphone</b> (250) 363-0110 ( )	<b>FAX No. - N° de FAX</b> ( ) -
<b>Destination - of Goods, Services, and Construction:</b> <b>Destination - des biens, services et construction:</b>	

Instructions: See Herein

Instructions: Voir aux présentes

<b>Delivery Required - Livraison exigée</b>	<b>Delivery Offered - Livraison proposée</b>
<b>Vendor/Firm Name and Address</b> <b>Raison sociale et adresse du fournisseur/de l'entrepreneur</b>	
<b>Telephone No. - N° de téléphone</b> <b>Facsimile No. - N° de télécopieur</b>	
<b>Name and title of person authorized to sign on behalf of Vendor/Firm</b> <b>(type or print)</b> <b>Nom et titre de la personne autorisée à signer au nom du fournisseur/</b> <b>de l'entrepreneur (taper ou écrire en caractères d'imprimerie)</b>	
<b>Signature</b>	<b>Date</b>

This solicitation amendment #3 is required for the following changes;

1. change ITT clause 1.2.2 Requirement; From: goods must be delivered to identified sites on or before 22 April, **2016**,

**To: goods must be delivered to identified sites on or before 20 May, 2016.**

2. And answer the following question;

Question: Would DFO accept a mix of some sizes Spiral and some sizes Straight Seam?

Answer: if the supplier were able to provide straight seam for the <20m requirement and spiral pipe for the 26m requirement that would be acceptable. In regards to the full length 26m spiral pipe, we would accept a single splice on the 26m spiral weld pipe to extend it to full length, provided the following conditions are met;

- Submit details of proposed pile splices, welding procedures and the electrodes with drawings, welding certifications, and inspection reports at least 21 days prior to the start of fabrication.
- Submit pile schedule indicating splice locations (shop) and proposed lengths of pipe at least 21 days prior to the start of fabrication.
- Welding materials to CSA W59, and must be of such quality as to ensure thorough penetration.
- Welding electrodes must conform to CSAW48, class E49XX.

**All the other instructions, terms and conditions remain unchanged.**