
PART 1 - GENERAL

- 1.1 Description of Work
- .1 This section specifies requirements for the following items:
 - .1 Ladders
 - .2 Mooring cleats
- 1.2 Reference Standards
- .1 ASTM A307-94 (or latest edition), Specification for Carbon Steel Bolts and Studs, 60,000 psi Tensile.
 - .2 CAN/CSA-G40.21-M92 (or latest edition), Structural Quality Steels.
 - .3 CAN/CSA-G164-M92 (or latest edition) - Hot Dip Galvanizing of Irregularly Shaped Articles.
 - .4 ASTM A48-94a (or latest edition), Gray Iron Castings
- 1.3 Related Work
- .1 Refer to other Specification Sections for related information.
 - .2 Refer to Section 01 33 00 for Shop Drawing/Submissions requirements.
- 1.4 Submissions
- .1 Shop Drawings:
 - .1 Clearly indicate the following items:
 - .1 General arrangements, dimensions, clearance locations and directions of assemblies as installed on structures.
 - .2 Locations, sizes and installation tolerances of anchor bolts, eye bolts and embedded parts.
 - .3 Types of materials used, finishes and core thickness.
 - .4 All other pertinent details and accessories.
 - .2 Product Data/Samples:
 - .1 Provide product data and manufacturers brochures for the mooring cleats.
 - .3 Test Results:
 - .1 Provide test results for the galvanized items.

-
- .4 Submissions
.1 Provide submissions in accordance with Section 01 33 00.
- 1.5 Measurement for Payment
.1 Ladders, including timber, rungs, and fasteners will be measured in accordance with Section 01 29 00.
.2 Mooring cleats, including fastenings, will be measured in accordance with Section 01 29 00.

PART 2 - PRODUCTS

- 2.1 Materials
.1 Timber: Any timber supplied by Contractor must conform to Section 06 05 73 Dimension Timber.
.2 Hardware and miscellaneous items must meet the following specifications:
.1 Machine bolts, lag bolts, drift bolts, anchor bolts, nuts, washers to ASTM A307.
.2 Steel plates, ladder rungs, holdfasts and miscellaneous steel: to CSA G40.21, Grade 300W.
.3 Mooring cleats: cast iron to ASTM A48, Class 25, with approximate weight of 41kg (90 lb.) each.
.4 Do not use items manufactured or fabricated from scrap steel of unknown chemical composition or physical properties.
.5 Hot dip galvanize bolts, anchor bolts, nuts, washers, pip sleeves, steel plates, rungs, holdfasts U-bolts and any other miscellaneous steel to CSA G164 with minimum zinc coating of 600 g/m².
.6 The material requirements for installation of light poles are given in the electrical sections/drawings.

PART 3 - EXECUTION

-
- 3.1 Ladders
- .1 Assemble ladder units and install completed units in locations shown on plan or as indicated by *Departmental Representative*.
 - .2 Countersink bolts on exterior face of ladder.
 - .3 Apply preservative to areas of unprotected wood exposed during course of work in accordance with Section 06 05 73.
- 3.2 Mooring Cleats
- .1 Install mooring cleats as shown on drawings and fasten to concrete deck and curb using anchor bolts as indicated. Allow for 25 mm of grout under base.
 - .2 Do not make alternations to any components without written permission of *Departmental Representative*.