



**RETURN BIDS TO:**  
**RETOURNER LES SOUMISSIONS À:**  
**Public Works Government Services Canada- Bid**  
**Receiving / Réception des soumissions**  
**189 Prince William Street**  
**Room 405**  
**Saint John**  
**New Brunswick**  
**E2L 2B9**

## SOLICITATION AMENDMENT MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

### Comments - Commentaires

**Vendor/Firm Name and Address**  
**Raison sociale et adresse du**  
**fournisseur/de l'entrepreneur**

**Issuing Office - Bureau de distribution**  
**Public Works Government Services Canada- Bid**  
**Receiving / Réception des soumissions**  
**189 Prince William Street**  
**Room 405**  
**Saint John**  
**New Bruns**  
**E2L 2B9**

<b>Title - Sujet</b> New GOCB Saint-Léonard, NB	
<b>Solicitation No. - N° de l'invitation</b> EC015-162530/A	<b>Amendment No. - N° modif.</b> 004
<b>Client Reference No. - N° de référence du client</b> R.069499.001	<b>Date</b> 2016-03-15
<b>GETS Reference No. - N° de référence de SEAG</b> PW-\$PWB-013-3833	
<b>File No. - N° de dossier</b> PWB-5-38220 (013)	<b>CCC No./N° CCC - FMS No./N° VME</b>
<b>Solicitation Closes - L'invitation prend fin</b> <b>at - à 02:00 PM</b> <b>on - le 2016-03-24</b>	<b>Time Zone</b> <b>Fuseau horaire</b> Atlantic Daylight Saving Time ADT
<b>F.O.B. - F.A.B.</b> <b>Plant-Usine:</b> <input type="checkbox"/> <b>Destination:</b> <input checked="" type="checkbox"/> <b>Other-Autre:</b> <input type="checkbox"/>	
<b>Address Enquiries to: - Adresser toutes questions à:</b> Johnston, Edward PWB	<b>Buyer Id - Id de l'acheteur</b> pwb013
<b>Telephone No. - N° de téléphone</b> (506) 636-3142 ( )	<b>FAX No. - N° de FAX</b> (506) 636-4376
<b>Destination - of Goods, Services, and Construction:</b> <b>Destination - des biens, services et construction:</b>	

**Instructions: See Herein**

**Instructions: Voir aux présentes**

<b>Delivery Required - Livraison exigée</b>	<b>Delivery Offered - Livraison proposée</b>
<b>Vendor/Firm Name and Address</b> <b>Raison sociale et adresse du fournisseur/de l'entrepreneur</b>	
<b>Telephone No. - N° de téléphone</b> <b>Facsimile No. - N° de télécopieur</b>	
<b>Name and title of person authorized to sign on behalf of Vendor/Firm</b> <b>(type or print)</b> <b>Nom et titre de la personne autorisée à signer au nom du fournisseur/</b> <b>de l'entrepreneur (taper ou écrire en caractères d'imprimerie)</b>	
<b>Signature</b>	<b>Date</b>

Cette modification à l'invitation numéro quatre (4) est soumise pour inclure l'addenda numéro 4 suivant.

La modification qui suie apportée aux documents de soumission entre en vigueur dès maintenant. L'addenda fera partie des documents de contrat.

Toutes autre conditions ne changent pas.

Modification numéro 4

## 1.1 DRAWING AND SPECIFICATION CHANGES

- .1 The following changes to the structural drawings and specifications are to be incorporated in the Bid Documents:
  - .1 Clarification: Lintel L1 is typical and used for openings in masonry up to 2000mm clear unless support is provided by other means (i.e steel). Lintels L2 are located on Drawing 301-2. Lintels L3 are located on Drawing 301-4.
- .2 The following changes to the architectural drawings and specifications are to be incorporated in the Bid Documents:
  - .1 Drawing 200-1 – General Arrangement and Landscape Plan
    - .1 Change detail reference 2/200-2 near Public Entrance to read “1/200-3”
  - .2 Drawing 201-1 – Site Layout Plan
    - .1 Clarification: Trees have been cleared and mulched on site for limit of contract. Contractor will be responsible to clear existing mulch.
  - .3 Drawing 601-3 – Dry Storage Building Plans, Elevations and Section
    - .1 Clarification: 50mm rigid insulation is required at perimeter of slab on grade and foundation walls.
  - .4 Drawing 606-1 – Casework and Interior Elevations Rms 101 and 113
    - .1 Clarification: TVs and associated brackets are NIC.
  - .5 Drawing 606-2 – Casework and Interior Elevations Rms 103, 104 and 114
    - .1 Elevations 1, 2, 3 & 4 for Room 103: Change Ceramic tile base (CT-2) to read “Rubber Base”.
  - .6 Drawing 607-1 – Room Finish and Door Schedule
    - .1 Finish Schedule - Room 140: Delete Floor type Sheet Vinyl Type 1.
    - .2 Finish Schedule – Add Room 159, finishes same as Room 164.
    - .3 Finish Schedule – Room 301: Delete Floor type Concrete.
    - .4 Finish Schedule – Concrete Floor: change to read “Sealed Concrete”.
  - .7 Drawing 607-7 – Flooring Layout Plan
    - .1 See attached Drawing 607-7 – Flooring Layout Plans to be incorporated into tender set.
  - .8 Section 05 50 00 – Metal Fabrications
    - .1 2.5.4.7 Delete reference to Architectural metal post.
  - .9 Section 09 29 00 – Gypsum Board
    - .1 3.3.2 Add: “Corner bead not required at locations noted to receive corner guards.”
  - .10 Section 10 95 00 – Miscellaneous Specialties
    - .1 2.5.1 Change to read “Style: Flush recessed design; compartments lined on bottom. Number of compartments: eight (8), two (2) rows of four (4). Locking: keyed differently.”
    - .2 Add 2.18 CHANNEL GUARDS
      - .1 Resilient channel guard: vinyl/acrylic covering over extruded aluminum retainer; surface mounted, 50.8 mm leg x corner radius as indicated; angle to suit corner.
        - .1 6.4 mm corner radius:

- .1 Acceptable Materials: Model SSM-25MN by Construction Specialties, 160DBN-Series by IPC Door and Wall Protection Systems, Koroguard G110-Series by Koroseal Wall Protection Systems, Pawling Corporation.
  - .2 Covering: 1.9 mm thick high impact vinyl/acrylic extrusions; colour selected by Departmental Representative.
  - .3 Retainer: extruded aluminum, purpose made snap-in type, 1.6 mm thick, continuous for height of guard.
  - .4 Accessories: provide closure caps and fasteners.
- Height: Full height of wall.
- 2.16.3.2 Change to read "Room 301: one (1) required."
- .3 The following changes to the mechanical drawings and specifications are to be incorporated in the Bid Documents:
    - .1 Drawing 2200-1 – Main Floor Plan Sanitary Waste, Vent and Storm Piping
      - .1 Clarification: Floor drains in 103, 116 and 121 are fed from TSP in Room 125.
    - .2 Section 22 42 01 – Plumbing Specialties and Accessories
      - .1 2.7.1 Change to read "Prime floor drain traps with cold water using Precision Plumbing Products PT-10 trap primer (or equivalent) c/w air gap filling and distribution to suite."
  - .4 The following changes to the electrical drawings and specifications are to be incorporated in the Bid Documents:
    - .1 Drawing 2601-2 – Main Floor Plant Electrical
      - .1 Room 120 and Room 119 Layout 1: Change to read "Equipment Racks supplied and installed by Division 27."
    - .2 Drawing 2700-1 - Main Floor Plan Telecommunications and Fire Alarm
      - .1 Add: Provide base radio cable in conduit, per attached Drawing 2700-3 – Base Radio Layout.
      - .2 Room 120 and Room 119 Layout 1: Change to read "Equipment Racks supplied and installed by this Contractor."
    - .3 Section 27 11 16 – Communications Cabinets, Racks, Frames and Enclosures
      - .1 2.1.2 & 2.1.3 are to be supplied with Cabinet.
    - .4 Section 27 15 00 – Communications Horizontal Cabling
      - .1 2.4 Patch cords to be Cat6, not Cat6a.
      - .2 2.4.1 Add: Contractor responsible to determine required patch cord length based on installation. Assume worst case and install actual lengths as required.
      - .3 2.5 Patch cords to be Cat6, not Cat6a.

## 1.2 REQUEST FOR ALTERNATIVES/SUBSTITUTIONS

- .1 The following products and/or equipment and/or systems have been reviewed and will be accepted as equal to the products and/or equipment and/or systems specified, provided all particulars, accessories and/or other adjustments required or specified are included.
  - .1 Section 03 30 00 – Cast In Place Concrete
    - .1 2.1.10.1 Add Ucan Flo Rok FR5.
  - .2 Section 04 05 19 – Masonry Anchorage and Reinforcing
    - .1 2.2.6.1 Add Ucan Flo Rok FR5.
  - .3 Section 05 50 00 – Metal Fabrications
    - .1 2.1.7.1 Add Ucan Flo Rok FR5.
  - .4 Section 27 15 00 – Communications Horizontal Cabling
    - .1 2.1 to 2.8 Alternative products i.e Leviton and Panduit may be used, provided they meet or exceed the Specification.