



RETURN BIDS TO:
RETOURNER LES SOUMISSIONS À:
Bid Receiving Public Works & Government
Services Canada/Réception des soumissions Travaux
publics et Services gouvernementaux Canada
1713 Bedford Row
Halifax, N.S./Halifax,(N.E.)
B3J 1T3
Halifax
Bid Fax: (902) 496-5016

SOLICITATION AMENDMENT

MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution
Atlantic Region Acquisitions/Région de l'Atlantique
Acquisitions
1713 Bedford Row
Halifax, N.S./Halifax, (N.E.)
B3J 3C9
Halifax
Nova Scot

Title - Sujet Reconstruction Clark's Harbour	
Solicitation No. - N° de l'invitation EB144-162575/A	Amendment No. - N° modif. 001
Client Reference No. - N° de référence du client EB144-16-2575	Date 2016-03-15
GETS Reference No. - N° de référence de SEAG PW-\$PWA-110-5375	
File No. - N° de dossier PWA-5-74170 (110)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2016-03-24	Time Zone Fuseau horaire Atlantic Daylight Saving Time ADT
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Collier (PWA), Susan	Buyer Id - Id de l'acheteur pwa110
Telephone No. - N° de téléphone (902) 496-5350 ()	FAX No. - N° de FAX (902) 496-5016
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction:	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

Amendment 001 is being issued to answer questions from a potential bidder as follows:

Question 1:

Existing Conditions and Removals, Sht. 1 of 5

Are any further details of the existing timber crib design and dimensions available?

Answer 1:

There are no as-built drawings for the existing cribwork. The approximate limits are indicated on the drawings. Additional information can be obtained by a site visit and the site is accessible for public access.

Question 2:

Cribwork Details and Sections, Sht. 3 of 5

Elevation view notes the timber binder post as 250x250, however plan and detail views note that they are 200x200.

Please confirm which is correct.

Answer 2:

There is an error in the elevation view as the binder posts for the new cribwork are to be 200x200 timbers.

Elevation view notes the timber binder post as 250x250, however plan and detail views note that they are 200x200. Please confirm which is correct.

See response to question 2.

Question 3:

Cribwork Details and Sections, Sht. 3 of 5

There are reference tags below the typical elevation views in relation to the varying lengths of the longitudinal/face timbers for each of the courses, is there a corresponding schedule available?

Answer 3:

The reference tags are based on proposed varying lengths of the longitudinal timbers (Imperial Measure-feet) which detail staggering the splice locations in the longitudinal courses. The specification section 31 53 13 provide information on submission requirements for the contractor outlining the construction methodology including the timber and splice layout plans.

ALL OTHER TERMS AND CONDITIONS REMAIN THE SAME