

Addendum/Addenda

No./N°

02

Project Description / Description de projet		
M-55, <i>THIRD FLOOR OFFICE RENOVATION</i>		
Solicitation No. / N° de sollicitation	Project No./N° de projet	W.O. No./N° d'ordre de travail
<i>15-22188</i>	M55-5130	
Departmental Representative / Représentant Ministériel	Date	
Mark O'Connor	March 17 th , 2016	
Notice: This addendum shall form part of the tender documents and all conditions shall apply and be read in conjunction with the original plans and specifications.		Nota: Cet addenda fait partie intégrale des dossiers d'appel d'offres; toutes les conditions énoncées doivent être lues et appliquées en conjonction avec les plans et les devis originaux.

ELECTRICAL

.1 DRAWING 5130-E02:

- .1 **Note 1, panel width 14" is mandatory to suit installation on existing column. 14" wide NQ panel is acceptable for that purpose.**

- .2 **Note 1, panel DP-1 trim replacement. A custom designed and manufactured trim is acceptable. Modification to existing trim is not feasible since the panel needs to be operational during the construction other than the panel shut down period.**

