

ADDENDUM NUMBER: THREE (03)

ADDENDUM DATE: March 22, 2016

ISSUED BY: SEPW Architecture Inc.
102 – 3718 Kinnear Place, SK. S7P 0A6
PH. (306) 652-6457

PROJECT: New Modular Police Building and Employee Housing
Black Lake, Saskatchewan

This Addendum forms part of the Contract Documents and amends the original Drawings and Specifications dated 2015-12-04, previous Addenda if applicable and as noted below. This Addendum consists of 1 page.

Ensure that all parties are aware of all items included in this Addendum.

The following revised or additional Drawings accompany and form an integral part of this Addendum:

Dwg. No.	Title	Date of Issue
Specification Section No.		

ELECTRICAL

E-3-1 REF. SECTION 28 31 01 FIRE ALARM SYSTEM

- Add: Smoke Detector Protective Cages:** Detectors mounted in Rooms 136, 137, 138, 139, 141, 142, 159 and 160 shall have protective cages installed as indicated on the drawings and details. Cages shall be one of the following models: Simplex model 2098-9829C, GE security model 6255-004 or Notifier G1A-2.

END OF ADDENDUM NO. 03